

**Bay County**

License Number: 1305148

TWEEN BAYS MOTEL

License Type: Motel

4508 W HWY 98, PANAMA CITY 32401

Inspection Date: 03/30/2022

Inspection Number: 1221599

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Hearing impaired smoke detector makes audible noise, no visible flash. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1505757

M I SUNSHINE MANAGEMENT LLC

License Type: Apartment

900 906 KNOX MCRAE DR APT 5, TITUSVILLE 32780

Inspection Date: 03/31/2022

Inspection Number: 1528538

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: FRANZ, LINDA

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Red gas cab stored under stairs near unit 902.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1502506

HILTON MELBOURNE BEACH OCEANFRONT

License Type: Hotel

3003 N HWY A1A, MELBOURNE 32903

Inspection Date: 03/29/2022

Inspection Number: 1161701

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MITTEN, JAMES

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.  
Working on system \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1602546

BROWARD MULTIFAMILY LLC

License Type: Apartment

750 NW 9 AVE, HALLANDALE 33009

Inspection Date: 03/29/2022

Inspection Number: 1515474

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation CodeObservationViolation Citation

06-03-4

Some windows on building 750 blocked with ply wood. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1621504

VENTURA POINTE

License Type: Apartment

7850 PASADENA BLVD, PEMBROKE PINES 33024

Inspection Date: 03/30/2022

Inspection Number: 1531804

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MCKINNEY, JOHN

Violation CodeObservationViolation Citation

01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Building 7800 - located in the west facing corridor o& the ground floor nearest units 112 & 113	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building 7800 SE facing corridor of the ground floor nearest unit 110	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

---

License Number: 1613418

GALLERYONE - A DOUBLETREE SUITES BY HILTON HOTELS

License Type: Hotel

2670 E SUNRISE BLVD, FORT LAUDERDALE 33304

**Broward County**

Inspection Date: 03/29/2022

Inspection Number: 1164317

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code    ObservationViolation Citation

04-01-4            Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Per operator, the system is in test mode due to construction.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4            Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1601407

GALLERY INVESTMENT LLC

License Type: Apartment

1801 CORAL RIDGE DR, FORT LAUDERDALE 33305

Inspection Date: 03/31/2022

Inspection Number: 1526000

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DEJONG, STEVEN

Violation Code

Observation

Violation Citation

01-04-4 No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Broward County**

License Number: 1621763

THE ISLES

License Type: Apartment

4781 SW 39 WAY, FORT LAUDERDALE 33312

Inspection Date: 04/01/2022

Inspection Number: 1534364

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: BARTON, GEOFFREY

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Bldg 9 at unit 3907.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1617783

PALM TRACE LANDINGS

License Type: Apartment

6351 PALM TRACE LANDINGS DR, DAVIE 33314

Inspection Date: 03/29/2022

Inspection Number: 1514748

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation Code

Observation

Violation Citation

01-01-4      Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.  
Next to unit 309 bldg 13 6000

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Clay County**

License Number: 2000920

STAY SUITES OF AMERICA

License Type: Hotel

1656 WELLS RD, ORANGE PARK 32073

Inspection Date: 03/28/2022

Inspection Number: 1164303

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: BIAVA, GRANT

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
Expired 3/27/2022

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2328950

EL PARAISO MOTEL

License Type: Motel

1615 W OKEECHOBEE RD, HIALEAH 33010

Inspection Date: 03/31/2022

Inspection Number: 1220593

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PRIETO, EDGAR

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2312644

GARDEN INN HOMESTEAD

License Type: Motel

51 SOUTH HOMESTEAD BLVD, HOMESTEAD 33030

Inspection Date: 04/01/2022

Inspection Number: 1221202

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One next to room 128. One next to room 228. One next to room 238. One next to room 234. One next to room 134.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2327186

HOMESTEAD PORTFOLIO LP

License Type: Apartment

30100 OLD DIXIE HWY, HOMESTEAD 33030

Inspection Date: 03/29/2022

Inspection Number: 1534537

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: LEIDECKER, EDILMA

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located between unit 3 and 5. And one located between unit 20 and 21.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2307671

REMINGTON APARTMENTS

License Type: Apartment

460 NW 6 ST, HOMESTEAD 330305767

Inspection Date: 03/31/2022

Inspection Number: 1525104

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located at 521 N.W. 5th AVE, between unit 5 and 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2309662

FLORIDA CITY RENTAL LLC

License Type: Apartment

567 - 575 W PALM DR, FLORIDA CITY 33034

Inspection Date: 03/28/2022

Inspection Number: 1526390

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed portable fire extinguisher locked in a box located at second floor. **\*\*Warning\*\*** - From foll

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2328078

LA VECINDAD

License Type: Apartment

771 W LUCY ST, FLORIDA CITY 33034

Inspection Date: 03/28/2022

Inspection Number: 1514699

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between unit 771 and 773.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2301814

KILZI BROS &amp; SONS LLC

License Type: Apartment

2345 Nw FLAGLER TERR, MIAMI 33125

Inspection Date: 03/29/2022

Inspection Number: 1521888

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between units 5 and 6  
\*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2303311

METRO MCG PROPERTIES INC

License Type: Apartment

700 NW 15TH AVE, MIAMI 33125

Inspection Date: 03/29/2022

Inspection Number: 1514174

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between units 9 and 10; between units 3 and 4 \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2305117

YURIANI INVESTMENTS LLC

License Type: Apartment

611 NW 14 AVE, MIAMI 33125

Inspection Date: 03/29/2022

Inspection Number: 1519030

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed between units 1 and 2; next to unit 6

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to unit 8

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330222

WAGNER CREEK

License Type: Apartment

1501 NW 13 CRT, MIAMI 33125

Inspection Date: 03/31/2022

Inspection Number: 1526654

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILCHEZ, NABEL

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330560

LANTOWER RIVER LANDING

License Type: Apartment

1500 NW N RIVER DR, MIAMI 33125

Inspection Date: 03/30/2022

Inspection Number: 1532054

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILCHEZ, NABEL

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2312995 1510 PROPERTIES LLC C/O CHARLES PEREZ

License Type: Apartment 1558 NW 1 ST, MIAMI 331255536

Inspection Date: 03/29/2022

Inspection Number: 1531972

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SAENZ, HILDA

Violation Code    ObservationViolation Citation

01-06-4      Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device between apt # 8 & 7.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330780

GRAND STATION APARTMENTS

License Type: Apartment

240 N MIAMI AVE, MIAMI 33128

Inspection Date: 03/28/2022

Inspection Number: 1534706

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: CUDEMOS, VIRNA

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2301611

MERDA DO MONE APTS

License Type: Apartment

1552 SW 2 ST, MIAMI 33135

Inspection Date: 04/01/2022

Inspection Number: 1519255

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Warning\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2313458

INSANOVA INVESTMENTS INC

License Type: Apartment

1418 SW 7 ST, MIAMI 33135

Inspection Date: 04/01/2022

Inspection Number: 1531962

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.  
Fire extinguisher located on the second floor by unit 5.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2328431

SIXTO APTS

License Type: Apartment

1322 SW 7 ST, MIAMI 33135

Inspection Date: 03/30/2022

Inspection Number: 1513626

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.  
Fire extinguisher located between unit 7 and 5.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329715

MEMEC USA LLC

License Type: Apartment

1553 SW 2 ST, APTS 1,4,5,6,7,9,12,15,16,21, MIAMI 33135

Inspection Date: 04/01/2022

Inspection Number: 1514344

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Warning\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2300670

MC FIG LLC

License Type: Apartment

1623 LENNOX AVE, MIAMI BEACH 33139

Inspection Date: 04/01/2022

Inspection Number: 1534408

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329231

BREAKWATER HOTEL

License Type: Hotel

940 - 960 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 04/01/2022

Inspection Number: 1162761

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329994

License Type: Apartment

5601 COLLINS AVE UNIT # 1402, MIAMI BEACH 33140-2412

Inspection Date: 04/01/2022

Inspection Number: 1528837

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation Code    Observation

Violation Citation

08-03-4    No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2304224

M K APARTMENTS

License Type: Apartment

7351 GARY AVE, MIAMI BEACH 331412530

Inspection Date: 03/28/2022

Inspection Number: 1525169

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device in fire extinguisher box by unit 9. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2329441

FRIENDSHIP TOWER APARTMENTS

License Type: Apartment

1551 NW 36 ST, MIAMI 33142

Inspection Date: 03/29/2022

Inspection Number: 1514864

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BROWN, JARON

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.  
Observed 1010

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2329376

WOODSPRING SUITES MIAMI SOUTHWEST

License Type: Hotel

16055 SW 117 AVE, MIAMI 33177

Inspection Date: 03/29/2022

Inspection Number: 1162881

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Observed system trouble light illuminated. **\*\*Repeat Violation\*\*** - From follow-up inspection 2022-03-29: At the time of the inspe

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2327833

MIAMI AIRPORT WEST/DORAL TOWNEPLACE SUITES

License Type: Hotel

10505 NW 36 ST, MIAMI 33178

Inspection Date: 04/01/2022

Inspection Number: 1164338

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CURRAS, YANLEE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2611854

OAK HAMMOCK APARTMENTS

License Type: Apartment

500 ACME ST, JACKSONVILLE 32211

Inspection Date: 04/01/2022

Inspection Number: 1533425

Inspection Type: Lodging-Licensing

Inspection Disposition: Call Back -

Inspector Name: THOMAS, PHILIP

Inspection

Extension given, pending

Violation CodeObservationViolation Citation

12-04-4

- From initial inspection : High Priority - Balcony/starway/platform collapsed. Building 6 has collapsed landing between first and second floor. Entire landing has fallen 6 feet and is resting on ground. Stairs leading down from second floor end with 6

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

**Duval County**

License Number: 2609493

ISLAND POINTE APARTMENTS LLC

License Type: Apartment

1000 BROWARD RD, JACKSONVILLE 32218

Inspection Date: 03/30/2022

Inspection Number: 1534748

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In apt 903

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

**Hillsborough County**

---

License Number: 3911434

FAIRFIELD INN & SUITES BY MARRIOTT

License Type: Hotel

10150 PALM RIVER RD, TAMPA 33619



**Hillsborough County**

Inspection Date: 03/29/2022

Inspection Number: 1161050

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: KLUSENDORF, JEANNE

Violation Code    ObservationViolation Citation

08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Boiler 122068	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3912329

HILTON GARDEN INN TAMPA NORTH

License Type: Hotel

13305 TAMPA OAKS BLVD, TEMPLE TERRACE 33637

Inspection Date: 03/31/2022

Inspection Number: 1163182

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: REGAS, ANTHONY

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed the boiler certificate expired 3-17-22, Jurisdiction 12450.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Leon County**

License Number: 4700019

SABAL COURT PARTNERS LLC

License Type: Apartment

2125 JACKSON BLUFF RD, TALLAHASSEE 32304

Inspection Date: 03/28/2022

Inspection Number: 1534718

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVILA, NELSON

Violation Code

Observation

Violation Citation

07-04-4 Exposed wiring on AC unit by w203. Panel removed from unit and left on the ground.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Leon County**

License Number: 4700044

THE URBANA APARTMENTS LLC

License Type: Apartment

319 HAYDEN RD, TALLAHASSEE 32304

Inspection Date: 03/30/2022

Inspection Number: 1534089

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: DAVILA, NELSON

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.  
Observed outside wires exposed due to cover damage.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5803452

DAYS INN AT CIVIC CENTER

License Type: Motel

9990 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 03/29/2022

Inspection Number: 1222562

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5809006

EXTENDED STAY AMERICA #9809

License Type: Hotel

8687 COMMODITY CIR, ORLANDO 32819

Inspection Date: 03/29/2022

Inspection Number: 1163143

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811120

HILTON ORLANDO

License Type: Hotel

6001 DESTINATION PWKY, ORLANDO 32819

Inspection Date: 03/31/2022

Inspection Number: 1163622

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation Code

Observation

Violation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5803843

CLARION INN INTERNATIONAL DRIVE

License Type: Hotel

8444 INTERNATIONAL DR, ORLANDO 32819-9329

Inspection Date: 04/01/2022

Inspection Number: 1164286

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: BACHOO, SAVITRI

Violation Code

Observation

Violation Citation

08-04-4 Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Osceola County**

**Osceola County**

---

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

**Osceola County**

Inspection Date: 03/31/2022

Inspection Number: 1164325

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By room 557 - From follow-up inspection 2022-03-31: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By room 557	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing striker by 349 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing striker by 349 **Repeat Violation** - From follow-up inspection 2022-03-31: **Time Extended	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-03-31: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

## Osceola County

08-01-4 - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2022-03-31:  
\*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014044

HAWTHORN SUITES WEST PALM BEACH

License Type: Hotel

301 LAMBERTON DR, WEST PALM BEACH 33401

Inspection Date: 03/29/2022

Inspection Number: 1163181

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: FRANCO, BROOKE

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Palm Beach County**

License Number: 6011863

SANCTUARY COVE APARTMENT

License Type: Apartment

700 SANCTUARY COVE DR, NORTH PALM BEACH 33410

Inspection Date: 03/31/2022

Inspection Number: 1521156

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOLDMAN, BARRY

Violation Code    Observation

Violation Citation

02-08-4      Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Building 992-1003, 928-939 - gas Grill under first floor stairwell. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6012381

HAMPTON INN & SUITES PALM BEACH GARDENS

License Type: Hotel

4001 RCA BLVD, PALM BEACH GARDENS 33410

Inspection Date: 03/31/2022

Inspection Number: 1162257

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOLDMAN, BARRY

Violation Code

Observation

Violation Citation

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. J# 092399, 092398 - 12/18/21

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6004162

E K L APARTMENTS

License Type: Apartment

133 NW AVE B, BELLE GLADE 33430-2643

Inspection Date: 03/28/2022

Inspection Number: 1518856

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SEVILLA, FREDDY

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Throughout the property

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6205545

MARISOL VISTA APARTMENTS

License Type: Apartment

1280 N 102 AVE, ST. PETERSBURG 33716

Inspection Date: 03/30/2022

Inspection Number: 1534654

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Breezeway leading up to 18-111 \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6206320

THE PALMS AT COUNTRYSIDE

License Type: Apartment

25350 US INTERSTATE 19, CLEARWATER 33763

Inspection Date: 03/31/2022

Inspection Number: 1524530

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: BENEDICT, TRACY

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Building 22 Apt 208. - From follow-up inspection 2022-03-31: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Putnam County**

License Number: 6400038

FT GATES FERRY-GATEWAY FISH CP

License Type: Motel

229 FORT GATES FERRY RD, CRESCENT CITY 32112

Inspection Date: 03/28/2022

Inspection Number: 1217341

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher by unit 10.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Putnam County**

License Number: 6400785

ANDERSEN'S LODGE AND ANDERSEN'S BAR & GRILL

License Type: Motel

10 BOSTON ST, WELAKA 32193

Inspection Date: 03/30/2022

Inspection Number: 1217709

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguishers in laundry area and on deck of unit 15.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6804704

HOLIDAY INN EXPRESS & SUITES SARASOTA EAST/I-75

License Type: Hotel

5730 GANTT RD, SARASOTA 34233

Inspection Date: 04/01/2022

Inspection Number: 1163291

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: CATTLEY, RAYMOND

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light on main panel. - From follow-up inspection 2022-04-01: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Sarasota County**

License Number: 6800192

BAYMONT INN & SUITES

License Type: Motel

1425 S TAMIAMI TRL, SARASOTA 34239

Inspection Date: 03/28/2022

Inspection Number: 1222426

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CATTLEY, RAYMOND

Violation Code

Observation

Violation Citation

04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed Honeywell panel at front desk with Trouble (2) listed.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6903746

LAKE'S EDGE APARTMENTS

License Type: Apartment

1000 PLANTATION LAKES CIR, SANFORD 32771

Inspection Date: 03/30/2022

Inspection Number: 1516412

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

**Volusia County**

---

License Number: 7406415

HAMPTON INN DAYTONA SPEEDWAY AIRPORT

License Type: Hotel

1715 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

**Volusia County**

Inspection Date: 03/31/2022

Inspection Number: 1160494

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

- 04-01-4      Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Manager states has called tech
- 06-01-4      Path to door marked as an exit is blocked. For reporting purposes only.  
-By 301,201 caution tape on front of exit door- manager states painting stairway.  
Maintenance states removing tape because floor should be dry.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. F1136520 **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-06-4	Combustibles stored in boiler room. For reporting purposes only. -ceiling Tiles in boxes stored next to boiler	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7405960

SANS SOUCI APARTMENT'S

License Type: Apartment

238 N SANS SOUCI AVE, DELAND 32720

Inspection Date: 03/30/2022

Inspection Number: 1520727

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: OCASIO-LOPEZ, LISA

Violation Code

Observation

Violation Citation

12-04-4

High Priority - Balcony/stairway/platform . 3rd floor in front of Apt. 5, platform missing section of wood due to wood rot. **\*\*Warning\*\***

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

**Walton County**

License Number: 7601179

SUPER 8 MOTEL

License Type: Motel

402 HUGH ADAMS RD, DEFUNIAK SPRINGS 32433

Inspection Date: 04/01/2022

Inspection Number: 1221762

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between rooms 233/232, 221/220 & 118/117. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-02-4

Frayed electrical wire(s). For reporting purposes only. Wires hanging from under roof into walkway at back right of building. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.