

Brevard County

License Number: 1502303

AMERICA'S BEST VALUE INN

License Type: Motel

180 HWY A1A, SATELLITE BCH 329372042

Inspection Date: 04/07/2022

Inspection Number: 1222608

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: VAUGHAN, COURTNEY

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Missing fire extinguisher by room 125

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620867

CAMBRIA SUITES FT LAUDERDALE

License Type: Hotel

141 SW 19 CT, DANIA 33004

Inspection Date: 04/06/2022

Inspection Number: 1164366

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: LONDONO, GLORIA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Per operator, there is an open permit. **Corrective Action Taken**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620885

BEACHWALK RESORT

License Type: Hotel

2600 E HALLANDALE BEACH BLVD, HALLANDALE BEACH 33009

Inspection Date: 04/06/2022

Inspection Number: 1163342

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621764

1818 PARK

License Type: Apartment

1818 HOLLYWOOD BLVD, HOLLYWOOD 33020

Broward County

Inspection Date: 04/05/2022

Inspection Number: 1534368

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Warning
Issued

Inspector Name: CHRISTGEN, THOM

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2022-04-07: Same - pending installation of fan and inspection per Maintenance Engineer. **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329828

THE BUSH INVESTMENT SVCS

License Type: Apartment

317 SW 5 AVE, HOMESTEAD 33030

Inspection Date: 04/05/2022

Inspection Number: 1526548

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed portable fire extinguisher locked in a box in front of u it 5.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2320410

YES MOTEL

License Type: Motel

28475 S DIXIE HWY, HOMESTEAD 33033

Inspection Date: 04/07/2022

Inspection Number: 1222147

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GONZALEZ, RICARDO

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed no breaking device for fire extinguisher by apartment 30.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2322094

DAYS INN

License Type: Motel

124 E PALM DR, FLORIDA CITY 33034

Inspection Date: 04/05/2022

Inspection Number: 1220924

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed one portable fire extinguisher missing from it's designed location in front of room 111.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329349

DABRE LLC

License Type: Apartment

1330 NW 5 ST, MIAMI 33125

Inspection Date: 04/08/2022

Inspection Number: 1481351

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher with no breaking device, located in front of unit number 5. - From follow-up inspection 2022-04-08: Observed fire extinguisher with with no breaking device, located in front of unit number 5. ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330533

DOWNTOWN VILLAS

License Type: Apartment

419 NW 8 ST, MIAMI 33136

Inspection Date: 04/08/2022

Inspection Number: 1531673

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By 102. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2304637

TIFFANY HOTEL

License Type: Hotel

801 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 04/08/2022

Inspection Number: 1163339

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

121051 expired 6/19/20, 121050 expired 6/19/20

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329209

THE TONY HOTEL

License Type: Hotel

800 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 04/06/2022

Inspection Number: 1163432

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

121051 expired 6/19/20, 121050 expired 6/19/20

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329281

THE LESLIE HOTEL

License Type: Hotel

1244 OCEAN DR, MIAMI BEACH 33139

Inspection Date: 04/06/2022

Inspection Number: 1163319

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Located near laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Located near laundry room.
Operator unlocked box. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329419

LENNOX MIAMI

License Type: Hotel

1900 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 04/04/2022

Inspection Number: 1162691

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel located at front desk office area. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2321194

621 LENOX APTS

License Type: Apartment

621 LENOX AVE, MIAMI BEACH 331395988

Inspection Date: 04/06/2022

Inspection Number: 1518144

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Located on 1st floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305153

SIERRAS #1 CORPORATION

License Type: Apartment

7124 BAY DR, MIAMI BEACH 33141

Inspection Date: 04/08/2022

Inspection Number: 1519843

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device for fire extinguisher boxes by units 2 and 5.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2307985

6936 BYRON AVE LLC

License Type: Apartment

6936 BYRON AVE, MIAMI BEACH 33141

Inspection Date: 04/07/2022

Inspection Number: 1531884

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device for fire extinguisher box by unit 1. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330786

RUSTO KOLENOVIC AND SADIKA KOLENOVIC

License Type: Apartment

6918 BAY DR, MIAMI BEACH 33141

Inspection Date: 04/05/2022

Inspection Number: 1534835

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: PRIETO, VICENTE

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed fire panel not connected.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2322259

BOWERY EVANS LLC

License Type: Apartment

31 NW 77 ST, MIAMI 33150

Inspection Date: 04/07/2022

Inspection Number: 1534809

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: JOSEPH, VANRIE

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330261

PALMETTO STATION

License Type: Apartment

17945 SW 97 AVE, PALMETTO BAY 33157

Inspection Date: 04/08/2022

Inspection Number: 1524494

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: SWIGERT, RICHARD

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed the panel in trouble mode located by front door. - From follow-up inspection 2022-04-08: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed the panel in trouble mode located by front door. **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308829

1755 APARTMENTS

License Type: Apartment

1755 NE 164 ST, NORTH MIAMI BEACH 33162

Inspection Date: 04/07/2022

Inspection Number: 1534871

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: STUBBS, CHRISTINE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light is on. ****Warning****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324535

THE PARK AT SHEFFIELD

License Type: Apartment

15601 SW 137 AVE, MIAMI 33177

Inspection Date: 04/07/2022

Inspection Number: 1519548

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located between unit 110 and 109.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2315280

JW MARRIOTT MIAMI TURNBERRY RESORT & SPA

License Type: Hotel

19999 W COUNTRY CLUB DR, AVENTURA 33180

Inspection Date: 04/05/2022

Inspection Number: 1163341

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2609313

RED ROOF INN

License Type: Motel

10901 HARTS RD, JACKSONVILLE 32218

Inspection Date: 04/04/2022

Inspection Number: 1222595

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher by room 301. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902852

THE GODFREY HOTEL AND CABANAS

License Type: Hotel

7700 W COURTNEY CAMPBELL CAUSEWAY, TAMPA 33607

Inspection Date: 04/07/2022

Inspection Number: 1163093

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902668

BEARRS INN & SUITES

License Type: Motel

400 E BEARRS AVE, TAMPA 33613

Inspection Date: 04/07/2022

Inspection Number: 1220833

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: REGAS, ANTHONY

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3901892

RANCH HOUSE MOTEL

License Type: Motel

2909 S 50 ST, TAMPA 336196045

Inspection Date: 04/06/2022

Inspection Number: 1218129

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near room 18

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3906758

THE DAWSON

License Type: Apartment

15501 BRUCE B DOWNS BLVD, TAMPA 33647

Hillsborough County

Inspection Date: 04/06/2022

Inspection Number: 1534875

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: POWELL, DAVID

Violation CodeObservationViolation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher dials displaying recharge on several buildings	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguishers missing from several buildings	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

04-06-4 Fire alarm control panel emitting an audible alarm. For reporting purposes only. Observed panel sounding alert on building 30, 17

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605198

DAYS INN & SUITES

License Type: Hotel

10150 DANIELS PKWY, FORT MYERS 33913

Inspection Date: 04/06/2022

Inspection Number: 1164364

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: CANDO, JOHANA

Violation Code

Observation

Violation Citation

07-02-4

Frayed electrical wire(s). For reporting purposes only. Observed exposed wires by pipe line in the first floor staircase garbage exit door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605264

HOMEWOOD SUITES BY HILTON BONITA SPRINGS

License Type: Hotel

8901 HIGHLAND WOODS BLVD, BONITA SPRINGS 34135

Inspection Date: 04/07/2022

Inspection Number: 1164004

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DOMKOWSKI, DANIEL

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Two boiler certificates expired on 10/23/2021.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

Leon County

License Number: 4703110

HOTEL INDIGO - TALLAHASSEE COLLEGE TOWN

License Type: Hotel

826 W GAINES ST, TALLAHASSEE 32304

Leon County

Inspection Date: 04/05/2022

Inspection Number: 1162985

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DAVILA, NELSON

Violation CodeObservationViolation Citation

08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5402143

REEFHUSE RESORT & MARINA

License Type: Hotel

103800 OVERSEAS HWY, KEY LARGO 33037

Inspection Date: 03/23/2022

Inspection Number: 1163367

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5401245

PEGASUS INT HOTEL

License Type: Hotel

501 SOUTHARD ST, KEY WEST 330406835

Inspection Date: 04/05/2022

Inspection Number: 1159850

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800094

WESTGATE LAKES RESORT AND SPA

License Type: Vacation Rental - Condo

10000 TURKEY LAKE RD, ORLANDO 32819

Inspection Date: 04/08/2022

Inspection Number: 1089439

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801823

FOUR POINTS BY SHERATON ORLANDO INTERNATIONAL DRIVE

License Type: Hotel

5905 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 04/06/2022

Inspection Number: 1162271

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: KOSTELNY, ROGER

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

FL304076 exp 11/21/21, FL 283590 exp 11/21/21 - From follow-up inspection 2022-04-06: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809992

HARD ROCK HOTEL

License Type: Hotel

5800 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 04/08/2022

Inspection Number: 1164355

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Main room behind security has trouble light
Ground fault loop #3

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5803629

HYATT REGENCY GRAND CYPRESS

License Type: Hotel

1 GRAND CYPRESS BLVD, ORLANDO 32836

Inspection Date: 04/08/2022

Inspection Number: 1164380

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5914876

VACATION VILLAGE AT PARKWAY OWNER'S ASSOCIATION INC

License Type: Vacation Rental - Condo

2949 ARABIAN NIGHTS BLVD, KISSIMMEE 34747

Inspection Date: 04/04/2022

Inspection Number: 1089413

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Building 20 has 8 boilers and no boiler certificate. - From follow-up inspection 2022-02-28: ****Time Extended**** - From follow-up inspection 2022-04-04: Establishment has applied for the certificates ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6010741

HOLIDAY INN EXPRESS

License Type: Hotel

13950 US HWY 1, JUNO BEACH 33408-1697

Inspection Date: 04/05/2022

Inspection Number: 1161813

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Main lobby panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6205421

SUPER 8 MOTEL

License Type: Motel

22950 HWY 19 N, CLEARWATER 33765

Inspection Date: 04/07/2022

Inspection Number: 1222568

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: PEARCE, LAURA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel in closed in front desk area . For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6301106

MARREX APARTMENTS

License Type: Apartment

1109 E ORANGE ST, LAKE LAND 33801

Inspection Date: 04/07/2022

Inspection Number: 1526255

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: POWELL, DAVID

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. No observable fire extinguishers present outside of the buildings. Unable to confirm presence in each unit as an office or manager are not present.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903585

HILTON GARDEN INN ORLANDO NORTH-LAKE MARY FL

License Type: Hotel

705 CURRENCY CIR, LAKE MARY 32746

Inspection Date: 04/06/2022

Inspection Number: 1162430

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System in trouble , operas working with its vendor to repair

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400133

SEA SHELLS BEACH RESORT

License Type: Motel

1014 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 04/05/2022

Inspection Number: 1222079

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

02-07-4

Flammable chemicals stored near a source of ignition. For reporting purposes only.

-large bag of charcoal stored up against water heater with open flame vent stack, -employee moved **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406511

TROPIC AIRE MOTEL

License Type: Motel

1000 S ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 04/05/2022

Inspection Number: 1221180

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

08-06-4

Combustibles stored in water heater/boiler room. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.