

**Broward County**

License Number: 1602351

COLLINS APTS 10

License Type: Apartment

2307 - 2338 PERSHING ST BLDG 1-21, HOLLYWOOD 33020

Inspection Date: 04/12/2022

Inspection Number: 1525910

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

1. Observed on the North side of Building 3.
2. Observed on the South side of Building 8.
3. Observed on the South side of Building 9.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2300399

PEREZ APTS

License Type: Apartment

310 E 21 ST, HIALEAH 330102748

Inspection Date: 04/15/2022

Inspection Number: 1520386

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: PRIETO, EDGAR

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By unit #5. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330791

THE LANDINGS AT HOMESTEAD

License Type: Apartment

201-301 NE 11 ST, HOMESTEAD 33030

Inspection Date: 04/12/2022

Inspection Number: 1534897

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: LEIDECKER, EDILMA

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2328955

SUPER 8 MOTEL

License Type: Motel

1196 N KROME AVE, FLORIDA CITY 33034

Inspection Date: 04/12/2022

Inspection Number: 1221696

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located between unit 139 and unit 140. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2325791

COURTYARD MIAMI AIRPORT

License Type: Hotel

1201 NW 42 AVE, MIAMI 33126

Inspection Date: 04/13/2022

Inspection Number: 1159400

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MARTINEZ, YANET

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed all boilers certificate expired since October 08, 2021.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329205

RESIDENCE INN BY MARRIOTT MIAMI AIRPORT SOUTH

License Type: Hotel

1201 NW LEJEUNE RD, MIAMI 33126

Inspection Date: 04/13/2022

Inspection Number: 1159321

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTINEZ, YANET

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2307611

MIAMI AIRPORT MARRIOTT- FULL SERVICE

License Type: Hotel

1201 NW 42 AVE, MIAMI 331262656

Inspection Date: 04/13/2022

Inspection Number: 1164003

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MARTINEZ, YANET

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed all boilers certificate expired since October 08, 2021. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330271

5805 NW 7 LLC

License Type: Apartment

5805 NW 7 PLACE, MIAMI 33127

Inspection Date: 04/11/2022

Inspection Number: 1522521

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at the First floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2301578

LAWRENCE ESTATES LLC

License Type: Apartment

1045 NW 1 ST, MIAMI 33130

Inspection Date: 04/15/2022

Inspection Number: 1525876

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device next to apartment 2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2311987

SONG AND DANCE LLC

License Type: Apartment

1043 SW 3 ST, MIAMI 33130

Inspection Date: 04/15/2022

Inspection Number: 1530244

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device located next to apartment 2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2312089

BRICKELL GATE INC

License Type: Apartment

1040 SW 7 ST, MIAMI 33130

Inspection Date: 04/15/2022

Inspection Number: 1521358

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed breaking device missing next to Apartment 2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329412

DYNAMIC HOTEL

License Type: Hotel

637 W FLAGLER ST, MIAMI 33130

Inspection Date: 04/14/2022

Inspection Number: 1162855

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330313

DYNAMIC HOTEL

License Type: Apartment

637 W FLAGLER ST, MIAMI 33130

Inspection Date: 04/14/2022

Inspection Number: 1524526

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329494

YOTEL MIAMI

License Type: Hotel

227 NE 2 ST, MIAMI 33132

Inspection Date: 04/13/2022

Inspection Number: 1162318

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: CUDEMOS, VIRNA

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed boiler #354981, #354962, #352591, #353113 no boiler certificate.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2308521

FAMILY APT

License Type: Apartment

2102 SW 3 ST, MIAMI 331351822

Inspection Date: 04/11/2022

Inspection Number: 1513241

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. It's floor extinguisher.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2311336

LENDOIRO BUILDING

License Type: Apartment

1545 SW 5 ST, MIAMI 331353731

Inspection Date: 04/13/2022

Inspection Number: 1529922

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

06-02-4

Door marked as an exit is blocked. For reporting purposes only. Observed  
A piece of furniture blocking Exterior Exit second-floor hallway. \*\*Repeat  
Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2304413

BP 825 LLC

License Type: Apartment

825 ALTON RD, MIAMI BEACH 33139

Inspection Date: 04/14/2022

Inspection Number: 1519087

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.  
Observed in front of the building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2304622

1346 ALTON LLC

License Type: Apartment

1334 ALTON RD, MIAMI BEACH 33139

Inspection Date: 04/12/2022

Inspection Number: 1526398

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Observed on building 1346.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2306187

650 MICHIGAN AVE LLC

License Type: Apartment

650 MICHIGAN AVE, MIAMI BEACH 33139

Inspection Date: 04/13/2022

Inspection Number: 1532826

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.  
Located on 1st floor, near apartment 8.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329171

Z OCEAN

License Type: Hotel

1437 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 04/11/2022

Inspection Number: 1162400

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired for justification number 122631 expiration date 3/04/2022. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329320

NAUTILUS

License Type: Hotel

1825 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 04/11/2022

Inspection Number: 1163830

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. By the front desk: door with fire panel. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. FI 133322, 06/03/22, by mechanical room 203, alley. \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329342

ABAE HOTEL

License Type: Hotel

1215 WEST AVE, MIAMI BEACH 33139

Inspection Date: 04/12/2022

Inspection Number: 1162868

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2329483

URBANICA FIFTH HOTEL

License Type: Hotel

803 5 ST, MIAMI BEACH 33139

**Dade County**

Inspection Date: 04/12/2022

Inspection Number: 1162039

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located on 4th floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed water heater with a temperature of 210F.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330260

SURF STYLE

License Type: Apartment

1208 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 04/11/2022

Inspection Number: 1520247

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2309346

MANATEE APTS

License Type: Apartment

1361 EUCLID AVE, MIAMI BEACH 331393936

Inspection Date: 04/15/2022

Inspection Number: 1525114

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located near mailboxes. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2301677

SUNBRITE APARTMENTS

License Type: Apartment

1330 PENNSYLVANIA AVE, MIAMI BEACH 331394029

Inspection Date: 04/12/2022

Inspection Number: 1514860

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILLIAMS, ALFREDA

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2308061

JERRICO APARTMENTS

License Type: Apartment

235 78 ST, MIAMI BEACH 331412189

Inspection Date: 04/14/2022

Inspection Number: 1515628

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device in fire extinguisher boxes by units 4, 15, 17, and 27.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2314861

SHERATON MIAMI AIRPORT HOTEL &amp; EXECUTIVE MEETING CENTER

License Type: Hotel

3900 NW 21 ST, MIAMI 33142

Inspection Date: 04/15/2022

Inspection Number: 1163879

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PRIETO, EDGAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329201

GOLDEN TOWERS

License Type: Apartment

5545 NW 17 AVE 5545-55, MIAMI 33142

Inspection Date: 04/13/2022

Inspection Number: 1525724

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: BROWN, JARON

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.  
Observed fire extinguisher next to unit 3 missing breakage device.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2301987

GHG ON MEMORIAL LLC

License Type: Apartment

13210 MEMORIAL HWY, NORTH MIAMI 33161

Inspection Date: 04/11/2022

Inspection Number: 1534807

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: SUAREZ, LEOPOLDO

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2308829

1755 APARTMENTS

License Type: Apartment

1755 NE 164 ST, NORTH MIAMI BEACH 33162

Inspection Date: 04/13/2022

Inspection Number: 1534946

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: VILCHEZ, NABEL

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2314402

HONEYSUCKLE APARTMENTS

License Type: Apartment

10715 SW 3RD ST, SWEETWATER 33174

Inspection Date: 04/12/2022

Inspection Number: 1516115

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguisher with no braking device located by unit 5.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2319923

TRUMP DORAL (PRITIKIN)

License Type: Hotel

4400 NW 87 AVE, DORAL 33178

Inspection Date: 04/11/2022

Inspection Number: 1159759

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HARVIE, HARUKO

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2303736

TRUMP DORAL/TRUMP DORAL GOLF CLUB AND RESORT MIAMI

License Type: Hotel

4400 NW 87 AVE, MIAMI 33178

Inspection Date: 04/11/2022

Inspection Number: 1161446

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HARVIE, HARUKO

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2327833

MIAMI AIRPORT WEST/DORAL TOWNEPLACE SUITES

License Type: Hotel

10505 NW 36 ST, MIAMI 33178

Inspection Date: 04/14/2022

Inspection Number: 1164427

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CURRAS, YANLEE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2320149

COUNTRY INN &amp; SUITES

License Type: Motel

11750 MILLS DR, MIAMI 33183

Inspection Date: 04/13/2022

Inspection Number: 1220531

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2022-04-13: No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613260

ALOFT JACKSONVILLE AIRPORT

License Type: Hotel

751 SKYMARKS DR, JACKSONVILLE 32218

Inspection Date: 04/12/2022

Inspection Number: 1163940

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.  
Boiler certifications in managers office.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Escambia County**

License Number: 2702778

HOTEL DEL SOL

License Type: Motel

6900 PENSACOLA BLVD, PENSACOLA 32505

Inspection Date: 04/13/2022

Inspection Number: 1222630

Inspection Type: Complaint Partial

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: JIMENEZ, MARCO

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.  
Door locking system with wires in disrepair and phone jack on wall in  
disrepair in room 542.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

**Hillsborough County**

---

License Number: 3913720

8014 TOMMY COURT APARTMENTS

License Type: Apartment

8014 TOMMY CT, TAMPA 33619

**Hillsborough County**

Inspection Date: 04/11/2022

Inspection Number: 1534844

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building 8001	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	- From initial inspection : Observed: Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building 8001 Priority: Reporting - From follow-up inspection 2022-04-11: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

07-01-4	Damaged electrical wire(s). For reporting purposes only. Electric panel meter by building 1029, handing off the walls	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	- From initial inspection : Observed: Damaged electrical wire(s). For reporting purposes only. Electric panel meter by building 1029, handing off the walls. Priority: Reporting - From follow-up inspection 2022-04-11: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3910558

TAMPA PALMS GOLF &amp; CC

License Type: Motel

5811 TAMPA PALMS BLVD, TAMPA 336471090

Inspection Date: 04/13/2022

Inspection Number: 1221120

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: POWELL, DAVID

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.expired 1/3/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4601279

ECONO LODGE

License Type: Motel

13301 N CLEVELAND AVE, NORTH FORT MYERS 33903

Inspection Date: 04/13/2022

Inspection Number: 1221804

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Observed LP gas tanks under stairwell by room 133. Operator says tanks are empty and customer will be back to retrieve them.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4604781

DIAMONDHEAD BEACH RESORT LLC

License Type: Hotel

2000 ESTERO BLVD, FT MYERS BCH 33931

Inspection Date: 04/11/2022

Inspection Number: 1163456

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: WALTER, KAYLA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate expired 04-10-2021.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5102009

VENTURE RENTALS LTD

License Type: Apartment

3800 LAKE BAYSHORE DR, BRADENTON 342059001

Inspection Date: 04/15/2022

Inspection Number: 1518862

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: BECHTOLD, NEIL

Violation CodeObservationViolation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.  
Operator stated that the fire department is aware of the issue. Parts are on  
back order for repair.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5102652

VENTURE RENTALS

License Type: Apartment

3600 LAKE BAYSHORE DR #16, BRADENTON 342059026

Inspection Date: 04/15/2022

Inspection Number: 1530027

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: BECHTOLD, NEIL

Violation CodeObservationViolation Citation

04-04-4

Fire alarm control panel has no power for zone 1. For reporting purposes only. Operator stated that the fire department is aware of the issue. Parts are on back order for repair. This issue only applies to the south side building of 16R zone 1 that includes 101-105, 201-205, 301-305, 401-405, and 501-505.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5103072

HOLIDAY INN EXPRESS &amp; SUITES BRADENTON WEST

License Type: Hotel

4450 47 ST W, BRADENTON 34210

Inspection Date: 04/11/2022

Inspection Number: 1164044

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HELGESON, ERIC

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

As a repeat violation the importance of following proper protocol with this violation was reinforced with the employee. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5105058

ISLAND TIME INN

License Type: Motel

105 BRIDGE ST, BRADENTON BEACH 34217

Inspection Date: 04/12/2022

Inspection Number: 1221752

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: RICHENDOLLAR, SANDRA

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. Observed fire extinguisher missing from second floor. Maintenance person brought one onsite and placed in the cabinet.  
\*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Nassau County**

License Number: 5500098

SHIP INN

License Type: Motel

542953 US HWY 1, CALLAHAN 32011

Inspection Date: 04/11/2022

Inspection Number: 1221619

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ROZIER, TORRANCE

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored near front door . For reporting purposes only.  
Room 31

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okeechobee County**

License Number: 5700634

UTAH TOWNHOMES

License Type: Apartment

215 NE 11 ST, OKEECHOBEE 34972

Inspection Date: 04/12/2022

Inspection Number: 1528666

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: JACKS, ALBERT

Violation CodeObservationViolation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only. Missing one in upstairs in unit 31.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

**Orange County**

---

License Number: 5803452

DAYS INN AT CIVIC CENTER

License Type: Motel

9990 INTERNATIONAL DR, ORLANDO 32819

**Orange County**

Inspection Date: 04/12/2022

Inspection Number: 1222562

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2022-04-11: \*\*Time Extended\*\* - From follow-up inspection 2022-04-12: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2022-04-11: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5803629

HYATT REGENCY GRAND CYPRESS

License Type: Hotel

1 GRAND CYPRESS BLVD, ORLANDO 32836

Inspection Date: 04/11/2022

Inspection Number: 1164380

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: BACHOO, SAVITRI

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2022-04-11: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811118

HILTON GARDEN INN

License Type: Hotel

11400 MARBELLA PALM CT, ORLANDO 32836

Inspection Date: 04/11/2022

Inspection Number: 1162550

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Strobe light doesn't flash in room 709

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5805932

INTOWN SUITES ORLANDO SOUTH LLC

License Type: Hotel

1951 CENTRAL FLORIDA PKWY, ORLANDO 32837

Inspection Date: 04/14/2022

Inspection Number: 1163853

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: ALVIS, DAVID

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\*** - From follow-up inspection 2022-04-14: Time extended until next unannounced inspection **\*\*Time Extended\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5912054

OMNI CHAMPIONSGATE RESORT HOTEL LP

License Type: Hotel

1500 MASTERS BLVD, CHAMPIONS GATE 33896

Inspection Date: 04/12/2022

Inspection Number: 1161729

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-04-12: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

---

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

**Osceola County**

Inspection Date: 04/12/2022

Inspection Number: 1164399

Inspection Type: Complaint Full

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Striker missing by room 349, 449, 500, 510, 543, 349	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

08-01-4      Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014433

OVERSEA FLAGLER BANYAN SQUARE

License Type: Apartment

290 N OLIVE AVE, WEST PALM BEACH 33401

Inspection Date: 04/12/2022

Inspection Number: 1520210

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: MONTILLA, NATHALIE

Violation Code

Observation

Violation Citation

01-01-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. On 3rd floor next to women restaurant. - From follow-up inspection 2022-04-12: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pasco County**

License Number: 6100353

LA VISTA INN

License Type: Motel

11736 US HIGHWAY 19 N, PORT RICHEY 34668

Inspection Date: 04/16/2022

Inspection Number: 1222612

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MEAKINS, ALLISON

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.  
 Light doesn't blink  
 Operator ordered new detector and has a fully functioning one. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6203085

THE BEACH HOUSE OF TREASURE ISLAND

License Type: Motel

12100 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 04/13/2022

Inspection Number: 1222625

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: DAY-WALKER, LISA

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. Bicycles stored in walkway on 2nd floor. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6202724

GULF TOWERS

License Type: Motel

404 GULF BLVD, INDIAN ROCKS BEACH 33785

Inspection Date: 04/15/2022

Inspection Number: 1220634

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.  
Room 454.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6800737

SIESTA KEY BEACHSIDE RESORT &amp; SPA

License Type: Motel

5311 OCEAN BLVD, SARASOTA 34242

Inspection Date: 04/15/2022

Inspection Number: 1222283

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CATTLEY, RAYMOND

Violation CodeObservationViolation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed uncovered electrical box between units 207 and 208, exterior.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6903746

LAKE'S EDGE APARTMENTS

License Type: Apartment

1000 PLANTATION LAKES CIR, SANFORD 32771

Inspection Date: 04/15/2022

Inspection Number: 1516412

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-04-15:

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Lucie County**

License Number: 6600789

ROYAL INN BEACH HOTEL

License Type: Motel

222 HERNANDO ST, FORT PIERCE 34949-3239

Inspection Date: 04/15/2022

Inspection Number: 1221475

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. There is no power light on smoke detector in room 306

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7401889

SOUTH DAYTONA TOWERS

License Type: Apartment

1910 S PALMETTO AVE, SOUTH DAYTONA 32119

Inspection Date: 04/15/2022

Inspection Number: 1526942

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COREY, DEREK

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.  
 -portable fire extinguisher broken off wall, laying on its side on ground outside unit #221.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.