

Bradford County

License Number: 1400018

BUDGET INN OF LAWTEY

License Type: Motel

23670 US HWY 301 N, LAWTEY 32058

Inspection Date: 04/21/2022

Inspection Number: 1218239

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BADDING, MELANIE

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Outside of room 118.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505666

RESIDENCE INN CAPE CANAVERAL

License Type: Hotel

8959 ASTRONAUT BLVD, CAPE CANAVERAL 32920

Inspection Date: 04/19/2022

Inspection Number: 1161808

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1500803

SURFCASTER MOTEL

License Type: Motel

5935 S HWY A1A, MELBOURNE BEACH 32951

Inspection Date: 04/20/2022

Inspection Number: 1221681

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MITTEN, JAMES

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
In laundry room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505768

BAXLEY MANOR LLC

License Type: Apartment

630 KUREK COURT, MERRITT ISLAND 32953

Inspection Date: 04/19/2022

Inspection Number: 1528575

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: FICHTER, GARRICK

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Multiple fire extinguishers in red zone throughout complex

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1603261

2231 ADAMS STREET LLC

License Type: Apartment

2231 ADAMS ST, HOLLYWOOD 33020

Inspection Date: 04/18/2022

Inspection Number: 1528324

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed to the left of the door to 2235.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621556

10X LIVING AT LAS OLAS WALK - SOUTH TOWER

License Type: Apartment

200 S FEDERAL HWY, FORT LAUDERDALE 33301

Inspection Date: 04/18/2022

Inspection Number: 1534987

Inspection Type: Lodging-Licensing

Inspection Disposition: Warning

Inspector Name: BRANN, JUSTIN

Inspection

Issued

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Inspection Report will be emailed to Fire Marshall for review.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621587

10X LIVING AT LAS OLAS WALK

License Type: Apartment

106 S FEDERAL HWY, FORT LAUDERDALE 33301

Inspection Date: 04/19/2022

Inspection Number: 1534995

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: BRANN, JUSTIN

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Inspection report will be emailed to Fire Marshall for review.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1604688

THE WESTIN BEACH RESORT FORT LAUDERDALE

License Type: Hotel

303 N FORT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 04/18/2022

Inspection Number: 1161991

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Inspection report will be emailed to Fire Marshall for review. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1609861

THE WESTIN BEACH RESORT FORT LAUDERDALE

License Type: Hotel

321 N FORT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 04/18/2022

Inspection Number: 1161987

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Inspection report will be emailed to Fire Marshall for review. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1602041

OSEAN VILLA LLC

License Type: Apartment

4641 & 4637 N OCEAN DR, FORT LAUDERDALE 33308

Inspection Date: 04/21/2022

Inspection Number: 1521234

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher low and expired more than one year

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621261

BERKSHIRE LAUDERDALE BY THE SEA

License Type: Apartment

2400 NE 65 ST, FORT LAUDERDALE 33308

Inspection Date: 04/22/2022

Inspection Number: 1514549

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside of 313. Operator replaced **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1600393

LA MER MOTEL

License Type: Motel

4529 N. OCEAN DRIVE, LAUDERDALE BY THE SE 33308

Inspection Date: 04/21/2022

Inspection Number: 1221949

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Low and expired in 2021

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1601954

SEAFOAM APTS

License Type: Apartment

4408 EL MAR DR, LAUDERDALE-BY-THE-SE 33308-3606

Inspection Date: 04/19/2022

Inspection Number: 1522613

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DEJONG, STEVEN

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge.
By pool, next to unit #32.
For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1601413

OCEAN SKY HOTEL AND RESORT

License Type: Hotel

4060 GALT OCEAN DR, FORT LAUDERDALE 33308-6597

Inspection Date: 04/20/2022

Inspection Number: 1163425

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation Code

Observation

Violation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2000520

CLUB CONTINENTAL BED&BRKFST

License Type: Bed and Breakfast

2143 ASTOR ST, ORANGE PARK 320735624

Inspection Date: 04/21/2022

Inspection Number: 1094607

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BIAVA, GRANT

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Certification expired 1/14/2022

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102466

DOUBLETREE GUEST SUITES NAPLES

License Type: Hotel

12200 N TAMIAMI TRL, NAPLES 34110

Inspection Date: 04/18/2022

Inspection Number: 1162235

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BARKLEY, KENDELL

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed no boiler certificate for establishment.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309450 75 WEST APARTMENTS
 License Type: Apartment 75 WEST 28 ST, HIALEAH 33010

Inspection Date: 04/18/2022 Inspection Number: 1502782 Inspection Type: Routine - Lodging Inspection Disposition: Call Back -
 Inspector Name: PRIETO, EDGAR Admin. complaint recommended

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartments #8 and 9 and between apartments #2 and #3. - From follow-up inspection 2	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartments #2 and 3 and between apartments #8 and #9.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300430

BEL INN

License Type: Motel

1202 N KROME AVE, HOMESTEAD 33030

Inspection Date: 04/20/2022

Inspection Number: 1221575

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330627

THE FLATS AT TATUM PARK

License Type: Apartment

601 S FLAGLER AVE, HOMESTEAD 33030

Inspection Date: 04/20/2022

Inspection Number: 1529673

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330200

THE HEIGHTS AT CORAL TOWN PARK

License Type: Apartment

14401 SW 268 ST, 14381, 14391, 14421, 14441, 14471, MIAMI 33032

Inspection Date: 04/20/2022

Inspection Number: 1519711

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: GONZALEZ, RICARDO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light on by unit 108 building 14441.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330246

PRINCETON GROVES VILLAGE LLC

License Type: Apartment

25011 SW 130 AVE, PRINCETON 33032

Inspection Date: 04/21/2022

Inspection Number: 1517338

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GONZALEZ, RICARDO

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed breaking device missing at fire extinguisher on building 25151 between units 101 and 102.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed trouble light flashing on building 25101. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2314094 1484 NW 15 AVE
 License Type: Apartment 1484 NW 15 AVE, MIAMI 331252671

Inspection Date: 04/19/2022 Inspection Number: 1522875 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: UNZAGA, MILADYS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No breaking device for extinguisher located by unit 7.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328235

HOMEWOOD SUITES MIAMI AIRPORT BLUE LAGOON

License Type: Hotel

5500 BLUE LAGOON DR, MIAMI 33126

Inspection Date: 04/18/2022

Inspection Number: 1163471

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330292 REGENCY MANOR RESIDENCES

License Type: Apartment 4355 NW 11 ST, MIAMI 33126

Inspection Date: 04/19/2022 Inspection Number: 1522178 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ORDONEZ, CATALINA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher located by unit 1 K in building 4355. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329841

MADISON VIEW APARTMENTS

License Type: Apartment

539 NW 7 ST, MIAMI 33136

Inspection Date: 04/21/2022

Inspection Number: 1531151

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed the fire alarm panel in front apartment 103 with the trouble light.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2315636

NEW ARENA SQUARE NO & SO LTD

License Type: Apartment

275 NW 10 ST, MIAMI 331363403

Inspection Date: 04/22/2022

Inspection Number: 1515681

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. By the laundry room.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2306777

PRETORIA ESTATE AG LLC

License Type: Apartment

934 MERIDIAN AVE, MIAMI BEACH 33139

Inspection Date: 04/20/2022

Inspection Number: 1528463

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Located near unit 3. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329040

BENTLEY BEACH HOTEL

License Type: Hotel

101 OCEAN DRIVE, MIAMI BEACH 33139

Dade County

Inspection Date: 04/22/2022

Inspection Number: 1163424

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MASKASEM, SUPPACHAI

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boilers 121044, 121045, 121046, 121047 all expired on 09/10/16.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

08-03-4 No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328318

BEST WESTERN PLUS ATLANTIC BEACH RRSORT

License Type: Hotel

4101 COLLINS AVE, MIAMI BEACH 33140

Inspection Date: 04/21/2022

Inspection Number: 1159819

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: UNZAGA, MILADYS

Violation Code

Observation

Violation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Observed fire extinguisher locked , located next to room 115. - From follow-up inspection 2022-04-21

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301823

TULLAIRE APTS

License Type: Apartment

935 BAY DR, MIAMI BEACH 331415620

Inspection Date: 04/20/2022

Inspection Number: 1525089

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device for fire extinguisher boxes by unit 3 at the front and back sides.
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308085

LA FUENTE HOTEL

License Type: Motel

7470 SW 8 ST, MIAMI 331444546

Inspection Date: 04/21/2022

Inspection Number: 1221725

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher located by room 10.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308555

VILLA BIANCA

License Type: Apartment

13251 MEMORIAL HWY, NORTH MIAMI 33161

Inspection Date: 04/20/2022

Inspection Number: 1519671

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No breaking device for extinguisher located next to the laundry room, the one located next to unit 9 and the other one located next

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310182

YELLOW KING APARTMENTS

License Type: Apartment

12890 NE 6 AVE, NORTH MIAMI 33161

Inspection Date: 04/19/2022

Inspection Number: 1525576

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SUAREZ, LEOPOLDO

Violation Code

Observation

Violation Citation

04-04-4 Fire alarm control panel has no power. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303398

AVENTURA OAKS

License Type: Apartment

1572 NE 191 ST, NORTH MIAMI BEACH 33179

Inspection Date: 04/20/2022

Inspection Number: 1530900

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Located between Apts 146 and 147.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2325567

EMERALD PALMS APARTMENTS

License Type: Apartment

12325 SW 151 ST, MIAMI 33186

Inspection Date: 04/22/2022

Inspection Number: 1521319

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed common trouble light illuminated at building A. - From follow-up inspection 2022-03-15: **Time Extended** - From f

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2609172

HOSPITALITY INN

License Type: Motel

7071 103 ST, JACKSONVILLE 32210

Inspection Date: 04/19/2022

Inspection Number: 1222661

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
Outside porch light at room 226 hanging from wires, not attached to building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2612591

RESIDENCE INN JACKSONVILLE AIRPORT

License Type: Hotel

1310 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 04/18/2022

Inspection Number: 1161936

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
In room 113, hearing impaired smoke detector did not function when tested. ****Warning****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613159

HOLIDAY INN EXPRESS & SUITES

License Type: Hotel

1200 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 04/18/2022

Inspection Number: 1162487

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
 Manager could not show proper functioning hearing impaired smoke detector in room 124. **Warning**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613243

MICROTEL BY WYNDHAM @ JACKSONVILLE INTERNATIONAL AIRPORT

License Type: Hotel

13200 INTERNATIONAL AIRPORT BLVD, JACKSONVILLE 32218

Inspection Date: 04/18/2022

Inspection Number: 1162800

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
Employees did not know how to test hearing impaired smoke detectors.
Manager called company that provided testing information. Hearing impaired smoke detectors

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613252

HYATT PLACE JACKSONVILLE AIRPORT

License Type: Hotel

14565 DUVAL RD, JACKSONVILLE 32218

Inspection Date: 04/21/2022

Inspection Number: 1163275

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
In both rooms 207 and 215. ****Warning****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613268

COMFORT SUITES AIRPORT

License Type: Hotel

1180 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 04/18/2022

Inspection Number: 1162627

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
In room 105, manager could not properly show hearing impaired smoke detector functions. ****Warning****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2608861

BEST STAY AMERICA

License Type: Motel

8220 DIX ELLIS TRAIL, JACKSONVILLE 32256

Inspection Date: 04/21/2022

Inspection Number: 1219641

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
Complaint Time Extension

Inspector Name: JEFFERS, MARY-BETH

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher between rooms #246-248 in undercharged zone of gauge - From follow-up inspection 2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher between rooms #246-248 in undercharged zone of gauge

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hernando County

License Number: 3700071

QUALITY INN & SUITES

License Type: Motel

30307 CORTEZ BLVD, BROOKSVILLE 34602

Inspection Date: 04/19/2022

Inspection Number: 1220472

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: COLE, GABRIELLE

Violation Code

Observation

Violation Citation

04-03-4

- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Smoke detector in room 100 appears to be disconnected. - From follow-up inspection 2022-03-23: Room 100 occupied.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hernando County

License Number: 3700960

MICROTEL INN & SUITES

License Type: Hotel

6298 NATURE COAST BLVD, BROOKSVILLE 34602

Inspection Date: 04/19/2022

Inspection Number: 1161709

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: COLE, GABRIELLE

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By room 325, 301, 209. - From follow-up inspection 2022-04-19:
Time Extended

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913532

LA QUINTA INN & SUITES

License Type: Hotel

310 GRAND REGENCY BLVD, BRANDON 33510

Inspection Date: 04/20/2022

Inspection Number: 1164397

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: CRUZ, JABULANI

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4500355

SOLUTIONS SERENITY LLC

License Type: Apartment

712 OAK TERR DR, LEESBURG 34748

Inspection Date: 04/19/2022

Inspection Number: 1522249

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SULLIVAN, SENJUN

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
 Between unit 14 and 15.
 Between units 16 and 17.
 Between units 4 and 5.
 Between units 2 and 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605238

PARK CREST AT THE LAKES

License Type: Apartment

13621 PARK CREST BLVD, FORT MYERS 33912

Inspection Date: 04/22/2022

Inspection Number: 1528320

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: SOMMERS, KARA

Violation CodeObservationViolation Citation

02-08-4

- From initial inspection : Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell near Unit 1F, Building 1. For reporting purposes only. - From follow-up inspection 2022-04-22:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell near Unit 1F, Building 1. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105834

ANNA MARIA VACATIONS

License Type: Vacation Rental - Dwelling

3018 AVE C, HOLMES BEACH 34217

Inspection Date: 04/22/2022

Inspection Number: 1092761

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RICHENDOLLAR, SANDRA

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed electrical meter missing from exterior of unit 4519. It is beside the breaker box.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5101506

LANTERN INN & SUITES

License Type: Motel

7251 N TAMIAMI TRL, SARASOTA 34243

Inspection Date: 04/19/2022

Inspection Number: 1221371

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: EASLER, VERONICA

Violation CodeObservationViolation Citation

06-02-4

Door marked as an exit is blocked. For reporting purposes only.

Observed marked exit door blocked in housekeeping laundry room.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5401610

MARINA DEL MAR

License Type: Motel

527 CARIBBEAN DR, KEY LARGO 33037

Inspection Date: 04/18/2022

Inspection Number: 1222352

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation Code

Observation

Violation Citation

03-01-4

No fire sprinkler system installed in a transient lodging establishment three stories or more in height, or over 75 feet in height. For reporting purposes only.

509.215 and 509.032(2)(d) FS Reporting: 509.215 Any public lodging establishment, as defined in this chapter, which is of three stories or more, or over 75 feet in height shall be equipped with an automatic sprinkler system installed in compliance with the provisions prescribed in the National Fire Protection Association publication NFPA No. 13 "Standards for the Installation of Sprinkler Systems. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400103

THE SAINT HOTEL KEY WEST

License Type: Hotel

417 EATON ST, KEY WEST 33040

Inspection Date: 04/19/2022

Inspection Number: 1160207

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Lobby and inside the kitchen.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okeechobee County

License Number: 5700412

TANGLEWOOD APARTMENTS

License Type: Apartment

420 NW 9 ST, OKEECHOBEE 349722121

Inspection Date: 04/22/2022

Inspection Number: 1530074

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKS, ALBERT

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only, in laundry room and in unit 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5805056

RED ROOF PLUS

License Type: Hotel

8342 JAMAICAN CT, ORLANDO 32819

Inspection Date: 04/20/2022

Inspection Number: 1164435

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: KOSTELNY, ROGER

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811181

LA QUINTA INN & SUITES BY WYNDHAM ORLANDO I DRIVE THEME PARKS

License Type: Hotel

11545 INTERNATIONAL DR, ORLANDO 32821

Inspection Date: 04/20/2022

Inspection Number: 1162568

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LINDSAY, SHARON

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811191

TRU BY HILTON ORLANDO CONVENTION CENTER

License Type: Hotel

6461 WESTWOOD BOULEVARD, ORLANDO 32821

Inspection Date: 04/21/2022

Inspection Number: 1162084

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LINDSAY, SHARON

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only./ hot water heater has capability of 500,000 BTU per hour and requires a boiler certificate. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811212

SPOT X HOTEL ORLANDO

License Type: Hotel

12235 REGENCY VILLAGE DR, ORLANDO 32821

Orange County

Inspection Date: 04/19/2022

Inspection Number: 1163703

Inspection Type: Routine - Lodging

Inspection Disposition: Warning

Inspector Name: LINDSAY, SHARON

Issued

Violation CodeObservationViolation Citation

08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-06-4	Combustibles stored in boiler room. For reporting purposes only./ paint buckets	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5804083

SHERATON ORLANDO LAKE BUENA VISTA RESORT

License Type: Motel

12205 S APOPKA VINELAND RD, ORLANDO 32836

Inspection Date: 04/19/2022

Inspection Number: 1219957

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811159

HYATT PLACE ORLANDO/ LAKE BUENA VISTA

License Type: Hotel

8688 PALM PKWY, ORLANDO 32836

Inspection Date: 04/20/2022

Inspection Number: 1161642

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Room 601

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900674

HOLIDAY INN ORLANDO SW CELEBRATION AREA

License Type: Hotel

5711 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 04/14/2022

Inspection Number: 1164384

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BORRERO, AUDREY

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5913651

QUALITY INN

License Type: Motel

2934 POLYNESIAN ISLE BLVD, KISSIMMEE 34746

Inspection Date: 04/21/2022

Inspection Number: 1222681

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: BORRERO, AUDREY

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.
In room 105

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5912070

GRAND HOTEL KISSIMMEE

License Type: Hotel

3104 PARKWAY BLVD, KISSIMMEE 34747

Inspection Date: 04/21/2022

Inspection Number: 1163883

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014082

MELROSE CAMERFORD LLC

License Type: Apartment

255 EVERNIA ST, 5TH FLR MANAGEMENT OFFICE, WEST PALM BEACH 33401

Inspection Date: 04/19/2022

Inspection Number: 1519309

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: MONTILLA, NATHALIE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Expired:12-20-21

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014264

THE STRAND

License Type: Apartment

255 EVERNIA ST, WEST PALM BEACH 33401

Inspection Date: 04/19/2022

Inspection Number: 1519363

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: FRANCO, BROOKE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 12/20/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6004048

LAKE MANGONIA APARTMENTS

License Type: Apartment

2100 N AUSTRALIAN AVE, WEST PALM BEACH 33407

Inspection Date: 04/22/2022

Inspection Number: 1519698

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: FRANCO, BROOKE

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only. Observed garbage bags at exit door on first floor of North building. ****Warning****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6000203

WATERFORD BAY APARTMENTS

License Type: Apartment

200 NE 20 ST, BOCA RATON 33431

Inspection Date: 04/21/2022

Inspection Number: 1514946

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside of B145

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6102769

LANDINGS AT SEA FOREST

License Type: Apartment

4522 SEAGULL DR, NEW PORT RICHEY 34652

Inspection Date: 04/22/2022

Inspection Number: 1516895

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOLDMAN, BARRY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. 4 floor - company has been notified. **Corrective Action Taken**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6101249

WORTHINGTON COURT APARTMENTS

License Type: Apartment

7541 HIGHWATER DR, NEW PORT RICHEY 34655

Inspection Date: 04/20/2022

Inspection Number: 1524915

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRADY, OSSIAN

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a landing. For reporting purposes only.

Observed liquid propane tank at unit 3 of building M on patio that is under 2nd floor landing.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6102919

PIONEER BUILDING

License Type: Apartment

3104 TOWN AVE, NEW PORT RICHEY 34655

Inspection Date: 04/18/2022

Inspection Number: 1531509

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BRADY, OSSIAN

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

Observed fire extinguisher missing from enclosure by unit 202

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6100353

LA VISTA INN

License Type: Motel

11736 US HIGHWAY 19 N, PORT RICHEY 34668

Inspection Date: 04/16/2022

Inspection Number: 1222612

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MEAKINS, ALLISON

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
Light doesn't blink
Operator ordered new detector and has a fully functioning one. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

Inspection Date: 04/21/2022

Inspection Number: 1222655

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: MEAKINS, ALLISON

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
Light not functioning on either detector when plugged in.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

Pinellas County

License Number: 6201702

HILTON GARDEN INN

License Type: Motel

6100 GULF BLVD, ST PETE BEACH 33706-3714

Pinellas County

Inspection Date: 04/19/2022

Inspection Number: 1221998

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HEFFNER, CHRISTOPHER

Violation CodeObservationViolation Citation

01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguisher 3rd floor outside of room 311.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Inspector observed 4 intellihot 499,999 insta heat hot water boilers. Operator stated that boiler inspection was attempted but the operator had a few det	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6201655

ALTA MAR AT BRODWATER

License Type: Apartment

3901 38 AVE S, ST. PETERSBURG 33711

Inspection Date: 04/20/2022

Inspection Number: 1533760

Inspection Type: Complaint Full

Inspection Disposition: Call Back -

Inspector Name: HEFFNER, CHRISTOPHER

Admin. complaint recommended

Violation Code

Observation

Violation Citation

12-04-4

- From initial inspection : High Priority - Balcony/starway/platform have been condemned by AHJ.
Balconies have been boarded off.
Unable access balconies from inside or outside of unit.
All stairwells have been boarded off as well. ****Warning**** - Fro

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Pinellas County

License Number: 6205617

TROPICAL BREEZE APTS

License Type: Apartment

1693 2 AVE N, ST PETERSBURG 33713

Inspection Date: 04/22/2022

Inspection Number: 1527859

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HEFFNER, CHRISTOPHER

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
First floor north west corner of building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6212648

DAYS INN CENTRAL

License Type: Motel

650 34 ST N, ST. PETERSBURG 33713

Inspection Date: 04/22/2022

Inspection Number: 1221506

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HEFFNER, CHRISTOPHER

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Outside of room 111

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6204804

CEDAR MOTEL

License Type: Motel

3300 34 ST N, ST PETERSBURG 33713-2410

Inspection Date: 04/18/2022

Inspection Number: 1217364

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HEFFNER, CHRISTOPHER

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Fire extinguisher outside of office is overcharged.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215767

HILTON HOTEL ST PETERSBURG CARILLON PARK

License Type: Hotel

950 LAKE CARILLON DR, ST. PETERSBURG 33716

Inspection Date: 04/18/2022

Inspection Number: 1163500

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

FL 130735, 130736, 133820, 133819 exp 08/07/2021. Director of engineering provided report of recent inspection but new certificates have not been received ye

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6800740

CADILLAC MOTEL

License Type: Motel

4021 N TAMIAMI TRL, SARASOTA 34234

Inspection Date: 04/18/2022

Inspection Number: 1222047

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HELGESON, ERIC

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed between rooms 105 and 106.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6801281

HYATT REGENCY SARASOTA

License Type: Hotel

1000 BLVD OF THE ARTS, SARASOTA 34236

Inspection Date: 04/20/2022

Inspection Number: 1163107

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: MCKEON, MICHAEL

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation**** - From follow-up inspection 2022-04-20: ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904019

PURE LIVING APARTMENTS

License Type: Apartment

740 SAVORY PL, LAKE MARY 32746

Inspection Date: 04/20/2022

Inspection Number: 1524309

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. System is in trouble

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501634

SUMMER BREEZE

License Type: Apartment

200 SUMMER BREEZE WAY, SAINT AUGUSTINE 32086

Inspection Date: 04/21/2022

Inspection Number: 1535019

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: GROTZ, CINDY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Fire pulls do not function per maintenance personnel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602528

SUNRISE SANDS BEACH RESORT

License Type: Hotel

110 S OCEAN DR, FORT PIERCE 34949

Inspection Date: 04/20/2022

Inspection Number: 1162623

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire panel is silenced .

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406495

HOLIDAY INN DAYTONA BEACH LPGA

License Type: Hotel

137 AUTOMALL CIR, DAYTONA BEACH 32124

Inspection Date: 04/19/2022

Inspection Number: 1160326

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: COREY, DEREK

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
-repair crew on site

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406506

WOODSPRING SUITES DAYTONA

License Type: Hotel

2910 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32124

Inspection Date: 04/18/2022

Inspection Number: 1161441

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: COREY, DEREK

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-04-18: **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400329

VANGUARD MOTEL

License Type: Motel

650 S YOUNG ST, ORMOND BEACH 32174

Inspection Date: 04/21/2022

Inspection Number: 1221276

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only, room 19.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406502

HAMPTON INN & SUITES

License Type: Hotel

20 SUMMIT OAK PL, DELAND 32720

Inspection Date: 04/18/2022

Inspection Number: 1161837

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: OCASIO-LOPEZ, LISA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7600053

ADAMS MOTEL

License Type: Motel

545 US 90 W, DEFUNIAK SPRINGS 32433

Inspection Date: 04/18/2022

Inspection Number: 1221967

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

07-02-4

Frayed electrical wire(s). For reporting purposes only. Hanging outside on left side of office.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.