

**Alachua County**

License Number: 1103006

THE 400 APARTMENTS

License Type: Apartment

400 NW 1 AVE, GAINESVILLE 32601

Inspection Date: 04/28/2022

Inspection Number: 1526341

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: CASEY, KEITH

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  
Observed no boiler certificate.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1305148

TWEEN BAYS MOTEL

License Type: Motel

4508 W HWY 98, PANAMA CITY 32401

Inspection Date: 05/02/2022

Inspection Number: 1222708

Inspection Type: Complaint Partial

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1500775

DIXIE MOTEL APARTMENTS LLC

License Type: Motel

301 FORREST AVE, COCOA 32922

Inspection Date: 04/27/2022

Inspection Number: 1221576

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SCHUCK, GREGORY

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Extinguisher located between 121&122

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1605822

HOLLYOAK APARTMENTS LLC

License Type: Apartment

240 SW 8 ST, POMPANO BEACH 33060

Inspection Date: 04/27/2022

Inspection Number: 1534966

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANCE, GASTON

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. At first floor fire extinguisher.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1620830

BUENA VISTA HOTEL

License Type: Hotel

4225 EL MAR DR, LAUDERDALE-BY-THE-SE 33308

Inspection Date: 04/26/2022

Inspection Number: 1164021

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Trouble signal

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1603191

6500 BLDG

License Type: Apartment

6500 NE 18 AVE, FORT LAUDERDALE 33334-5152

Inspection Date: 04/26/2022

Inspection Number: 1521128

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only  
Observed outside of Apt 1

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2306568

COTTOM APARTMENTS

License Type: Apartment

41 E 8 ST, HIALEAH 330104465

Inspection Date: 04/26/2022

Inspection Number: 1518062

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: VILCHEZ, NABEL

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between apartments 16 and 17, 6 and 7, 2 and 3. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2311240

FLORIDA BUILDING CORP APTS

License Type: Apartment

235 E 8 ST, HIALEAH 330104499

Inspection Date: 04/27/2022

Inspection Number: 1525240

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: VILCHEZ, NABEL

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2301981

FORTUNE AT HIALEAH LLC

License Type: Apartment

980 W 29 ST, HIALEAH 33012

Inspection Date: 04/28/2022

Inspection Number: 1516189

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.  
Observed for unit located by apartment 2.  
**\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329274

FORTUNE AT HIALEAH LLC

License Type: Apartment

940 W 29 ST, HIALEAH 33012

Inspection Date: 04/28/2022

Inspection Number: 1520954

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.  
Observed for units located by apartments 24, 12.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329275 FORTUNE AT HIALEAH LLC  
 License Type: Apartment 990 W 29 ST, HIALEAH 33012

Inspection Date: 04/28/2022 Inspection Number: 1523278 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LODENQUAI, BARRINGTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed for unit located by apartment 18 **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330334

SOPHIA SQUARE APARTMENTS

License Type: Apartment

13710 SW 256TH STREET, HOMESTEAD 33032

Inspection Date: 04/27/2022

Inspection Number: 1527213

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: GONZALEZ, RICARDO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm  
control panel. For reporting purposes only.509.032(2)(d) FS Reporting: The division, or its agent,  
shall notify the local firesafety authority or the State  
Fire Marshal of any readily observable violation of a  
rule adopted under chapter 633 which relates to public  
lodging establishments or public food establishments,  
and the identification of such violation does not require  
any firesafety inspection certification. For reporting  
purposes only.

**Dade County**

License Number: 2311339

ECONOLOGDE INN &amp; SUITES

License Type: Motel

1223 NE 1 AVE, FLORIDA CITY 33034

Inspection Date: 04/25/2022

Inspection Number: 1221763

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Observed the smoke detector alarm hanging from the ceiling at room 103. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2327953

PALM VILLAS NORTH APARTMENTS

License Type: Apartment

726 W PALM DR, FLORIDA CITY 33034

Inspection Date: 04/29/2022

Inspection Number: 1527612

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located outside of unit 202. One located outside of unit 501 N. One located outside of unit 702.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329568

CORAL BAY LLC

License Type: Apartment

1405 NW 2 CT, FLORIDA CITY 33034

Inspection Date: 04/25/2022

Inspection Number: 1520956

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only  
Observed the portable fire extinguishers were missing, first and second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330801

VIAN INVESTMENTS LLC

License Type: Apartment

1334 NW 3 ST, MIAMI 33125

Inspection Date: 04/28/2022

Inspection Number: 1535096

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: SAENZ, HILDA

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device at fire extinguisher located between apartment # 3 and 4.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2312847

POIN APTS

License Type: Apartment

940 NW 22 AVE, MIAMI 331253347

Inspection Date: 04/26/2022

Inspection Number: 1522773

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguisher boxes located next to apartment # 2 and #6. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2313949

SALMA APTS

License Type: Apartment

51 NW 17 PL, MIAMI 331255428

Inspection Date: 05/02/2022

Inspection Number: 1522872

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguishers with no braking devices located on first and second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2307060

MACIAS APTS

License Type: Apartment

66 NW 17 CT, MIAMI 331255449

Inspection Date: 05/02/2022

Inspection Number: 1515620

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed both Extinguishers on premises with no braking devices. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2325966

PEREZ APARTMENT BUILDING

License Type: Apartment

1544 NW 1 ST, MIAMI 331255574

Inspection Date: 04/28/2022

Inspection Number: 1525268

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguisher with no braking device located between stairs on first floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2328235

HOMEWOOD SUITES MIAMI AIRPORT BLUE LAGOON

License Type: Hotel

5500 BLUE LAGOON DR, MIAMI 33126

Inspection Date: 04/25/2022

Inspection Number: 1163471

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

08-04-4

- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2022-04-25: Boiler certificate not posted in the boiler room. For reporting purposes only. \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2310296

301 DALE LLC

License Type: Apartment

1063 NW 3 ST, MIAMI 33128

Inspection Date: 05/02/2022

Inspection Number: 1519206

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. Observed in building 1053, between apartments #2 and #3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2308483

BRICKELL RIDGE APARTMENTS

License Type: Apartment

1090 SW 1 AVENUE, MIAMI 33130

Inspection Date: 04/26/2022

Inspection Number: 1530787

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed by the entrance of the patio by building 1020. Also observed trouble signal next to apartment 3 building 1090.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2311239

JOCEL CORPORATION

License Type: Apartment

729 SW 2 ST, MIAMI 33130

Inspection Date: 04/25/2022

Inspection Number: 1530291

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.  
Observed fire extinguisher by unit 2. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329481

WEST BRICKELL TOWER APARTMENTS

License Type: Apartment

1026 SW 2 AVE, MIAMI 33130

Inspection Date: 04/25/2022

Inspection Number: 1521845

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329386

ALOFT CORAL GABLES

License Type: Hotel

2524 LE JEUNE RD, CORAL GABLES 33134

Inspection Date: 04/29/2022

Inspection Number: 1162295

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: GONZALEZ, ALEJANDRO

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2022-04-29: At the time of the callback inspection the boilers certificates were incomplete and not in compliance. \*\*Admin Complaint\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2302749

VANAK INVESTMENTS LLC

License Type: Apartment

1760 NW 1 PL, MIAMI 33136

Inspection Date: 04/29/2022

Inspection Number: 1518694

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 3 and 8.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2305080

R & L APTS

License Type: Apartment

220 NW 15 ST, MIAMI 331361846

Inspection Date: 04/28/2022

Inspection Number: 1525272

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By apartments 1 and 4.  
**\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2301027

MORGAN APTS

License Type: Apartment

1155 NW 2 AVE, MIAMI 331362751

Inspection Date: 04/28/2022

Inspection Number: 1513298

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By unit 4 and 12

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329381

HYDE SUITES MIDTOWN

License Type: Hotel

3401 NE 1 AVE, MIAMI 33137

Inspection Date: 04/25/2022

Inspection Number: 1162739

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: SEYBA, JAMES

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-04-25: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Time Extended\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2314946

SHALIMAR MOTEL

License Type: Motel

6200 BISCAYNE BLVD, MIAMI 33138

Inspection Date: 04/27/2022

Inspection Number: 1220632

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only Observed in front of rooms #219 and #218 in second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2305485

NATIONAL HOTEL (THE)

License Type: Hotel

1677 COLLINS AVENUE, MIAMI BEACH 33139

Inspection Date: 04/27/2022

Inspection Number: 1163868

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-04-27: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2329100

THE SETAI HOTEL

License Type: Hotel

2001 COLLINS AVE, MIAMI BEACH 33139

**Dade County**

Inspection Date: 04/26/2022

Inspection Number: 1162662

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

04-01-4	<p>- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. <b>**Repeat Violation**</b> - From follow-up inspection 2022-04-26: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. <b>**Time Extended**</b></p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
08-01-4	<p>- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 4 boiler certificates FL096428; FL096429; FL096429; FL096430; FL131411 all expired on 03-01-2019. - From follow-up inspection 2022-04-26: Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 4 boiler certificates FL096428; FL096429; FL096429; FL096430; FL131411 all expired on 03-01-2019. <b>**Time Extended**</b></p>	<p>61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

**Dade County**

License Number: 2329497

THE RITZ CARLTON, SOUTH BEACH

License Type: Hotel

1 LINCOLN RD, MIAMI BEACH 33139

Inspection Date: 04/29/2022

Inspection Number: 1164396

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: HODGE, KRISTEN

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. Observed jurisdiction number's 134444 , 134417 for boilers with an expiration date of 12-26-21. Observed invoice regarding boiler inspection conducted on 4/22/22 requesting certificate continuance, in the process of renewing certification. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2303686

THE POINT 2 LLC

License Type: Apartment

800 85TH ST, MIAMI BEACH 33141

Inspection Date: 04/29/2022

Inspection Number: 1535101

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: PRIETO, VICENTE

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device at fire extinguisher box by unit 808.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2308979

OSCARS APTS

License Type: Apartment

800 83 ST, MIAMI BEACH 331411354

Inspection Date: 04/28/2022

Inspection Number: 1522748

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 4.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329339 AMBER GARDEN APARTMENTS

License Type: Apartment 1320 NW 24 ST, MIAMI 33142

Inspection Date: 04/26/2022      Inspection Number: 1516816      Inspection Type: Routine - Lodging      Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: BROWN, JARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-04-26: At time of callback inspection Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





**Dade County**

License Number: 2312612

CARIB VILLAS APARTMENTS

License Type: Apartment

11101 SW 200 ST, MIAMI 33157

Inspection Date: 04/27/2022

Inspection Number: 1535046

Inspection Type: Complaint Full

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apartment 6209, 6114.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed next to apartment 7104.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2310937

C S APTS

License Type: Apartment

17150 NE 23 AVE, NORTH MIAMI BEACH 331602938

Inspection Date: 04/26/2022

Inspection Number: 1522764

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2310858

CENTURY TOWERS APTS

License Type: Apartment

100 KINGS PT DR, MIAMI BEACH 331604774

**Dade County**

Inspection Date: 04/28/2022

Inspection Number: 1515656

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. As of 2/27/22.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329471

MIAMI GARDENS INN &amp; SUITES

License Type: Hotel

16805 NW 12 AVE, MIAMI GARDENS 33169

Inspection Date: 04/25/2022

Inspection Number: 1164468

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: STUBBS, CHRISTINE

Violation CodeObservationViolation Citation

06-06-4

Door marked as an exit locked with a lock that requires a key. For reporting purposes only.  
Observed door marked exit at the black of the establishment has a key machine that is broken.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329852

MILA APARTMENTS

License Type: Apartment

20901 SAN SIMEON WAY, NORTH MIAMI BEACH 33179

Inspection Date: 04/26/2022

Inspection Number: 1519306

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located at buildings 20963, 21003 and 21423.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329662

WATERFORD AT AVENTURA

License Type: Apartment

19580 W DIXIE HWY, NORTH MIAMI BEACH 33180

Inspection Date: 04/26/2022

Inspection Number: 1521388

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 7.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**



**Duval County**

---

License Number: 2608324

RED ROOF INN

License Type: Motel

1063 AIRPORT RD, JACKSONVILLE 32218

**Duval County**

Inspection Date: 04/29/2022

Inspection Number: 1221307

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only Fire extinguisher by lobby near staircase. Person in charge states this extinguisher was used in a recent car fire. New extinguisher is present, but awaiting glass for case. \*\*Corrective Action Taken\*\* \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certification expired 09/20/2021. \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613237

SPRINGHILL SUITES

License Type: Hotel

13550 AIRPORT CT, JACKSONVILLE 32218

Inspection Date: 04/29/2022

Inspection Number: 1163876

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.  
No one knew how to test hearing impaired smoke detectors. **\*\*Warning\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Escambia County**

**Escambia County**

---

License Number: 2705801

REGENCY INN

License Type: Motel

7051 PENSACOLA BLVD, PENSACOLA 32505

**Escambia County**

Inspection Date: 04/26/2022

Inspection Number: 1221524

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher between room 235-237.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Gadsden County**

License Number: 3000003

HAMPTON INN BY HILTON

License Type: Hotel

165 SPOONER RD, QUINCY 32351

Inspection Date: 04/26/2022

Inspection Number: 1162513

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: DAVILA, NELSON

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  
Observed no boiler certificate for the establishment.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3913675

JW MARRIOTT TAMPA WATER STREET

License Type: Hotel

510 WATER ST, TAMPA 33602

Inspection Date: 04/25/2022

Inspection Number: 1161199

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room.  
For reporting purposes only.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



## Hillsborough County

License Number: 3902679

BUDGET INN EAST

License Type: Motel

4011 E COLUMBUS DR, TAMPA 33605

Inspection Date: 04/27/2022

Inspection Number: 1222707

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: MOULDER, BRITTANY

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit.  
For reporting purposes only.  
Observed employee replace smoke detector  
\*\*Corrected On-Site\*\*

509.215(1) and (2) and 509.032(2)(d) FS Reporting:  
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3900056

GARDEN VIEW MOTEL

License Type: Motel

2500 E BUSCH BLVD, TAMPA 336128412

Inspection Date: 05/02/2022

Inspection Number: 1217511

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CESAR, RACHEL

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Hammer missing from Fire extinguisher box outside room 132.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

---

License Number: 3911434

FAIRFIELD INN & SUITES BY MARRIOTT

License Type: Hotel

10150 PALM RIVER RD, TAMPA 33619

**Hillsborough County**

Inspection Date: 04/28/2022

Inspection Number: 1161050

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: MOULDER, BRITTANY

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

Boiler 122068 - From follow-up inspection  
2022-04-28: Observed no boiler certification  
\*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. - From follow-up inspection 2022-04-28: Observed no boiler certificate \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

---

License Number: 3913720

8014 TOMMY COURT APARTMENTS

License Type: Apartment

8014 TOMMY CT, TAMPA 33619

**Hillsborough County**

Inspection Date: 04/28/2022

Inspection Number: 1534844

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: MOULDER, BRITTANY

Violation CodeObservationViolation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building 8001 - From follow-up inspection 2022-04-28: Building 8001  
\*\*Admin Complaint\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

- From initial inspection : Observed: Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Building 8001  
Priority: Reporting - From follow-up inspection 2022-04-11: \*\*Time Extended\*\* - From follow-up inspection 2022-04-28: Observed: Portable fire extinguisher missing from it's designated location (sign present indicating designated location) ,Building 8001  
\*\*Admin Complaint\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

- 07-01-4 - From initial inspection : Observed: Damaged electrical wire(s). For reporting purposes only. Electric panel meter by building 1029, handing of the walls.  
Priority: Reporting - From follow-up inspection 2022-04-11: \*\*Time Extended\*\* - From follow-up inspection 2022-04-28: building 1029, handing off the walls. \*\*Admin Complaint\*\*
- 07-01-4 - From initial inspection : Damaged electrical wire(s). For reporting purposes only. Electric panel meter by building 1029, handing off the walls - From follow-up inspection 2022-04-28: Electric panel meter by building 1029, handing of the walls \*\*Admin Complaint\*\*
- 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
- 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4600002

GASPARILLA INN &amp; #46 #47 &amp; #59

License Type: Hotel

PALM AVE, BOCA GRANDE 339219999

Inspection Date: 04/30/2022

Inspection Number: 1164199

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
Jurisdiction Number: 133673. Expiration Date: 05/16/2020.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Manatee County**

License Number: 5102928

M\*STAR BRADENTON

License Type: Motel

6511 14 ST W, BRADENTON 34207

Inspection Date: 04/26/2022

Inspection Number: 1217261

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: CATTLEY, RAYMOND

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-04-26: Observed system silence  
\*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5400201

PIER HOUSE

License Type: Motel

1 DUVAL ST, KEY WEST 33040

Inspection Date: 04/26/2022

Inspection Number: 1219835

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room.  
For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603600

EMERALD GRANDE

License Type: Hotel

10 HARBOR BLVD, DESTIN 32541

Inspection Date: 04/26/2022

Inspection Number: 1161082

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  
Three boilers  
One newly installed

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5600066

GREENS ON 5TH

License Type: Apartment

5 MOONEY RD NE, FORT WALTON BEACH 32547

Inspection Date: 04/27/2022

Inspection Number: 1534912

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: BURROUGHS, RICHARD

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet/Electrical box damaged to indicate a malfunction. For reporting purposes only.  
 - electrical panel on the side of Building C is missing the cover (it's on the ground) exposing the circuit breakers and wires.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5806331

EMBASSY SUITES RESORT LAKE BUENA VISTA

License Type: Hotel

8100 LAKE AVE, ORLANDO 32836

Inspection Date: 04/29/2022

Inspection Number: 1161769

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LUI, SUK HAN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only./all three boiler certificates expired 4/1/2022.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5900710

KISSIMMEE MAINGATE

License Type: Motel

4694 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 04/25/2022

Inspection Number: 1220656

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GUTTERMAN, KENNETH

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014044

HAWTHORN SUITES WEST PALM BEACH

License Type: Hotel

301 LAMBERTON DR, WEST PALM BEACH 33401

Inspection Date: 04/29/2022

Inspection Number: 1163181

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: FRANCO, BROOKE

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2022-04-29: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

---

License Number: 6011425

COVE AT BOYNTON BEACH

License Type: Apartment

100 NEWLAKE DR, BOYNTON BEACH 33426



**Palm Beach County**

Inspection Date: 04/26/2022

Inspection Number: 1524214

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CUDEMOS, HAIDA

Violation CodeObservationViolation Citation

01-01-4	<p>Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.</p> <p>#1: Observed between apartment 813 &amp; 814.</p> <p>#2: Observed near apartment 1021.</p> <p>#3: observed near apartment 402.</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
01-02-4	<p>Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.</p> <p>Observed near apartment 617.</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

**Palm Beach County**

01-03-4            Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only  
Observed near apartment 221.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6012920

948 SW MLK BLDG

License Type: Apartment

948 SW AVE E, BELLE GLADE 33430

Inspection Date: 04/26/2022

Inspection Number: 1523688

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SEVILLA, FREDDY

Violation Code    Observation

Violation Citation

01-03-4            Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only  
Throughout the property

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6013961

SAVONA GRAND APARTMENTS

License Type: Apartment

7132 COLONY CLUB DR, LAKE WORTH 33463

Inspection Date: 05/02/2022

Inspection Number: 1515212

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: AHLE, ROBERT

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only Observe in building 5 Near apt 105,101 \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014128

DOVELAND

License Type: Apartment

8733 DOVELAND DR, PAHOKEE 33476

Inspection Date: 04/29/2022

Inspection Number: 1526308

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SEVILLA, FREDDY

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only building 8645 missing fire extinguisher by apartment E

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6214076

EXTENDED STAY HOTELS

License Type: Motel

2311 ULMERTON RD, CLEARWATER 33762

Inspection Date: 04/29/2022

Inspection Number: 1221529

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HOBBS, ANDREW

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6215784

HYATT REGENCY CLEARWATER BEACH RESORT & SPA

License Type: Hotel

301 GULF VIEW BLVD, CLEARWATER 33767

Inspection Date: 04/29/2022

Inspection Number: 1162514

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. F1123659 exp 7/25/2021, F1123660 exp 7/25/2021 \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6309178

STREAMSONG RESORT

License Type: Hotel

1000 STREAMSONG DR, STREAMSONG 33834

Inspection Date: 04/26/2022

Inspection Number: 1163869

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GARCIA, GUADALUPE

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler  
report expired. For reporting purposes only.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report  
is required annually for power boilers and high  
pressure/high temperature boilers and biannually for  
low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the  
local firesafety authority or the State Fire Marshal of  
any readily observable violation of a rule adopted under  
chapter 633 which relates to public lodging  
establishments or public food establishments, and the  
identification of such violation does not require any  
firesafety inspection certification. For reporting  
purposes only.

**Putnam County**

License Number: 6400085

BASSWORLD LODGE & MARINA

License Type: Apartment

209 N BROWN FISH CAMP RD, GEORGETOWN 32139

Inspection Date: 05/02/2022

Inspection Number: 1526892

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In unit 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**St. Johns County**

License Number: 6501024

SUPER 8 ST. AUGUSTINE

License Type: Motel

311 A1A BEACH BLVD, SAINT AUGUSTINE 32080

Inspection Date: 04/29/2022

Inspection Number: 1222036

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: GROTZ, CINDY

Violation CodeObservationViolation Citation

12-04-4

High Priority - Balcony/starway/platform collapsed.  
Deck/platform in front of North Building next to office is in disrepair. \*\*Warning\*\*

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

**St. Johns County**

License Number: 6500193

CONCH HOUSE MARINA RESORT

License Type: Motel

57 COMARES AVE, ST AUGUSTINE 32080

Inspection Date: 04/25/2022

Inspection Number: 1221910

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit.  
For reporting purposes only.  
In room 17.

509.215(1) and (2) and 509.032(2)(d) FS Reporting:  
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.