

Alachua County

License Number: 1102869

LAUREL OAK INN

License Type: Bed and Breakfast

221 SE 7 ST, GAINESVILLE 32601

Inspection Date: 05/02/2022

Inspection Number: 1094653

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: TORRES, WILLIAM

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only.
Observed LP tank greater than 2.7# stored under the handicap ramp and next to stairs behind establishment.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Alachua County

License Number: 1102968

LA QUINTA INN AND SUITES GAINESVILLE

License Type: Hotel

908 NW 69 TER, GAINESVILLE 32605

Inspection Date: 05/05/2022

Inspection Number: 1162178

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed a trouble light on the FACP.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1305148

TWEEN BAYS MOTEL

License Type: Motel

4508 W HWY 98, PANAMA CITY 32401

Inspection Date: 05/02/2022

Inspection Number: 1222708

Inspection Type: Complaint Partial

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bradford County

License Number: 1400032

BUDGET INN

License Type: Motel

739 N TEMPLE AVE, STARKE 32091

Inspection Date: 05/04/2022

Inspection Number: 1221995

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: TORRES, WILLIAM

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only
Observed missing fire extinguisher between unit 14 and 15

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1500557

LA QUINTA

License Type: Motel

1275 N ATLANTIC AVE, COCOA BCH 329313116

Inspection Date: 05/06/2022

Inspection Number: 1221402

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Contractor is working on system.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1502303

AMERICA'S BEST VALUE INN

License Type: Motel

180 HWY A1A, SATELLITE BCH 329372042

Inspection Date: 05/06/2022

Inspection Number: 1222608

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: VAUGHAN, COURTNEY

Violation Code

Observation

Violation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Missing fire extinguisher by room 125 - From follow-up inspection 2022-05-06: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620860

HOLLYWOOD ALL SUITE

License Type: Motel

334 ARIZONA ST, HOLLYWOOD 33019

Inspection Date: 05/06/2022

Inspection Number: 1220828

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: NEALY, VALENCIA

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
 -In between units D2-D3.
 -In between units A2-A3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1604142

PIERCE APARTMENT CONDOMINIUM ASSOCIATION

License Type: Apartment

2750 PIERCE ST, HOLLYWOOD 33020

Inspection Date: 05/05/2022

Inspection Number: 1523718

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed between unit 11 and 12.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620866

ZEN PLACE HOTEL

License Type: Motel

1856 SHERMAN ST, HOLLYWOOD 33020

Inspection Date: 05/04/2022

Inspection Number: 1219717

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed at the extinguisher between the storage rooms on the South side of the Front building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621611

RS 2206 ADAMS ST LLC

License Type: Apartment

2206 ADAMS ST, HOLLYWOOD 33020

Inspection Date: 05/05/2022

Inspection Number: 1532086

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed between unit 15 and 16 and between units 10 and 11.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620848

HILTON FT LAUDERDALE BEACH RESORT

License Type: Hotel

505 N FT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 05/06/2022

Inspection Number: 1163235

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Inspection report will be emailed to Fire Marshall for review.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324625

J X & SON'S LLC

License Type: Apartment

1127 NE 1 AVE, HOMESTEAD 33030

Inspection Date: 05/03/2022

Inspection Number: 1513793

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Repeat Violation

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326068

PHOENIX APTS

License Type: Apartment

1554 NE 8 ST, HOMESTEAD 33033

Inspection Date: 05/05/2022

Inspection Number: 1521838

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GONZALEZ, RICARDO

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed trouble light on buildings 1536, 1546.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2320673

BUDGET HOST INN

License Type: Motel

815 N KROME AVE, FLORIDA CITY 33034

Inspection Date: 05/02/2022

Inspection Number: 1221848

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Observed between rooms 122 and 123, rooms 116 and 117. - From follow-up inspection
2022-05-02: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2313949

SALMA APTS

License Type: Apartment

51 NW 17 PL, MIAMI 331255428

Inspection Date: 05/02/2022

Inspection Number: 1522872

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguishers with no braking devices located on first and second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2307060

MACIAS APTS

License Type: Apartment

66 NW 17 CT, MIAMI 331255449

Inspection Date: 05/02/2022

Inspection Number: 1515620

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed both Extinguishers on premises with no braking devices. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310296

301 DALE LLC

License Type: Apartment

1063 NW 3 ST, MIAMI 33128

Inspection Date: 05/02/2022

Inspection Number: 1519206

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. Observed in building 1053, between apartments #2 and #3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326353

VELASCO APARTMENTS

License Type: Apartment

1137 SW 4 ST # 3, MIAMI 33130

Inspection Date: 05/04/2022

Inspection Number: 1513669

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: SWIGERT, RICHARD

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next apartments 1 and 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2306201

CIMA APTS

License Type: Apartment

2121 SW 1 ST, MIAMI 331351688

Inspection Date: 05/02/2022

Inspection Number: 1535123

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher expired. Located at the back of the property. In building 2121.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302749

VANAK INVESTMENTS LLC

License Type: Apartment

1760 NW 1 PL, MIAMI 33136

Inspection Date: 04/29/2022

Inspection Number: 1518694

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 3 and 8.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329914

FORTIN PLAZA CORP

License Type: Apartment

425 NE 22 ST, MIAMI 33137

Inspection Date: 05/05/2022

Inspection Number: 1528728

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm
control panel. For reporting purposes only.509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State
Fire Marshal of any readily observable violation of a
rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Dade County

License Number: 2329399

DESIGN SUITES MIAMI BEACH

License Type: Hotel

5445 COLLINS AVE STE CU14, MIAMI BEACH 33140

Inspection Date: 05/05/2022

Inspection Number: 1161899

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. The boilers were already inspected on 2/16/2022, but not available certificate. Boiler certificates expired on 2/19/2022.

" - From follow-up inspection 2022-05-05:
Time Extended

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308979

OSCARS APTS

License Type: Apartment

800 83 ST, MIAMI BEACH 331411354

Inspection Date: 04/28/2022

Inspection Number: 1522748

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 4.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2304428

PARK SURF APARTMENTS

License Type: Apartment

341 73 ST, MIAMI BEACH 331412784

Inspection Date: 05/03/2022

Inspection Number: 1513292

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: PRIETO, VICENTE

Violation Code

Observation

Violation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking devices of fire extinguisher boxes between units 1 and 9 and between units 2 and 3. ****Repeat Violation**** - From follow-up inspection 2022-05-03: Observed missing breaking device for fire extinguisher boxes between units 2 - 3 and 8 9 ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2304250

ST GEORGE APARTMENTS

License Type: Apartment

5200 NW 26 AVE, MIAMI 33142

Inspection Date: 05/03/2022

Inspection Number: 1522535

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BROWN, JARON

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed fire extinguisher next to unit 9 and 24 at building 5250 with no breakage device. Observed fire extinguisher next to unit 21 and 27 at building 5200 with no breakage device.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330034

PEARL DADELAND

License Type: Apartment

7440 N KENDALL DR, MIAMI 33156

Inspection Date: 05/06/2022

Inspection Number: 1517076

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LODENQUAI, BARRINGTON

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330238

MIRABELLE

License Type: Apartment

7400 SW 88 ST, MIAMI 33156

Inspection Date: 05/06/2022

Inspection Number: 1531542

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310858

CENTURY TOWERS APTS

License Type: Apartment

100 KINGS PT DR, MIAMI BEACH 331604774

Dade County

Inspection Date: 04/28/2022

Inspection Number: 1515656

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. As of 2/27/22.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330463

UNIVERSITY BRIDGE, LLC

License Type: Apartment

740 SW 109 AVE, MAIMI 33174

Inspection Date: 05/05/2022

Inspection Number: 1531842

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PICO, JORGE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm
control panel. For reporting purposes only.509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State
Fire Marshal of any readily observable violation of a
rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Dade County

License Number: 2330434

MARCIA GARDENS, LLC

License Type: Apartment

10301 SW 127 AVE, MIAMI 33186

Inspection Date: 05/06/2022

Inspection Number: 1519998

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed for building 10301.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329447

TOWNEPLACE SUITES MIAMI KENDALL WEST

License Type: Hotel

9055 SW 162 AVE, MIAMI 33196

Inspection Date: 05/05/2022

Inspection Number: 1163604

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

Duval County

License Number: 2611854

OAK HAMMOCK APARTMENTS

License Type: Apartment

500 ACME ST, JACKSONVILLE 32211

Duval County

Inspection Date: 05/04/2022

Inspection Number: 1533425

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Call Back -
Complied

Inspector Name: THOMAS, PHILIP

Violation Code

Observation

Violation Citation

Duval County

12-04-4

- From initial inspection : High Priority - Balcony/starway/platform collapsed. Building 6 has collapsed landing between first and second floor. Entire landing has fallen 6 feet and is resting on ground. Stairs leading down from second floor end with 6 foot drop. Landing between 2 and 3 floor shows major stress. Area is marked off from bottom but inspector was able to walk up stairway on opposite side of building and cross over on second floor where roped off area had been removed. Operator stated movers are using the second floor to move current tenets. No movers were observed by inspector. Units on that side of building are 612 and 611 on third floor, 610 and 609 on second floor, 608 and 607 on first floor. Inspector recommends all units to be vacated. ****Warning**** - From follow-up inspection 2021-11-18: Tenets have been relocated on that side of building. All areas are clearly marked off with caution tape and fencing. Operator has started looking for repair options. ****Time Extended**** - From follow-up inspection 2022-01-25: Situation is the same. Repairs have not started. Operator states building is empty

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Duval County

with no occupants. ****Time Extended**** - From follow-up inspection 2022-03-01: Operator states the city has cleared the way for construction to be started. ****Time Extended**** - From follow-up inspection 2022-04-01: Operator has shown plan for rebuilding stairway on building 6. Building 6 has been vacated on the collapsed stairwell side with no tenets. The occupant level is being reduced by 6 to reflect that licensing does not include the collapsed side of building 6 and units are not to be rented until AFTER a follow inspection is completed on building 6 and the license has been adjusted to include the units. ****Time Extended**** - From follow-up inspection 2022-05-04: Units 612 and 611 on third floor, 610 and 609 on second floor, 608 and 607 on first floor are not part of issued license. Units number has been reduced according to reflect they are not included in licensing. Establishment will call inspector 904.704.1018 for inspection BEFORE units are rented and unit count will be adjusted after inspection has occurred. ****Time Extended****

Duval County

License Number: 2613264

ALOFT JACKSONVILLE TAPESTRY PARK HOTEL

License Type: Hotel

4812 DEER LAKE DR W, JACKSONVILLE 32246

Inspection Date: 05/05/2022

Inspection Number: 1163697

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JEFFERS, MARY-BETH

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
 No boiler certificate available for #136468-operat stated already in process of being certified. Maintenance supervisor has been working with fire Marshall. Provided paperwork that A new boiler has been ordered as of 2/22/22 through WW Gay-due in 10-12 weeks

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2612763

HAMPTON INN PONTE VEDRA

License Type: Hotel

1220 MARSH LANDING PKWY, JACKSONVILLE BEACH 32250

Inspection Date: 05/04/2022

Inspection Number: 1162699

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: GONZALEZ, MAYRA

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room.
For reporting purposes only.
****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only.
****Repeat Violation**** - From follow-up inspection 2022-05-04: Boiler certificate still not posted ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900056

GARDEN VIEW MOTEL

License Type: Motel

2500 E BUSCH BLVD, TAMPA 336128412

Inspection Date: 05/02/2022

Inspection Number: 1217511

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CESAR, RACHEL

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Hammer missing from Fire extinguisher box outside room 132.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3901464

QUALITY INN

License Type: Motel

1020 S DALE MABRY, TAMPA 336295005

Inspection Date: 05/05/2022

Inspection Number: 1221154

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: SINGER, ROBERT

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher outside room 123 has no striker.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605198

DAYS INN & SUITES

License Type: Hotel

10150 DANIELS PKWY, FORT MYERS 33913

Inspection Date: 05/06/2022

Inspection Number: 1164364

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: CANDO, JOHANA

Violation Code

Observation

Violation Citation

07-02-4

- From initial inspection : Frayed electrical wire(s). For reporting purposes only. Observed exposed wires by pipe line in the first floor staircase garbage exit door. - From follow-up inspection 2022-05-06: Observed exposed wires by pipe line in the first floor staircase garbage exit door. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4600002

GASPARILLA INN & #46 #47 & #59

License Type: Hotel

PALM AVE, BOCA GRANDE 339219999

Inspection Date: 04/30/2022

Inspection Number: 1164199

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Jurisdiction Number: 133673. Expiration Date: 05/16/2020.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400023

AVALON

License Type: Bed and Breakfast

1317 DUVAL ST, KEY WEST 33040

Inspection Date: 05/03/2022

Inspection Number: 1094852

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: WHITEHURST, SCOTT

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
Wheelen hearing impaired smoke detector alarm sets off before pushing test button

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603626

RESIDENCE INN BY MARRIOTT FORT WALTON BEACH

License Type: Hotel

2 MIRACLE STRIP PKWY SE, FORT WALTON BEACH 32548

Inspection Date: 05/04/2022

Inspection Number: 1161948

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BURROUGHS, RICHARD

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
- establishment has had their boilers inspected but they have not received their certificates.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5804772

DAYS INN & SUITES

License Type: Motel

1853 MCCOY RD, BELLE ISLE 32809

Inspection Date: 05/06/2022

Inspection Number: 1217345

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PASIECKI, VICTORIA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside room 130

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5805056

RED ROOF PLUS

License Type: Hotel

8342 JAMAICAN CT, ORLANDO 32819

Inspection Date: 05/03/2022

Inspection Number: 1164489

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811149

HAMPTON INN AND SUITES ORLANDO SEAWORLD

License Type: Hotel

7003 SEA HARBOR DR, ORLANDO 32821

Inspection Date: 05/04/2022

Inspection Number: 1162762

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LINDSAY, SHARON

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only./ room 220 , the alarm sounds but the light doesn't flash to indicate the alarm is sounding.
Warning

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801553

DAYS INN ORLANDO

License Type: Motel

2500 W 33 ST, ORLANDO 32839

Orange County

Inspection Date: 05/04/2022

Inspection Number: 1222732

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: PASIECKI, VICTORIA

Violation CodeObservationViolation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 4th floor near elevator, located in fire hose box	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 053116- 2/4/22	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5906532

SECRETS HIDEAWAY

License Type: Motel

2145 EAST IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34744

Inspection Date: 05/04/2022

Inspection Number: 1221000

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 05/03/2022

Inspection Number: 1164204

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: BORRERO, AUDREY

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
Per GM they are still waiting to receive the certificates. - From follow-up inspection
2022-05-03: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900724

ONE WAY MAINGATE HOTEL

License Type: Motel

2930 POLYNESIAN ISLE BLVD, KISSIMMEE 34746

Inspection Date: 05/04/2022

Inspection Number: 1219725

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911043

BEST WESTERN PLUS INN & SUITES

License Type: Hotel

3484 POLYNESIAN ISLE BLVD, KISSIMMEE 34746

Inspection Date: 05/04/2022

Inspection Number: 1162626

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5912068

MM LAKE HOTEL LLC

License Type: Hotel

4944 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 05/06/2022

Inspection Number: 1163168

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
Boiler FL 138722.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900708

PARADISE INN

License Type: Motel

4501 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746-5416

Inspection Date: 05/06/2022

Inspection Number: 1217899

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: OCASIO-LOPEZ, LISA

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900643

QUALITY INN & SUITES BY THE LAKE KISSIMMEE

License Type: Motel

7785 W US 192, KISSIMMEE 34747

Inspection Date: 05/04/2022

Inspection Number: 1222152

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 1-17-2021 **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5901202

QUALITY INN & SUITES BYTHE PARKS

License Type: Motel

2945 ENTRY POINT BLVD, KISSIMMEE 34747

Inspection Date: 05/05/2022

Inspection Number: 1221684

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm
control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5912071

MARGARITAVILLE RESORT ORLANDO

License Type: Hotel

8000 FINS UP CIR, KISSIMMEE 34747

Inspection Date: 05/05/2022

Inspection Number: 1162838

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014365

VILLAGE AT MANGONIA LAKE LLC

License Type: Apartment

2201 N AUSTRALIAN AVE, WEST PALM BEACH 33407

Inspection Date: 05/05/2022

Inspection Number: 1529283

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: FRANCO, BROOKE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 2181 6th floor at elevators.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014087

SOUTH GROUP OF BELLE GLADE LLC

License Type: Apartment

514 SW 7 ST, BELLE GLADE 33430

Inspection Date: 05/06/2022

Inspection Number: 1519305

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only 1st floor/hallway.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6002954

PARKVIEW APARTMENTS

License Type: Apartment

324 NE 1 ST, BELLE GLADE 33430-3152

Inspection Date: 05/06/2022

Inspection Number: 1523502

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: SEVILLA, FREDDY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Second floor by apartment #11

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6013961

SAVONA GRAND APARTMENTS

License Type: Apartment

7132 COLONY CLUB DR, LAKE WORTH 33463

Inspection Date: 05/02/2022

Inspection Number: 1515212

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: AHLE, ROBERT

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only Observe in building 5 Near apt 105,101 **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6013438

APPLE TEN HOSPITALITY MANAGEMENT INC

License Type: Hotel

8201 CONGRESS AVE, BOCA RATON 33487

Inspection Date: 05/06/2022

Inspection Number: 1164510

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6204365

PAGE TERRACE

License Type: Motel

10500 GULF BLVD, TREASURE ISLAND 337064817

Inspection Date: 05/04/2022

Inspection Number: 1219919

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: DAY-WALKER, LISA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow trouble light illuminated on fire panel in the front desk area.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215234

MARRIOTT ST PETERSBURG CLEARWATER

License Type: Hotel

12600 ROOSEVELT BLVD N, ST. PETERSBURG 33716

Inspection Date: 05/03/2022

Inspection Number: 1164475

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: LOZANO, KELVIN

Violation Code

Observation

Violation Citation

04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2022-05-03:	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215777

RESIDENCE INN CLEARWATER DOWNTOWN

License Type: Hotel

940 COURT ST, CLEARWATER 33756

Inspection Date: 05/03/2022

Inspection Number: 1163529

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HEFFNER, CHRISTOPHER

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6214076

EXTENDED STAY HOTELS

License Type: Motel

2311 ULMERTON RD, CLEARWATER 33762

Inspection Date: 04/29/2022

Inspection Number: 1221529

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HOBBS, ANDREW

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6205854

BRITTANY BAY APARTMENTS

License Type: Apartment

1201 SEMINOLE BLVD, LARGO 33770

Inspection Date: 05/06/2022

Inspection Number: 1520127

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HOBBS, ANDREW

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Rear of unit 43

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Putnam County

License Number: 6400085

BASSWORLD LODGE & MARINA

License Type: Apartment

209 N BROWN FISH CAMP RD, GEORGETOWN 32139

Inspection Date: 05/02/2022

Inspection Number: 1526892

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In unit 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

Seminole County

License Number: 6903992

THE WESTIN LAKE MARY, ORLANDO NORTH

License Type: Hotel

2974 INTERNATIONAL PKWY, LAKE MARY 32746

Seminole County

Inspection Date: 05/04/2022

Inspection Number: 1162571

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Alarm is in trouble	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900006

SERENITY TOWERS ON THE ST JOHNS

License Type: Apartment

519 E 1 ST, SANFORD 32771

Seminole County

Inspection Date: 05/03/2022

Inspection Number: 1523483

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only.
Tank stored in maintenance shop. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Boiler certificates expired 01/09/2022.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501024

SEASIDE INN

License Type: Motel

311 A1A BEACH BLVD, SAINT AUGUSTINE 32080

Inspection Date: 05/03/2022

Inspection Number: 1222036

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: GROTZ, CINDY

Violation Code

Observation

Violation Citation

12-04-4

- From initial inspection : High Priority -
Balcony/starway/platform collapsed.
Deck/platform in front of North Building next to
office is in disrepair. ****Warning**** - From
follow-up inspection 2022-05-03: Owner has
posted caution tape and blocked off access to the
damaged decking. Plans are in progress to have
deck removed. ****Time Extended**** ****Corrective
Action Taken****

61C-1.004(5) FAC High Priority: All building structural
components, attachments and fixtures shall be kept in
good repair.

St. Johns County

License Number: 6501397

WORLD GOLF VILLAGE RENAISSANCE ST AUGUSTINE RESORT

License Type: Hotel

500 S LEGACY TRL, SAINT AUGUSTINE 32092

Inspection Date: 05/06/2022

Inspection Number: 1159416

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PERKINS, MARC

Violation Code

Observation

Violation Citation

08-06-4

Combustibles stored in boiler room. For reporting purposes only.
In the boiler room, one propane tank stored by th entrance door on the floor of the boiler room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501410

HAMPTON INN

License Type: Hotel

2525 CO RD 208, ST AUGUSTINE 32092

Inspection Date: 05/05/2022

Inspection Number: 1160541

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PERKINS, MARC

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
Hearing impaired smoke alarm for room 420 not properly functioning, exterior room push button fc lights correctly works but the test of the alarm system does not light up to make an alarm sound.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401031

PERALTA APARTMENT INC

License Type: Apartment

859 DR MARY MCLEOD BETHUNE BLVD, DAYTONA BEACH 32114

Inspection Date: 05/04/2022

Inspection Number: 1524540

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

06-05-4

Door marked as an exit locked with a lock that would require special knowledge/tool to unlock. For reporting purposes only.
At rear of building there is a security type door with a key lock on both sides. Door is locked. The front of building has similar door which is open . The exterior hallway is between two buildings .

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401977

BEST WESTERN INTERNATIONAL SPEEDWAY

License Type: Hotel

2620 INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 05/06/2022

Inspection Number: 1163976

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only -by room 258

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406627

BELLAMY DAYTONA

License Type: Apartment

601 BELLAMY CRT, DAYTONA BEACH 32114

Inspection Date: 05/03/2022

Inspection Number: 1531695

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
 -club house ,building 2 ,3 silence light and trouble light manager states quarterly inspection being at time of inspection
 Observed Pye Parker on site,spoke with he says system is on test. He is testing sprinkler

 - panel in clubhouse now state all systems normal

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406694

ICON ONE DAYTONA

License Type: Apartment

235 Highbanks Blvd, Daytona Beach 32114

Inspection Date: 05/04/2022

Inspection Number: 1535074

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: BRANNER, LISELOTTE

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Small panel in lobby

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401479

EL CARIBE RESORT & CONFERENCE CENTER

License Type: Motel

2125 S ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 05/06/2022

Inspection Number: 1221494

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit in
disrepair/no power/battery.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7403661

BEACH HAVEN INN

License Type: Motel

2115 S ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 05/06/2022

Inspection Number: 1221923

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

06-01-4

Path to fire escape stairway is blocked/obstructed. For reporting purposes only.

-dolly set in front of stairway path used for fire escape, nearest unit;204

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401000

BEST WESTERN AKU TIKI INN

License Type: Motel

2225 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 05/05/2022

Inspection Number: 1221778

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GUTTERMAN, KENNETH

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405055

HOLIDAY SHORES BEACH CLUB

License Type: Motel

2617 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 05/04/2022

Inspection Number: 1221459

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

04-03-4

Fire alarm in common area damaged as to appear to be inoperable. For reporting purposes only.

-fire alarm next to unit 215 on wall in common area, duct tape currently used to support box on wall, zip tie used to secure wire covering. Wiring is partially exposed

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406508

BEACHSIDE HOTEL

License Type: Motel

3309 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 05/05/2022

Inspection Number: 1221556

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.

Exposed wire coming from ground showing scorch/burn marks, uncapped end. North end of building near north stairwell on side of lobby

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.