

Brevard County

License Number: 1505034

BARNA APARTMENTS

License Type: Apartment

4525 BARNA AVE, TITUSVILLE 32780

Inspection Date: 04/15/2022

Inspection Number: 1535287

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: FRANZ, LINDA

Violation CodeObservationViolation Citation

02-08-4

Observed: Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Unit
d
Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505674

RESIDENCE INN MELBOURNE

License Type: Hotel

1430 S BABCOCK ST, MELBOURNE 32901

Inspection Date: 05/09/2022

Inspection Number: 1162480

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. manager Julie states it is paid and okay, needs copy.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505758

ISLAND INVESTMENTS OF BREVARD, LLC

License Type: Apartment

623 FORREST AVE, COCOA 32922

Inspection Date: 05/10/2022

Inspection Number: 1524257

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: FRANZ, LINDA

Violation CodeObservationViolation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only. 2 electrical outlet on ground floor on west side, covers missing and exposed wiring. Units 1 and :

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1602936

WRP 14TH COURT INVESTMENTS LLC

License Type: Apartment

930 N 14 CT, HOLLYWOOD 33020

Inspection Date: 05/13/2022

Inspection Number: 1514900

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on the extinguisher across from Unit 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1611555

ELI 1777 LLC

License Type: Apartment

901 N 24 AVE, HOLLYWOOD 33020

Inspection Date: 05/12/2022

Inspection Number: 1523782

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed the glass break hammer missing on the extinguisher between units 1 and 2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1608574

ALFA INVESTMENTS LLC

License Type: Apartment

842 NW 1ST AVE, FT LAUDERDALE 33311

Inspection Date: 05/09/2022

Inspection Number: 1528936

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: FRANCE, GASTON

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
At front right side of building, ground floor.
****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621579

BELLA VISTA APARTMENTS

License Type: Apartment

3541 30TH PLACE, LAUDERDALE LAKES 33311

Inspection Date: 05/09/2022

Inspection Number: 1520235

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Building 6

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only. Observed in building 4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2306927

1730 50 BRIGHT DR APTS

License Type: Apartment

1730 BRIGHT DR, HIALEAH 330102664

Inspection Date: 05/13/2022

Inspection Number: 1518073

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: VILCHEZ, NABEL

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. In front of apartment #6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310671

LLERENA APTS

License Type: Apartment

26 W 11 ST, HIALEAH 330103945

Inspection Date: 05/12/2022

Inspection Number: 1518100

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: VILCHEZ, NABEL

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between apartments 4 and 5. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303198

EVERGLADES MOTEL

License Type: Motel

605 S KROME AVE, HOMESTEAD 33030

Inspection Date: 05/09/2022

Inspection Number: 1221748

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located between 8 and 9.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308299

PARK MOTEL

License Type: Motel

600 S KROME AVE, HOMESTEAD 33030

Inspection Date: 05/11/2022

Inspection Number: 1221583

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only located between unit 4 and 5. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2325370

BISCAYNE PALM CLUB

License Type: Apartment

15495 SW 288 ST, HOMESTEAD 33033

Inspection Date: 05/10/2022

Inspection Number: 1516994

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GONZALEZ, RICARDO

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed breaking device missing on fire extinguisher on third floor building A.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329180

SISTO 1545 NW 1 STREET APARTMENTS

License Type: Apartment

1545 NW 1 STREET, MIAMI 33125

Inspection Date: 05/09/2022

Inspection Number: 1527855

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed next to unit #2, #14, #20, #30, #24
 Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328893

HAVANA INN

License Type: Apartment

193 NW 58 ST, MIAMI 33127

Inspection Date: 05/10/2022

Inspection Number: 1513770

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SAENZ, HILDA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at the second floor next to apartment # 10 and also the one located next to restroom at the second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2319919

BORINQUEN APARTMENTS

License Type: Apartment

425-435 SW 10 AVE, MIAMI 33130

Inspection Date: 05/12/2022

Inspection Number: 1535261

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Observed at fire extinguisher next to unit 308.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed fire extinguisher next to unit 318 missing breaking device at building 435.
Observed fire extinguisher next to unit 300 missing breaking device at building 425.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2321976

LATIN QUARTER APT

License Type: Apartment

1859 SW 5 ST, MIAMI 331353465

Inspection Date: 05/12/2022

Inspection Number: 1513368

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. First floor next to apartment 8

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305603

DWBJ CORP

License Type: Apartment

243 NW 10 ST, MIAMI 331363435

Inspection Date: 05/10/2022

Inspection Number: 1515823

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 1.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310225

DESIGN PLACE

License Type: Apartment

5035 NE 2 AVE, MIAMI 331372917

Inspection Date: 05/10/2022

Inspection Number: 1519415

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at building 5265.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309788 1031-41 NE 78TH ROAD, LLC
 License Type: Apartment 1020 NE 78TH ROAD, MIAMI 33138

Inspection Date: 05/13/2022 Inspection Number: 1521336 Inspection Type: Routine - Lodging Inspection Disposition: Administrative complaint recommended
 Inspector Name: LODENQUAI, BARRINGTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartments 3 and 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301413

CASA MATANZA

License Type: Hotel

516 ESPANOLA WAY, MIAMI BEACH 33139

Inspection Date: 05/11/2022

Inspection Number: 1163116

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MASKASEM, SUPPACHAI

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305549

PLYMOUTH HOTEL

License Type: Hotel

336 21 ST, MIAMI BEACH 33139

Inspection Date: 05/13/2022

Inspection Number: 1163777

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel located behind front desk area. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303220

LAPPI PARADISE LLC

License Type: Apartment

600 79TH ST, MIAMI BEACH 33141

Inspection Date: 05/09/2022

Inspection Number: 1528799

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: PRIETO, VICENTE

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device by unit 6. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2306883

YTECH-180 UNITS MIAMI BEACH INVESTMENT

License Type: Apartment

715 78 ST, MIAMI BEACH 33141

Inspection Date: 05/13/2022

Inspection Number: 1524630

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PRIETO, VICENTE

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device on fire extinguisher box by unit 4 (building 7819), by unit 3, unit 4, unit 8, unit 6 (building 780)

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309694

DECO LINDO APARTMENTS

License Type: Apartment

6834 HARDING AVE, MIAMI BEACH 33141

Inspection Date: 05/09/2022

Inspection Number: 1530620

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located next to Apt 15.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329678

REGAL APARTMENTS LLC

License Type: Apartment

6020 NW 13 AVE, MIAMI 33142

Inspection Date: 05/12/2022

Inspection Number: 1514937

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Observed fire extinguisher next to unit 15 missing breakage device

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330169

OSPREY APARTMENTS LLC

License Type: Apartment

5329 NW 17 AVE, MIAMI 33142

Inspection Date: 05/10/2022

Inspection Number: 1526593

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BROWN, JARON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329740

AMLI DADELAND

License Type: Apartment

8250 SW 72 CT, MIAMI 33143

Inspection Date: 05/09/2022

Inspection Number: 1522201

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PICO, JORGE

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed in building 8250 ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2603702

RIVERVIEW APARTMENTS

License Type: Apartment

301 CARAVAN CIR, JACKSONVILLE 32216

Inspection Date: 05/10/2022

Inspection Number: 1535244

Inspection Type: Lodging-Licensing

Inspection Disposition: Warning

Inspector Name: VILBRUN, JOSUE

Inspection

Issued

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.
Missing fire extinguisher inside laundry area on wall where red storage case is located next to pool area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613196

QUALITY INN OF ORANGE PARK

License Type: Motel

6135 YOUNGERMAN CIR, JACKSONVILLE 32244

Inspection Date: 05/10/2022

Inspection Number: 1221390

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only
From designated location by room 161

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2612170

EXTENDED STAY AMERICA

License Type: Motel

10020 SKINNER LAKE DR, JACKSONVILLE 32246

Inspection Date: 05/09/2022

Inspection Number: 1221668

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JEFFERS, MARY-BETH

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
 No boiler certificate available at boilers. Sticker posted on both boiler displays expiration date of 7-29-22. Operator called corporate office to have

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hamilton County

License Number: 3400014

AMERICAN INN

License Type: Motel

8072 SR 6 W, JASPER 32052

Inspection Date: 05/10/2022

Inspection Number: 1222734

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit.
For reporting purposes only. In room 21.

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hernando County

License Number: 3700960

MICROTEL INN & SUITES

License Type: Hotel

6298 NATURE COAST BLVD, BROOKSVILLE 34602

Inspection Date: 05/10/2022

Inspection Number: 1161709

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: COLE, GABRIELLE

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By room 325, 301, 209. - From follow-up inspection 2022-04-19: **Time Extended** - From follow-

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3905481

WATERSTONE APARTMENTS

License Type: Apartment

3339 HANDY RD, TAMPA 33618

Inspection Date: 05/13/2022

Inspection Number: 1526963

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRADY, OSSIAN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Observed trouble light on at fire access control panel of building 9 next to 913.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4604656

LAGO DEL SOL APARTMENTS

License Type: Apartment

10770 CLEAR LAKE LOOP, FORT MYERS 33908

Inspection Date: 05/13/2022

Inspection Number: 1525888

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only. Buildings 15061 and 15101. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5100174

TALTY'S SUN RAY COURT

License Type: Apartment

905 E 30 AVE, BRADENTON 342083947

Inspection Date: 05/12/2022

Inspection Number: 1513440

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AUBIN, GARY

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed in unit 929 wire cut out before going in unit. As a repeat violation the importance of following proper protocol with this violation was reinforced with the empl

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809119

EXTENDED STAYAMERICA #1613

License Type: Hotel

5620 MAJOR BLVD, ORLANDO 32819

Inspection Date: 05/10/2022

Inspection Number: 1163951

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL 094905 and FL 094906 expired 8/9/21

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900611

MONTECARLO INN

License Type: Motel

4733 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 05/13/2022

Inspection Number: 1220773

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: OCASIO-LOPEZ, LISA

Violation CodeObservationViolation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900705

PALM MOTEL (THE)

License Type: Motel

4519 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 05/13/2022

Inspection Number: 1221615

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: OCASIO-LOPEZ, LISA

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900719

ECONO LODGE

License Type: Motel

4669 W IRLO BRONSON HWY, KISSIMMEE 34746

Inspection Date: 05/13/2022

Inspection Number: 1222777

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing striker by room 205

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014081

ESTATES AT WELLINGTON GREEN

License Type: Apartment

2301 WELLINGTON GREEN DR, WELLINGTON 33414

Inspection Date: 05/09/2022

Inspection Number: 1519580

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: FRANCO, BROOKE

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
 Building 23 outside 106 and 206.
 Building 21 between 101 and 102.
 Building 6 outside 207.
 Building 5 next to 302.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014169

AXIS WELLINGTON GREEN

License Type: Apartment

3409 POMEROL DR, WELLINGTON 33414

Inspection Date: 05/10/2022

Inspection Number: 1518962

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: FRANCO, BROOKE

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Building 4 outside 406.
Building 1 next to 401,301, 304

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014174

CONGRESS APARTMENTS

License Type: Apartment

4177 S CONGRESS AVE, LAKE WORTH 33461

Inspection Date: 05/10/2022

Inspection Number: 1530697

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed at unit 14

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6216235 N/A
 License Type: Apartment 700 1 ST N, ST PETERSBURG 33701

Inspection Date: 05/12/2022 Inspection Number: 1533082 Inspection Type: Lodging-Licensing Inspection Disposition: Warning Issued
 Inspector Name: MURPHY, JAMES Inspection

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
07-01-4	Damaged electrical wire(s). For reporting purposes only. Exposed wiring for overhead light in second floor laundry room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	- From initial inspection : Damaged electrical wire(s). For reporting purposes only. Exposed wiring for overhead light in second floor laundry room. - From follow-up inspection 2022-05-13:	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6212549

CHESAPEAKE APARTMENTS

License Type: Apartment

2307 CUMBERLAND CIR, CLEARWATER 33763

Inspection Date: 05/13/2022

Inspection Number: 1521044

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKINNEY, JOHN

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Building 24 1st floor extinguisher

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6201261

EITEL-SYNDER APARTMENTS

License Type: Apartment

301 NIMBUS AVE S, CLEARWATER 33765

Inspection Date: 05/10/2022

Inspection Number: 1513698

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CUDEMOS, HAIDA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed near apartment 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6216144

GRAND HAVEN APARTMENTS

License Type: Apartment

415 WOODROW AVE, LARGO 33770

Inspection Date: 05/10/2022

Inspection Number: 1517776

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HEFFNER, CHRISTOPHER

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6208979

APARTMENT

License Type: Apartment

360 N 2 AVE, SAFETY HARBOUR 346953655

Inspection Date: 05/11/2022

Inspection Number: 1523040

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 360 near apartment G ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804211

TGM UNIVERSITY PARK

License Type: Apartment

6001 MEDICI CT, SARASOTA 34243

Inspection Date: 05/12/2022

Inspection Number: 1524113

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EASLER, VERONICA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Observed light on fire alarm control panel for trouble control building 6230 alarm MOD INVREF 02:39 P 051122 1M023. Operator stated that the are aware of the

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804830

OAKWOOD APARTMENTS

License Type: Apartment

6720 15TH ST E, SARASOTA 34243

Inspection Date: 05/11/2022

Inspection Number: 1529680

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EASLER, VERONICA

Violation Code

Observation

Violation Citation

04-01-4	<p>Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.</p> <p>Observed light on fire alarm control panel for trouble control building 1309 NAC trip open 10:06 AM 050922 1M024. Operator and maintenance personnel stated tha</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
04-06-4	<p>Fire alarm control panel emitting an audible alarm. For reporting purposes only.</p> <p>Observed light on fire alarm control panel for trouble control building 1309 NAC trip open 10:06 AM 050922 1M024. Operator and maintenance personnel stated that they are aw</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Seminole County

License Number: 6901069

DAYS INN ALTAMONTE SPRINGS

License Type: Motel

150 S WESTMONTE DR, ALTAMONTE SPRINGS 32714

Inspection Date: 05/09/2022

Inspection Number: 1217245

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VAZQUEZ, JULITZA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher by ice machine close to room 131.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501640

EMBASSY SUITES

License Type: Hotel

300 A1A BEACH BLVD, ST. AUGUSTINE BEACH 32080

Inspection Date: 05/09/2022

Inspection Number: 1163426

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GROTZ, CINDY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401143

MAINSAIL INN & SUITES

License Type: Motel

281 S ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 05/10/2022

Inspection Number: 1222772

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in lobby. For reporting purposes only.

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.