

**Bay County**

License Number: 1301493

WESTWOOD VILLAGE

License Type: Apartment

2203 BECK AVE, PANAMA CITY 32405

Inspection Date: 05/18/2022

Inspection Number: 1535250

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: LYNN, NICKOLAS

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Outside of E3 and G7.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bradford County**

License Number: 1400184

SEP RENTALS

License Type: Apartment

12610 S US 301, STARKE 32091

Inspection Date: 05/18/2022

Inspection Number: 1520364

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BADDING, MELANIE

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.  
Did not observe a fire extinguisher on the property during inspection.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1505033

SUBURBAN EXTENDED STAY HOTEL MELBOURNE

License Type: Hotel

1125 AIRPORT BLVD, MELBOURNE 32901-2937

Inspection Date: 05/17/2022

Inspection Number: 1164542

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Supervisory light on, horn circuit. Manager reset panel. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1505723

HAMMOCK HARBOR APARTMENTS

License Type: Apartment

1330 NAPLES CR #105, ROCKLEDGE 32955

Inspection Date: 05/20/2022

Inspection Number: 1530441

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FICHTER, GARRICK

Violation Code

Observation

Violation Citation

12-04-4

High Priority - Balcony/starway/platform collapsed.  
The rear stairwell on building 3 next to unit 108 has a step in disrepair. Operator placed caution tape, blocking off stairwell. Secondary stairwell grants access to units.

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

**Broward County**

License Number: 1613150

LEXFORD PROP INC

License Type: Apartment

2482 OAK GARDENS LN, HOLLYWOOD 33020-1652

Inspection Date: 05/19/2022

Inspection Number: 1521180

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed next to Unit 2403.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed the extinguisher box next to unit 2483, 2404, 2412, 2420, 2426, 2438, 2456, 2464, 2472 2506, the building 16 laundry room,

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1601526

CLEVELAND PARADISE APARTMENTS

License Type: Apartment

1720 CLEVELAND ST, HOLLYWOOD 33020-2803

Inspection Date: 05/17/2022

Inspection Number: 1516362

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed at the extinguisher between units 210E and 211E.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1621290

AMARAY LAS OLAS BY WINDSOR LLC

License Type: Apartment

215 SE 8 AVE, FORT LAUDERDALE 33301

Inspection Date: 05/17/2022

Inspection Number: 1517664

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KHATOON, BEGUM

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1600802

GRANADA HALL

License Type: Apartment

3000 GRANADA ST, FORT LAUDERDALE 33304

Inspection Date: 05/20/2022

Inspection Number: 1523632

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on second floor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1604403

GHG SDB002 LLC

License Type: Apartment

1020-1050 NE 7 AVE, FORT LAUDERDALE 33304

Inspection Date: 05/16/2022

Inspection Number: 1526938

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PITRE, ASTRID

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only Building 1040 under staircase at unit 28.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Broward County**

License Number: 1620799

9TH STREET APTS

License Type: Apartment

1701 NE 9 ST, FORT LAUDERDALE 33304

Inspection Date: 05/16/2022

Inspection Number: 1514071

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed on side of 1701 building

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1621597

VICTORIA PARK HARBOR LLC

License Type: Apartment

1500 NE 6TH CT, FORT LAUDERDALE 33304

Inspection Date: 05/16/2022

Inspection Number: 1527117

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed at unit 4,7

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1605101

SILVER MIST APARTMENTS

License Type: Apartment

1045 NE 9 AVE, FORT LAUDERDALE 33304-2118

Inspection Date: 05/19/2022

Inspection Number: 1513995

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only  
Observed outside of unit 3

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Clay County**

License Number: 2000960

COURTYARD BY MARRIOTT ORANGE PARK

License Type: Hotel

610 WELLS RD, ORANGE PARK 32073

Inspection Date: 05/16/2022

Inspection Number: 1162774

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRES, WILLIAM

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Observed trouble light on for supervisory RE: Duct.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2101614

HAMPTON INN NAPLES- CENTRAL

License Type: Hotel

3210 TAMIAMI TRL N, NAPLES 34103

Inspection Date: 05/16/2022

Inspection Number: 1164538

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: GRAVES, PETER

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. The boiler certification has expired, 134141, 5/10/2021, 124012, 5/10/2021.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2102713

SUMMER LAKES APTS II

License Type: Apartment

5600 JONQUIL CIR, NAPLES 34109

Inspection Date: 05/19/2022

Inspection Number: 1518611

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: SOMMERS, KARA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher near stairway near Units 205 & 206, Building 4 and Units 101 & 102, Building 1.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Extinguisher near Units 307 & 308, Building 2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2102715

OASIS NAPLES APARTMENTS

License Type: Apartment

2277 ARBOUR WALK CIR, NAPLES 34109

Inspection Date: 05/18/2022

Inspection Number: 1518632

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: GRAVES, PETER

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. There is no device to access the fire extinguisher by apartment 213, building 2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2102466

DOUBLETREE GUEST SUITES NAPLES

License Type: Hotel

12200 N TAMIAMI TRL, NAPLES 34110

Inspection Date: 05/18/2022

Inspection Number: 1162235

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: BARKLEY, KENDELL

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed no boiler certificate for establishment. - From follow-up inspection 2022-05-18: Observed no boiler certificate

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2310926

PLAYA AZUL APTS

License Type: Apartment

465 W 11 ST, HIALEAH 33010

Inspection Date: 05/19/2022

Inspection Number: 1515986

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: VILCHEZ, NABEL

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between apartments #6 and #7.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2328228

GONZALEZ APARTMENTS

License Type: Apartment

137 W 6 ST, HIALEAH 33010

Inspection Date: 05/20/2022

Inspection Number: 1527479

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SANCHEZ, JAVIER

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330567

SEASCAPE POINTE APARTMENTS

License Type: Apartment

1140 SE 24 RD, HOMESTEAD 33035-2281

Inspection Date: 05/16/2022

Inspection Number: 1517833

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: GONZALEZ, RICARDO

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.  
Observed breaking device missing missing on extinguisher between unit 1041 and 1047.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2309410

CREEK CLUB APTS INC

License Type: Apartment

1441 NW 19 ST, MIAMI 331251584

Inspection Date: 05/20/2022

Inspection Number: 1518087

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2313384

CHASE HOLDINGS INC.

License Type: Apartment

2170 NW 11 ST, MIAMI 331252753

Inspection Date: 05/18/2022

Inspection Number: 1522777

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at multiple fire extinguishers **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2313496

RIVERLAND APTS

License Type: Apartment

2138 NW FLAGLER TERR, MIAMI 331255343

Inspection Date: 05/18/2022

Inspection Number: 1522778

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apartment number 2 and 5 **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2310764

RENE APARTMENTS

License Type: Apartment

1342 NW 3 ST, MIAMI 331255636

Inspection Date: 05/20/2022

Inspection Number: 1515652

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apartment #2. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2327822

GIANNI APARTMENT

License Type: Apartment

440 NW 35 ST, MIAMI 33127

Inspection Date: 05/18/2022

Inspection Number: 1522905

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2328893

HAVANA INN

License Type: Apartment

193 NW 58 ST, MIAMI 33127

Inspection Date: 05/16/2022

Inspection Number: 1513770

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: SAENZ, HILDA

Violation CodeObservationViolation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at the second floor next to apartment # 10 and also the one located next to restroom at the sec

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2308279

JOHNSON APTS

License Type: Apartment

5000 NW 2 AVE, MIAMI 331272176

Inspection Date: 05/13/2022

Inspection Number: 1527495

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.  
Observed light fixture in front of Apt 6 being held up by exposed wires.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2324062

TRIMARK INVESTMENT PARTNERS LLC

License Type: Apartment

553 SW 5 ST, MIAMI 33130

Inspection Date: 05/20/2022

Inspection Number: 1522221

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.  
Observed no breaking device provided at fire extinguisher box located near unit 4.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329499

CITIZENM

License Type: Hotel

11 SE 10 ST, MIAMI 33131

Inspection Date: 05/18/2022

Inspection Number: 1162846

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: CABANAS, NATALIE

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  
At the time of the inspection observed establishment has three boilers with input rating of 700,000 btu. No boiler certificate provided.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2300997

VQ EVERGLADES PROPERTIES LLC

License Type: Apartment

1306 SW 6 ST, MIAMI 33135

Inspection Date: 05/16/2022

Inspection Number: 1514196

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: GARCIA, B OSCAR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
**\*\*Warning\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2310510

PEREZ APTS

License Type: Apartment

1544 SW 2 ST, MIAMI 33135

Inspection Date: 05/17/2022

Inspection Number: 1514367

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. 1 st floor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2314629 DONALD F LIGHT TRS #1261  
 License Type: Apartment 1261 SW 4 ST, MIAMI 33135

Inspection Date: 05/17/2022 Inspection Number: 1524298 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329714

VC 1553 LLC

License Type: Apartment

1553 SW 2 ST, MIAMI 33135

Inspection Date: 05/17/2022

Inspection Number: 1524507

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm  
control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2304613

DEVILLA INVESTMENTS APTS

License Type: Apartment

930 SW 31 AVE, MIAMI 331354553

Inspection Date: 05/19/2022

Inspection Number: 1527451

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Next to apartment 7 .

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. Missing fire extinguisher next to apartment 5

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330005

MIDTOWN FIVE

License Type: Apartment

125 NE 32 ST, MIAMI 33137

Inspection Date: 05/18/2022

Inspection Number: 1535150

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: SEYBA, JAMES

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329153

LITTLE RIVER BEND APARTMENTS

License Type: Apartment

8250 NE 4 PL, MIAMI 33138

Inspection Date: 05/18/2022

Inspection Number: 1518535

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Observed flashing red lights illuminated on the panel in the office.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330563

EUROAMERICA INVESTMENTS

License Type: Apartment

80 NE 82 TERR, MIAMI 33138

Inspection Date: 05/17/2022

Inspection Number: 1527019

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.  
Observed by apartments 2,7,8.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2305469

SHELBORNE SOUTH BEACH

License Type: Hotel

1801 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 05/16/2022

Inspection Number: 1163297

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler jurisdiction number's 055333; 055334 all expired on 04/28/2019. Observed boiler re-inspection report, which complied boiler inspection to issue

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2304462

SOUTH GATE TOWERS APARTMENTS

License Type: Apartment

900 WEST AVE, MIAMI BEACH 331395233

Inspection Date: 05/19/2022

Inspection Number: 1518160

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located next to East stairs.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2305552

DORCHESTER HOTEL

License Type: Hotel

1850 COLLINS AVE, MIAMI BEACH 331397499

Inspection Date: 05/19/2022

Inspection Number: 1164042

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher located between room doors 259 & 261, up stairwell. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2310357

KEREM NORTH BEACH APTS LLC

License Type: Apartment

8215-8221 HARDING AVE, MIAMI BEACH 33141

Inspection Date: 05/16/2022

Inspection Number: 1533679

Inspection Type: Lodging-Licensing  
InspectionInspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed by unit 8, building 8215.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2328444

HACH ALLUCH I LLC

License Type: Apartment

7820 HARDING AVE, MIAMI BEACH 33141

Inspection Date: 05/18/2022

Inspection Number: 1525583

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PRIETO, VICENTE

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device in fire extinguisher box at building north side. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2300683

APARTAMENTOS NONONI LLC

License Type: Apartment

6001 SW 76 ST, MIAMI 33143

Inspection Date: 05/20/2022

Inspection Number: 1519424

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed breaking device missing on extinguisher by unit 1,4,5, 10.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2302135

PALM PLAZA APARTMENTS LLP

License Type: Apartment

5791 SW 74 TERR, SOUTH MIAMI 33143

Inspection Date: 05/20/2022

Inspection Number: 1526686

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed needle in the red on fire extinguisher located on 2nd floor in front of unit 14. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2303802

PEREZ FAMILY APTS

License Type: Apartment

3133 SW 23 TERR, MIAMI 331453154

Inspection Date: 05/18/2022

Inspection Number: 1515809

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Fire extinguisher located on the first floor by the electric meter room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2324350

SUN POINT RENTALS

License Type: Apartment

11180 SW 107 ST, MIAMI 331768269

Inspection Date: 05/18/2022

Inspection Number: 1527561

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

01-05-4

- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Fire extinguisher located by unit 305 and unit 109 in building 11180. Fire extinguisher located by unit 102 in building 11190. - From follo

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2600745

BUDGET OF JAX

License Type: Motel

6545 RAMONA BLVD, JACKSONVILLE 32205

Inspection Date: 05/20/2022

Inspection Number: 1221679

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit.  
For reporting purposes only. In room 105, smoke  
detractor in desk drawer

509.215(1) and (2) and 509.032(2)(d) FS Reporting:  
509.215(1) Each guest room shall be equipped with an  
approved listed single-station smoke detector meeting  
the minimum requirements of NFPA-74 Standards for  
the Installation, Maintenance and Use of Household Fire  
Warning Equipment. (2) The building has smoke  
detectors in each guest room individually annunciating  
to a panel at a supervised location. 509.032(2)(d) The  
division, or its agent, shall notify the local firesafety  
authority or the State Fire Marshal of any readily  
observable violation of a rule adopted under chapter  
633 which relates to public lodging establishments or  
public food establishments, and the identification of  
such violation does not require any firesafety  
inspection certification. For reporting purposes only.

**Duval County**

License Number: 2608861

BEST STAY AMERICA

License Type: Motel

8220 DIX ELLIS TRAIL, JACKSONVILLE 32256

Inspection Date: 05/19/2022

Inspection Number: 1219641

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
Complaint Time Extension

Inspector Name: JEFFERS, MARY-BETH

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher between rooms #246-248 in undercharged zone of gauge - From follow-up inspection 2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3901297

ALASKA MOTEL

License Type: Motel

1307 E HILLSBOROUGH AVE, TAMPA 336047209

Inspection Date: 05/18/2022

Inspection Number: 1222800

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: AUDETTE, DAKOTA

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Smoke detector remove from wall room 4.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3906542

HOLIDAY INN TAMPA AIRPORT WESTSHORE

License Type: Hotel

700 N WESTSHORE BLVD, TAMPA 33609

Inspection Date: 05/16/2022

Inspection Number: 1162362

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
 \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3902312

LENOX PLACE APARTMENTS

License Type: Apartment

11311 N 22ND ST, TAMPA 33612

Inspection Date: 05/17/2022

Inspection Number: 1531452

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MCKINNEY, JOHN

Violation CodeObservationViolation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.  
Fire panel in building 11311 no power. Manager contacted Life and Safety for servicing and contacted Tampa Safety Council for overnight.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3902550

BAYWATCH APTS

License Type: Apartment

11728 N 14TH ST, TAMPA 33612

Inspection Date: 05/19/2022

Inspection Number: 1516667

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKINNEY, JOHN

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.  
 Building 1335 between units 101 and 102  
 Building 1312 between units 101 and 102

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3913710

PALM SQUARE HOMES PREFERRED NAME

License Type: Apartment

102 E 122 AVE, TAMPA 33612

Inspection Date: 05/17/2022

Inspection Number: 1531270

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKINNEY, JOHN

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.  
Located on 2nd floor between units B-206 and B-207

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3903555

RIVERSIDE PALMS APARTMENTS

License Type: Apartment

5008 SIERRA PL, TAMPA 33617

Inspection Date: 05/17/2022

Inspection Number: 1535298

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: REGAS, ANTHONY

Violation Code

Observation

Violation Citation

12-04-4

High Priority - Balcony/starway/platform collapsed. Observed the stairwell and platform fo building 8413 units 506,606, and 607. Is collapsed. The area is closed and being blocked by caution tape. The residents have been moved to a hotel and they are wa

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

**Manatee County**

License Number: 5102928

M\*STAR BRADENTON

License Type: Motel

6511 14 ST W, BRADENTON 34207

Inspection Date: 05/17/2022

Inspection Number: 1217261

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: CATTLEY, RAYMOND

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-04-26: Observed system silence \*\*Time Extended\*\* - From follow-up inspection 2022-05-17:

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5105118

TROPIC ISLE AT THE ANNA MARIA ISLAND INN

License Type: Apartment

101 22 ST N, BRADENTON BEACH 34217

Inspection Date: 05/20/2022

Inspection Number: 1535237

Inspection Type: Lodging-Licensing  
InspectionInspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PIPIC, DINKA

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.  
Main fire panel trouble light blinking.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Marion County**

License Number: 5200122

BUDGET HOST INN

License Type: Motel

4013 NW BLITCHTON RD, OCALA 34475

Inspection Date: 05/19/2022

Inspection Number: 1221332

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: DRIGGERS, MANDY

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.  
Near unit 111.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Marion County**

License Number: 5200159

SILVER RIVER INN

License Type: Motel

5565 E SILVER SPRINGS BLVD, SILVER SPRINGS 34488

Inspection Date: 05/16/2022

Inspection Number: 1222781

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.  
Exit sign cover is removed wires are exposed near stairs behind office

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5400347

FISHER INN RESORT

License Type: Motel

84951 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 05/19/2022

Inspection Number: 1222229

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

03-01-4

- From initial inspection : No fire sprinkler system installed in a transient lodging establishment three stories or more in height, or over 75 feet in height. For reporting purposes only. - From follow-up inspection 2022-05-19: \*\*Time Extended\*\*

509.215 and 509.032(2)(d) FS Reporting: 509.215 Any public lodging establishment, as defined in this chapter, which is of three stories or more, or over 75 feet in height shall be equipped with an automatic sprinkler system installed in compliance with the provisions prescribed in the National Fire Protection Association publication NFPA No. 13 "Standards for the Installation of Sprinkler Systems. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5401786

WATERSIDE SUITES & MARINA

License Type: Motel

201 OCEAN DR, KEY LARGO 33037

Inspection Date: 05/13/2022

Inspection Number: 1222186

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: GONZALEZ, RICARDO

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
**\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811165

MARRIOTT ORLANDO DOWNTOWN

License Type: Hotel

400 W LIVINGSTON ST, ORLANDO 32801

Inspection Date: 05/18/2022

Inspection Number: 1162004

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ASSEFA, MARKIA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Per operator awaiting part to make repairs to two boilers. Certificate expired 2-19-21

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5801774

DOUBLETREE BY HILTON ORLANDO UNIVERSAL

License Type: Hotel

5780 MAJOR BLVD, ORLANDO 32819

Inspection Date: 05/16/2022

Inspection Number: 1163330

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. FL094886/FL131360. Expired 11-5-21; FL094909/FL094908/FL094910. Expired 11/5/17

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5809882

COURTYARD ORLANDO LK BUENA VISTA

License Type: Hotel

8623 VINELAND AVE, ORLANDO 32821

Inspection Date: 05/20/2022

Inspection Number: 1161939

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811325

CORTLAND WORLD GATEWAY

License Type: Apartment

15050 EMBER SPRINGS CIR, ORLANDO 32821

Inspection Date: 05/20/2022

Inspection Number: 1517620

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811108

RESIDENCE INN ORLANDO AIRPORT

License Type: Hotel

7024 AUGUSTA NATIONAL DR, ORLANDO 32822

Inspection Date: 05/18/2022

Inspection Number: 1163180

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./  
observed system trouble at main fire panel  
**\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811291

LINDEN ON THE GREENEWAY LLC

License Type: Apartment

13000 BREAKING DAWN DR, ORLANDO 32824

Inspection Date: 05/17/2022

Inspection Number: 1535211

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALVIS, DAVID

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5808160

DISNEY'S BOARDWALK INN

License Type: Hotel

2101 N EPCOT RESORT BLVD, BAY LAKE 328301000

Inspection Date: 05/12/2022

Inspection Number: 1163370

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Room 5050

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5810223

LAKE BUENA VISTA RESIDENCE INN

License Type: Hotel

11450 MARBELLA PALM CT, ORLANDO 32836

Inspection Date: 05/18/2022

Inspection Number: 1164543

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler  
report expired. For reporting purposes only.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report  
is required annually for power boilers and high  
pressure/high temperature boilers and biannually for  
low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the  
local firesafety authority or the State Fire Marshal of  
any readily observable violation of a rule adopted under  
chapter 633 which relates to public lodging  
establishments or public food establishments, and the  
identification of such violation does not require any  
firesafety inspection certification. For reporting  
purposes only.

**Orange County**

---

License Number: 5805672

BLUE TREE RESORT

License Type: Apartment

12007 CYPRESS RUN RD, ORLANDO 328366421

**Orange County**

Inspection Date: 05/17/2022

Inspection Number: 1513460

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation CodeObservationViolation Citation

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler Certificates expired in February. Manager and engineer is working on getting them updated with carbon monoxide detectors.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. Building 10.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 05/16/2022

Inspection Number: 1164527

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BORRERO, AUDREY

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

The hotel is waiting for the inspector to deliver the certificates. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6203125

SAHARA MOTEL

License Type: Motel

10910 GANDY BLVD, ST PETERSBURG 337021430

Inspection Date: 05/17/2022

Inspection Number: 1221789

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.  
 Unable to test Gentex hearing impaired smoke alarm due to it needing to be hard wired. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6208792

QUALITY INN- RODEWAY INN

License Type: Motel

20162 US HWY 19, CLEARWATER 33764

Inspection Date: 05/16/2022

Inspection Number: 1222789

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only.  
 Inside of laundry room. Operator moved out of laundry room \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6205337

BREYLEY APARTMENTS

License Type: Apartment

1820 SUNSET PT RD, CLEARWATER 33765

Inspection Date: 05/20/2022

Inspection Number: 1529636

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: PEARCE, LAURA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing tool at lock box in front of apartment 1812- O

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6306134

HYATT PLACE LAKELAND CENTER

License Type: Motel

525 W ORANGE ST, LAKELAND 33815

Inspection Date: 05/17/2022

Inspection Number: 1220079

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6300396

WINTER HAVEN GARDENS INN & BANQUET CENTER

License Type: Motel

1150 3 ST SW, WINTER HAVEN 33880

Inspection Date: 05/19/2022

Inspection Number: 1222803

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: WHITE, CHERYL

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. 135787 exp 10/03/21 130269 exp 10/02/21 For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7400503

BAYMONT INN & SUITES

License Type: Motel

2725 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 05/18/2022

Inspection Number: 1222791

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-05-18: Maintenance states fire alarm company has been called Manager states are under a fire wa	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406560

MAPLELEAF GARDENS LLC

License Type: Apartment

1202 RIDGEWOOD AVE, HOLLY HILL 32117

Inspection Date: 05/17/2022

Inspection Number: 1526955

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

07-01-4

Electrical wiring in disrepair. Exposed electrical wire(s) on north end of property. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406659

3 DOT REALTY MANAGEMENT, LLC

License Type: Apartment

1202 RIDGEWOOD AVE, HOLLY HILL 32117

Inspection Date: 05/17/2022

Inspection Number: 1520206

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

07-01-4

Electrical wiring in disrepair. Exposed electrical wire(s) on north end of the property. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406606

VIRGIL AND ELLEN ROSENFELD FAMILY TRUST

License Type: Apartment

419 N WILD OLIVE AVE, DAYTONA BEACH 32118

Inspection Date: 05/16/2022

Inspection Number: 1529528

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

12-04-4

High Priority - Stairway platform in severe  
disrepair.61C-1.004(5) FAC High Priority: All building structural  
components, attachments and fixtures shall be kept in  
good repair.-floor has loose wood board fit over top, leading to  
to unit 6 \*\*Warning\*\*

License Number: 7406665

HUMMINGBIRD PROPERTY NSB, LLC

License Type: Apartment

206 DOUGLAS STREET, NEW SMYRNA BEACH 32168

Inspection Date: 05/16/2022

Inspection Number: 1522648

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

12-04-4

High Priority - On exterior stairway to unit 5,  
wooden 2x10 tread loose/moves when stepped  
on. 3rd down from the top \*\*Warning\*\*61C-1.004(5) FAC High Priority: All building structural  
components, attachments and fixtures shall be kept in  
good repair.

**Volusia County**

License Number: 7401460

MAKAI BEACH RESORT

License Type: Motel

707 S ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 05/16/2022

Inspection Number: 1217588

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2022-05-16:

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.