

Bay County

License Number: 1304699

WEBB RENTAL

License Type: Apartment

1540 MULBERRY AVE, PANAMA CITY 32402

Inspection Date: 05/27/2022

Inspection Number: 1514219

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. On front of building 1

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621192

FOUR SEASONS DEVELOPMENT INC

License Type: Apartment

125 SE 9 CT, HALLANDALE BEACH 33009

Inspection Date: 05/24/2022

Inspection Number: 1523757

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: GANPAT, INDAR

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell , opposite unit 104. For reporting purposes only

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1600539

JACKSON ARMS APTS

License Type: Apartment

2506 PIERCE ST, HOLLYWOOD 33020-4389

Inspection Date: 05/23/2022

Inspection Number: 1530448

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed to the left of Unit 5B.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1601447

PILCO'S APTS

License Type: Apartment

2337 FILLMORE ST, HOLLYWOOD 33020-4487

Inspection Date: 05/23/2022

Inspection Number: 1513909

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CHRISTGEN, THOM

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed between unit 3 and 4.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1602567

NAPOLI APARTMENT MOTEL

License Type: Apartment

701 N BIRCH RD, FORT LAUDERDALE 33304-4024

Inspection Date: 05/25/2022

Inspection Number: 1518773

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BRANN, JUSTIN

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
By Apt 122. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1603760

LAKEVIEW APTS

License Type: Apartment

3810 SW 60 AVE, DAVIE 33314

Inspection Date: 05/24/2022

Inspection Number: 1518620

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only.
Liquid propane tank attached to outdoor style burner stored under table in laundry room bldg 3810.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1619114

LAKEVIEW APTS

License Type: Apartment

3720 SW 59 AVE, DAVIE 33314

Inspection Date: 05/24/2022

Inspection Number: 1527941

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Extinguisher by door to unit 2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Citrus County

License Number: 1900104

PORT PARADISE HOTEL LLC

License Type: Hotel

1610 SE PARADISE CIR, CRYSTAL RIVER 34429

Inspection Date: 05/23/2022

Inspection Number: 1163796

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: DODGE, DAVID

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102598

RITZ CARLTON NAPLES GOLF RESOR

License Type: Hotel

2600 TIBERON DR, NAPLES 34109

Inspection Date: 05/25/2022

Inspection Number: 1162077

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CANDO, JOHANA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 1 boiler certificate expired from 6. Operator has invoice for paid certification.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2101151

CORAL PALMS APARTMENTS

License Type: Apartment

4539 GOLDEN GATE PKWY, NAPLES 34116

Inspection Date: 05/27/2022

Inspection Number: 1518552

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Extinguishers near Unit 4, Building 4530; Unit 3, Building 4528.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200615

MHPJR, LLC

License Type: Apartment

584 S.E. PERRY AVE, LAKE CITY 32025

Inspection Date: 05/26/2022

Inspection Number: 1517856

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only
Outside both units of building 600.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330246

PRINCETON GROVES VILLAGE LLC

License Type: Apartment

25011 SW 130 AVE, PRINCETON 33032

Inspection Date: 05/24/2022

Inspection Number: 1517338

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: GONZALEZ, RICARDO

Violation CodeObservationViolation Citation

01-05-4

- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed breaking device missing at fire extinguisher on building 25151 between units 101 and 102. - From follow-up inspection 2022-05-24:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed trouble light flashing on building 25101
****Repeat Violation**** - From follow-up inspection 2022-05-24: Observed trouble

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300197

POMELO GROVE INVESTMENTS LLC

License Type: Apartment

68 NW 17 CT, MIAMI 33125

Inspection Date: 05/23/2022

Inspection Number: 1516697

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located at first floor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301432

LITTLE HAVANA 544

License Type: Apartment

544 NW 23 CT, MIAMI 33125

Inspection Date: 05/23/2022

Inspection Number: 1531071

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326605

ELITE RIVERVIEW APTS

License Type: Apartment

1750 NW 27 AVE, MIAMI 33125

Inspection Date: 05/24/2022

Inspection Number: 1525274

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: SAENZ, HILDA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed at the first floor between elevator and apartment #108.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329176

DANNY INC

License Type: Apartment

720 NW 27 CT, MIAMI 33125

Inspection Date: 05/23/2022

Inspection Number: 1520868

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located second floor next to unit 13.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300370

WEST DADE LTD II

License Type: Apartment

2330 NW 9 ST, MIAMI 331253200

Inspection Date: 05/27/2022

Inspection Number: 1513207

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2313439

MONADRI

License Type: Apartment

1030 NW 29 ST, MIAMI 33127

Inspection Date: 05/24/2022

Inspection Number: 1530941

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2320201

TACOLCY ECONOMIC DEVELOPMENT C

License Type: Apartment

5821 NW 7 AVE, MIAMI 33127

Inspection Date: 05/27/2022

Inspection Number: 1526720

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SAENZ, HILDA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at the fire extinguisher located next to the dumpster door at the first floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327761

METRO SUN 1065 APTS

License Type: Apartment

1065 NW 29 ST, MIAMI 33127

Inspection Date: 05/23/2022

Inspection Number: 1530866

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 10.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329300

CHUKIE INVESTMENT INC

License Type: Apartment

161 NW 37 ST, MIAMI 33127

Inspection Date: 05/24/2022

Inspection Number: 1530383

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 1.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300977

VC 1050 LLC

License Type: Apartment

1050 NW 2 ST, MIAMI 33128

Inspection Date: 05/11/2022

Inspection Number: 1528529

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: CUDEMOS, VIRNA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300188

VC 953 .

License Type: Apartment

953 SW 4 ST, MIAMI 33130

Inspection Date: 05/26/2022

Inspection Number: 1514705

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CRUZ, EDGAR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2314619

LIZ APARTMENT CORP

License Type: Apartment

134 SW 17 CT, MIAMI 33135

Inspection Date: 05/26/2022

Inspection Number: 1530294

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed st floor extinguisher not accessible.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330354

RAMON BETANCOURT 2001 TRUST

License Type: Apartment

128 SW 17 CT, MIAMI 33135

Inspection Date: 05/26/2022

Inspection Number: 1526833

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Underneath Stairways.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

06-03-4

Marked exit is inaccessible. For reporting purposes only. Observed Building repair items bicycles second-floor hallway.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310197

141 SW 14 AVE APTS

License Type: Apartment

141 SW 14 AVE, MIAMI 331352365

Inspection Date: 05/25/2022

Inspection Number: 1518130

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. In 1 st floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2313268 1820 APTS
 License Type: Apartment 1820 SW 6 ST, MIAMI 331353447

Inspection Date: 05/23/2022 Inspection Number: 1525135 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 1st floor extinguisher. **Warning**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301555

WEST DADE LTD

License Type: Apartment

1003 SW 15 AVE, MIAMI 331355257

Inspection Date: 05/23/2022

Inspection Number: 1518056

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GARCIA, B OSCAR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
****Warning****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327979 1117 NW 3RD AVENUE LLC

License Type: Apartment 1117 NW 3RD AVE, MIAMI 33136

Inspection Date: 05/23/2022

Inspection Number: 1531198

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By units 1 and 3.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-04-4	Fire alarm control panel has no power. For reporting purposes only. By unit 1.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327980

1117 NW 3RD AVENUE LLC

License Type: Apartment

220 NW 11 TERRACE, MIAMI 33136

Inspection Date: 05/23/2022

Inspection Number: 1531771

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By unit 2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. By unit 2

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329973

LLOWYE SEHOU

License Type: Apartment

225 NW 17 ST, MIAMI 33136

Inspection Date: 05/26/2022

Inspection Number: 1531304

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By apartments 2 and 4.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303941

747 PROPERTY, LLC

License Type: Apartment

747 NE 83 TERRACE, MIAMI 33138

Inspection Date: 05/25/2022

Inspection Number: 1514407

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Observed for all units except for unit on floor above apartment 20.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308378

738 NE 86 LLC

License Type: Apartment

738 NE 86 ST, MIAMI 33138

Inspection Date: 05/24/2022

Inspection Number: 1528868

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LODENQUAI, BARRINGTON

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Observed by apartment 7.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330164

THE CORRIDOR APARTMENTS

License Type: Apartment

760 NE 85 ST, MIAMI 33138

Inspection Date: 05/24/2022

Inspection Number: 1519624

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310334 142 NE 78 ST APARTMENTS
 License Type: Apartment 142 NE 78 ST, MIAMI 331384834

Inspection Date: 05/26/2022 Inspection Number: 1520921 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LODENQUAI, BARRINGTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed for unit between apartments 6 and 7.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2306387

ALBITE APARTMENTS

License Type: Apartment

8317 HARDING AVE, MIAMI BEACH 331411453

Inspection Date: 05/26/2022

Inspection Number: 1522734

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PRIETO, VICENTE

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device in fire extinguisher box by unit 3
****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300525

D`OR APTS

License Type: Apartment

7301 HARDING AVE, MIAMI BEACH 331412724

Inspection Date: 05/27/2022

Inspection Number: 1529744

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: PRIETO, VICENTE

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330817

MOSAICO

License Type: Apartment

1396 NW 36 ST, MIAMI 33142

Inspection Date: 05/23/2022

Inspection Number: 1535336

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: CRUZ, EDGAR

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2304560

PROSPER APTS

License Type: Apartment

3210 NW 22 AVE, MIAMI 331428588

Inspection Date: 05/26/2022

Inspection Number: 1520469

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BROWN, JARON

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Observed fire extinguisher in rear of unit 6 has no breakage device.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328203

DADELAND VISTA

License Type: Apartment

7000 SW 80 ST, MIAMI 33143

Inspection Date: 05/27/2022

Inspection Number: 1527477

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PICO, JORGE

Violation CodeObservationViolation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330433

EL GALLITO INVESTMENTS

License Type: Apartment

1325 SW 14 ST, MIAMI 33145

Inspection Date: 05/27/2022

Inspection Number: 1527035

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330352

ROCHELIN AND ROCHELIN PROPERTIES INC

License Type: Apartment

9580 NW 4 AVE, MIAMI 33150

Inspection Date: 05/24/2022

Inspection Number: 1514995

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JOSEPH, VANRIE

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330471

IVY COVE HOMES 2018 LLC

License Type: Apartment

6805 SW 88 ST, PINECREST 33156

Inspection Date: 05/23/2022

Inspection Number: 1517686

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. No breaking device on extinguisher next to laundry room. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302058

PRESTIGE GARDENS

License Type: Apartment

14165 NE 6 AVE, NORTH MIAMI 33161

Inspection Date: 05/25/2022

Inspection Number: 1515249

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SUAREZ, LEOPOLDO

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire Extinguisher by apt #6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303874

GRAND ISLAND PORTFOLIO LLC

License Type: Apartment

1495 NE 167 ST, NORTH MIAMI BEACH 33162

Dade County

Inspection Date: 05/25/2022

Inspection Number: 1535404

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: VILCHEZ, NABEL

Violation CodeObservationViolation Citation

01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only At building 300 located on first and second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. At building 300 located on first and second floor. - From follow-up inspection 20	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

- 01-05-4 - From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Next to apt #104. - From follow-up inspection 2022-05-26: At the time of callback inspection Portable fire extinguisher obstructed/not accessible.
- 01-05-4 Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Next to apt #104.
- 04-05-4 - From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Apartment #306 - From follow-up inspection 2022-05-26: At the time of callback inspection no smoke detector provided in guest room/unit. For reporting purposes only.
- 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
- 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
- 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

04-05-4	No smoke detector provided in guest room/unit. For reporting purposes only. Apartment #306	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	---

License Number: 2306245	TOWN PARKE APTS A
License Type: Apartment	9950 SW 8 ST, MIAMI 331742877

Inspection Date: 05/26/2022	Inspection Number: 1520402	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: GOMEZ-SANCHEZ, NELLY			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no device to access fire extinguisher located in east side laundry room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2600595

REGENCY INN

License Type: Motel

6237 ARLINGTON EXPY, JACKSONVILLE 32211

Inspection Date: 05/23/2022

Inspection Number: 1221017

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate expired 7/31/21 **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2602552

MONTEREY APT LLC

License Type: Apartment

1129 ARCO DR, JACKSONVILLE 32211

Inspection Date: 05/23/2022

Inspection Number: 1514431

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: THOMAS, PHILIP

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher in box between units 5 and 6 has been discharged and is in need of recharge

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2609107

DAYS INN JACKSONVILLE AIRPORT

License Type: Hotel

1170 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 05/25/2022

Inspection Number: 1164555

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit.
For reporting purposes only.
No alarm in room 109. ****Warning****

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613222

HOMEWOOD SUITES

License Type: Hotel

10434 MIDTOWN PKWY, JACKSONVILLE 32246

Inspection Date: 05/26/2022

Inspection Number: 1163584

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JEFFERS, MARY-BETH

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Both boiler certificates expired 12-12-21

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2608348

DAYS INN

License Type: Motel

8255 DIX ELLIS TRL, JACKSONVILLE 32256

Inspection Date: 05/23/2022

Inspection Number: 1222531

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: JEFFERS, MARY-BETH

Violation Code

Observation

Violation Citation

04-05-4 - From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only.
Smoke detector in room #141 in disrepair. Operator not to rent room until repaired and re-inspected **Warning** - From follow-up inspection 2022

07-04-4 - From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only.
Light switch in room #141 in disrepair. Room not to be rented until repaired and re-inspected **Warning** - From follow-up inspection 2022-

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913666

EXTENDED STAY AMERICA #9501

License Type: Hotel

10623 E BAY RD, GIBSONTON 33534

Inspection Date: 05/26/2022

Inspection Number: 1163321

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRUZ, JABULANI

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 2/10/22.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913605

OAKS AT RIVERVIEW

License Type: Apartment

202 E BROAD ST, TAMPA 33604

Inspection Date: 05/27/2022

Inspection Number: 1535455

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: VALENCIA, ASHLEY

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only
By unit 102A 103

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-02-4

Frayed electrical wire(s). For reporting purposes only. Internet provider box building 110

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913607

COURTYARD BY MARRIOTT

License Type: Hotel

3805 W CYPRESS ST, TAMPA 33607

Inspection Date: 05/26/2022

Inspection Number: 1163837

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913723

WESTHAVEN LLC

License Type: Apartment

4114 W N B ST, TAMPA 33609

Inspection Date: 05/25/2022

Inspection Number: 1527079

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Near mailboxes

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902312

LENOX PLACE APARTMENTS

License Type: Apartment

11311 N 22ND ST, TAMPA 33612

Inspection Date: 05/17/2022

Inspection Number: 1531452

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKINNEY, JOHN

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.
 Fire panel in building 11311 no power. Manager contacted Life and Safety for servicing and contacted Tampa Safety Council for overnight.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3914049

SHADOW PINES

License Type: Apartment

12202 N 15TH ST, TAMPA 33612

Inspection Date: 05/24/2022

Inspection Number: 1532867

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: CESAR, RACHEL

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only. Stairwell at building 100 blocked by bikes and chairs.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4502469

GARDEN PROPERTY

License Type: Apartment

1951 E ORANGE AVE, EUSTIS 32726

Inspection Date: 05/25/2022

Inspection Number: 1530873

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.

-on fascia outside of unit 4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4500195

COLONIAL INN MOTEL

License Type: Motel

1000 S BAY ST, EUSTIS 327265545

Inspection Date: 05/23/2022

Inspection Number: 1220825

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.
New installation, permit in window.
Left Voice Message for Eustis Fire Inspection, 352-357-6585.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4501094

MOUNT DORA APARTMENTS

License Type: Apartment

3001 NORTHLAND RD, MOUNT DORA 32757

Inspection Date: 05/24/2022

Inspection Number: 1512930

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: COREY, DEREK

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
-fire extinguisher box in laundry room near unit #98 missing breaker bar

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4500123

VILLA LAGOON INN

License Type: Motel

1051 LAKESHORE BLVD, TAVARES 32778

Lake County

Inspection Date: 05/23/2022

Inspection Number: 1220394

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

02-04-4

Gas can stored inside the building. For reporting purposes only.

-laundry room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning/unable to be tested.. For reporting purposes only. **Warning*
- From follow-up inspection 2022-05-24: Time extended **Time Extended** - From follow-up inspection 20

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

05-02-5	<p>- From initial inspection : Hearing-impaired smoke detector is not functioning/unable to be tested.. For reporting purposes only. **Warning*</p> <p>- From follow-up inspection 2022-05-24: Time extended **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
05-02-5	<p>Hearing-impaired smoke detector is not functioning/unable to be tested.. For reporting purposes only. **Warning**</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Lake County

License Number: 4500407

INN ON THE GREEN

License Type: Motel

700 E BURLEIGH BLVD, TAVARES 32778

Inspection Date: 05/23/2022

Inspection Number: 1218271

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

07-02-4

Frayed electrical wire(s). For reporting purposes only.

Exposed frayed wire in box above unmarked door behind lobby. Manager states not currently active.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lake County

License Number: 4503016

LAKE POINT SENIOR APTS LP

License Type: Apartment

1821 DORA AVE, TAVARES 32778

Inspection Date: 05/23/2022

Inspection Number: 1530322

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: COREY, DEREK

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room.
For reporting purposes only. **Corrected
On-Site**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4604205

THE MERIDIAN

License Type: Apartment

2825 CENTRAL AVE, FORT MYERS 33901

Inspection Date: 05/20/2022

Inspection Number: 1535411

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WALTER, KAYLA

Violation CodeObservationViolation Citation

01-02-4

Observed: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observer fire extinguisher in recharge zone on 3rd floor laundry room.
Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

Observed: Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only
Observed fire extinguisher as missing in 2nd floor Laundry room.
Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4703065

BAINBRIDGE PLACE

License Type: Apartment

2309 OLD BAINBRIDGE RD, TALLAHASSEE 32303

Inspection Date: 05/24/2022

Inspection Number: 1523610

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TRUESDALE, CHRIS

Violation CodeObservationViolation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only. Observed pathway to stairs blocked by futon behind unit 2102.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105024

WATERLINE MARINA RESORT AND BEACH CLUB

License Type: Hotel

5325 MARINA DR, HOLMES BEACH 34217

Inspection Date: 05/24/2022

Inspection Number: 1161104

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: PIPIC, DINKA

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Proof of insurance provided. - From follow-up inspection 2022-05-24: Operator currently has work on boiler. **Time Extend

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200343

VILLAGE SQUARE APARTMENTS

License Type: Apartment

1725 NE 36 AVE., OCALA 34470

Inspection Date: 05/25/2022

Inspection Number: 1514175

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Building 1715 between units 1-2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400611

BAYSIDE APTS

License Type: Apartment

98480 OVERSEAS HWY, KEY LARGO 33037

Inspection Date: 05/26/2022

Inspection Number: 1517106

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation Code

Observation

Violation Citation

07-02-4

Frayed electrical wire(s). For reporting purposes only.
Observed frayed wire under balcony in front of ur
8.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403067

HILTON GARDEN INN KEY WEST

License Type: Motel

3850 N ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 05/24/2022

Inspection Number: 1222810

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500078

TROPIC MOTEL

License Type: Motel

850427 US HWY 17, YULEE 32097

Inspection Date: 05/26/2022

Inspection Number: 1220819

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROZIER, TORRANCE

Violation Code

Observation

Violation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored out in front door . For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801524

CROWNE PLAZA DOWNTOWN ORLANDO

License Type: Hotel

304 W COLONIAL DR, ORLANDO 32801

Inspection Date: 05/23/2022

Inspection Number: 1164206

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ASSEFA, MARKIA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher located in the laundry room needs to be recharged

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811099

ROSEN SHINGLE CREEK

License Type: Hotel

9939 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 05/23/2022

Inspection Number: 1163105

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811161

HOMEWOOD SUITES ORLANDO CONVENTION CENTER SOUTH

License Type: Hotel

6940 WESTWOOD BLVD, ORLANDO 32821

Inspection Date: 05/23/2022

Inspection Number: 1161753

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed boiler to far left labeled for Laundry.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800160

KNIGHTS INN

License Type: Motel

5870 S ORANGE BLOSSOM TRL, ORLANDO 32839

Inspection Date: 05/24/2022

Inspection Number: 1221676

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PASIECKI, VICTORIA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to guest laundry

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5912070

GRAND HOTEL KISSIMMEE

License Type: Hotel

3104 PARKWAY BLVD, KISSIMMEE 34747

Inspection Date: 05/23/2022

Inspection Number: 1163883

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2022-05-23: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014043

HOMEWOOD SUITES BY HILTON

License Type: Hotel

4700 DONALD ROSS RD, PALM BEACH GARDENS 33418

Inspection Date: 05/26/2022

Inspection Number: 1162406

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: FRANCO, BROOKE

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fifth floor outside linen closet.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6102919

PIONEER BUILDING

License Type: Apartment

3104 TOWN AVE, NEW PORT RICHEY 34655

Inspection Date: 05/25/2022

Inspection Number: 1531509

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: AIELLO, ROCCI

Violation Code

Observation

Violation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

Observed fire extinguisher missing from enclosur by unit 202 - From follow-up i

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6204694

BLACK PEARL RESORT MOTEL

License Type: Motel

11160 E 1ST STREET, TREASURE ISLAND 33706

Inspection Date: 05/24/2022

Inspection Number: 1221675

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: DAY-WALKER, LISA

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only. Gate put up in upstairs walk balcony area blocking exit. Discussed with management and removed gate. ****Corrected On-Site****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6213380

TAHITIAN RESORT

License Type: Motel

11320 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 05/24/2022

Inspection Number: 1218410

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher near 123 in Recharge zone . ****Repeat Violation***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215781

WESTWINDS WATERFRONT RESORT LLC

License Type: Hotel

10265 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 05/24/2022

Inspection Number: 1163139

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in undercharge zone near office.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6204365

PAGE TERRACE

License Type: Motel

10500 GULF BLVD, TREASURE ISLAND 337064817

Inspection Date: 05/24/2022

Inspection Number: 1219919

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: DAY-WALKER, LISA

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Yellow trouble light illuminated on fire panel in the front desk area.
- From follow-up inspection 2022-05-24: **Time Extended*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215799

NICK PROPERTIES GROUP INC

License Type: Apartment

407 S MARS AVE, CLEARWATER 33755

Inspection Date: 05/24/2022

Inspection Number: 1521607

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing tool for break panel on first floor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215830

FRANK R CHIVAS

License Type: Apartment

309 S VENUS AVE, CLEARWATER 33755

Inspection Date: 05/24/2022

Inspection Number: 1528029

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Front area near apartment 4 ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6211998

MAGNOLIA APARTMENTS

License Type: Apartment

811 MAGNOLIA DR, CLEARWATER 33756

Inspection Date: 05/26/2022

Inspection Number: 1513511

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HEFFNER, CHRISTOPHER

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher between 809 1/2 B and 809 1/2 A.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6204653

ROSE MOTEL

License Type: Motel

332 HAMDEN DR, CLEARWATER 33767

Inspection Date: 05/23/2022

Inspection Number: 1221997

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Upstairs.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6309166

VALUE LODGE

License Type: Hotel

210 E FOWLER AVE, TAMPA 33612

Inspection Date: 05/26/2022

Inspection Number: 1164439

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: CESAR, RACHEL

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804840

THE FOUNTAINS AT LAKE POINTE WOODS

License Type: Apartment

3260 LAKE POINTE BLVD, SARASOTA 34231

Inspection Date: 05/27/2022

Inspection Number: 1534997

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CATTLEY, RAYMOND

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed system trouble 1 in main lobby and the 2nd in 1st floor Seville.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6801566

SOTO APARTMENTS

License Type: Apartment

4601 TRI PAR DR, SARASOTA 34234

Inspection Date: 05/25/2022

Inspection Number: 1535381

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: HELGESON, ERIC

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
Observed damaged wire outside unit 214.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only.
Observed damaged outlet outside unit 108.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900032

RAMADA

License Type: Motel

150 DOUGLAS AVE, ALTAMONTE SPRINGS 32714

Inspection Date: 05/27/2022

Inspection Number: 1222457

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTIN, LESLIE

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
-boiler certificate 094799 expired 4/16/2020.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6500060

PONTE VEDRA INN & CLUB

License Type: Hotel

200 PONTE VEDRA BLVD, PONTE VEDRA BEACH 32082

Inspection Date: 05/25/2022

Inspection Number: 1160262

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PERKINS, MARC

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
At entrance to laundry facility from loading dock, fire extinguisher in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501417

HOLIDAY INN ST AUGUSTINE-WORLD GOLF VILLAGE

License Type: Hotel

475 COMMERCE LAKE DR, SAINT AUGUSTINE 32095

Inspection Date: 05/26/2022

Inspection Number: 1164544

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: PERKINS, MARC

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
No boiler certification present in boiler room or available in establishment. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406444

HOLIDAY INN EXPRESS SPEEDWAY

License Type: Hotel

90 PROFESSIONAL BLVD, DAYTONA BEACH 32114

Inspection Date: 05/26/2022

Inspection Number: 1163960

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

02-04-4

3 generators store in storage on 3 floor with electrical panels. They appear to be new and manger states has no gas in them.For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406483

DAYTONA BEACH RESIDENCE INN

License Type: Hotel

1725 RICHARD PETTY BLVD, DAYTONA BEACH 32114

Inspection Date: 05/27/2022

Inspection Number: 1163919

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only.
 -Ground level stairway path partial block by chairs,south side of building.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406229

ANCHOR INN

License Type: Bed and Breakfast

312 WASHINGTON ST, NEW SMYRNA BEACH 32168

Inspection Date: 05/26/2022

Inspection Number: 1094723

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PICHARDO, RENEE

Violation Code

Observation

Violation Citation

12-04-4

High Priority - Staircase spindles loose/ nails
rusted at bottom. West side ****Warning****

61C-1.004(5) FAC High Priority: All building structural
components, attachments and fixtures shall be kept in
good repair.

Volusia County

License Number: 7406452

CORVETTE MOTEL

License Type: Motel

565 S ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 05/24/2022

Inspection Number: 1220808

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit
15. For reporting purposes only.

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406522

OM HOSPITALITY OF DELTONA LLC

License Type: Motel

481 DELTONA BLVD, DELTONA 32725

Inspection Date: 05/23/2022

Inspection Number: 1221691

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm
control panel. For reporting purposes only.509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State
Fire Marshal of any readily observable violation of a
rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.