

**Alachua County**

License Number: 1101306

HICKORY HILLS ADDITION

License Type: Apartment

4027 SW 17 LN, GAINESVILLE 326074099

Inspection Date: 06/03/2022

Inspection Number: 1513190

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

06-01-4

Path to exit from the balcony impeded. For reporting purposes only.

Observed in front of G and H, an electric chair and a rolling chair are stored on the walkway.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Alachua County**

License Number: 1100727

ECONO LODGE

License Type: Motel

2649 SW 13 ST, GAINESVILLE 32608

Inspection Date: 05/31/2022

Inspection Number: 1218644

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: TORRES, WILLIAM

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.

Observed smoke detector in guest room 120 did not alarm when tested and it is covered with a plastic cloth. Smoke detector in guest room 128 alarm is barely audible and it appears that it may have had a short due to black scorch mark above smoke detector.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only.

Observed loose electrical outlet face plate under headboard guest room 120

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Baker County**

License Number: 1200123

TRAVELODGE

License Type: Motel

1651 S 6TH STREET, MACCLENNY 32063

Inspection Date: 06/01/2022

Inspection Number: 1222833

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: BADDING, MELANIE

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher by unit 227 in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1500372

TRAVEL INN OF TITUSVILLE

License Type: Motel

7503 S US HWY 1, TITUSVILLE 32780

Inspection Date: 06/02/2022

Inspection Number: 1221110

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: FRANZ, LINDA

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.  
For reporting purposes only. Light does not flash during testing.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1505793

BEACHWOOD APARTMENTS

License Type: Apartment

637 S ORLANDO AVE, COCOA BEACH 32931

Inspection Date: 06/03/2022

Inspection Number: 1521995

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: HICKS, GEORGE RANDY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Across from washer and dryer.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1607149

TREASURE VILLA APARTMENT

License Type: Apartment

823 NE 5 ST, HALLANDALE 33009-3569

Inspection Date: 06/02/2022

Inspection Number: 1518815

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: GANPAT, INDAR

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Second floor between units 3&5 \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1604765

EMMANUEL APARTMENTS

License Type: Apartment

6131 SW 35 CT, MIRAMAR 33023-5163

Inspection Date: 06/01/2022

Inspection Number: 1530524

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: GANPAT, INDAR

Violation Code

Observation

Violation Citation

06-02-4

Windows east of property blocked with plywood.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1606519

413 APARTMENTS

License Type: Apartment

413 N 62 AVE, HOLLYWOOD 33024-7849

Inspection Date: 06/03/2022

Inspection Number: 1528150

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKINNEY, JOHN

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
 Located on the second floor between units 202 and 203

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Broward County**

License Number: 1620848

HILTON FT LAUDERDALE BEACH RESORT

License Type: Hotel

505 N FT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 06/01/2022

Inspection Number: 1164573

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Inspection report will be emailed to Fire Marshall for review.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1615393

TEQUESTA SQUARE

License Type: Apartment

835 SW 4 ST, FORT LAUDERDALE 33312-7801

Inspection Date: 06/02/2022

Inspection Number: 1516319

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Extinguisher between 7nits 2 & 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2101115

INN OF NAPLES

License Type: Hotel

4055 TAMIAMI TRAIL N, NAPLES 34103

Inspection Date: 06/03/2022

Inspection Number: 1164566

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired  
07/18/20. For reporting purposes only.61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report  
is required annually for power boilers and high  
pressure/high temperature boilers and biannually for  
low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the  
local firesafety authority or the State Fire Marshal of  
any readily observable violation of a rule adopted under  
chapter 633 which relates to public lodging  
establishments or public food establishments, and the  
identification of such violation does not require any  
firesafety inspection certification. For reporting  
purposes only.

**Collier County**

License Number: 2102706

HOME2 SUITES BY HILTON NAPLES I-75 PINE RIDGE RD

License Type: Hotel

3685 KRAMER DR, NAPLES 34109

Inspection Date: 06/03/2022

Inspection Number: 1162334

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available  
Operator working with State Fire Marshal to get resolved. For reporting purposes only. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2102440

WHISTLER'S GREEN APARTMENTS

License Type: Apartment

4700 WHISTLERS GREEN CIR, NAPLES 34116

Inspection Date: 05/31/2022

Inspection Number: 1519386

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2306402

SAN JORGE APARTMENTS

License Type: Apartment

3601 W 12 AVE, HIALEAH 33012

Inspection Date: 06/03/2022

Inspection Number: 1531950

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MARTINEZ, YANET

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located by unit 13.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2313789 1559-60 NW 15 ST RD LLC

License Type: Apartment 1560 NW 15 ST RD, MIAMI 33125

Inspection Date: 06/03/2022

Inspection Number: 1516791

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: SAENZ, HILDA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartments #15 and apartment #14, and also between apartment #10 & # 11.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2300370

WEST DADE LTD II

License Type: Apartment

2330 NW 9 ST, MIAMI 331253200

Inspection Date: 05/27/2022

Inspection Number: 1535491

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2310080

DEVILLA APARTMENTS

License Type: Apartment

1874 NW FLAGLER TERR, MIAMI 331255423

Inspection Date: 05/31/2022

Inspection Number: 1520532

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguisher with no braking device located by unit 1. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

## FIRE CODE VIOLATIONS OBSERVED IN PUBLIC LODGING ESTABLISHMENTS - WEEK ENDING 6/4/2022

[www.MyFloridaLicense.com/dbpr/hr/](http://www.MyFloridaLicense.com/dbpr/hr/)**Dade County**

License Number: 2319491

851 NW 1 ST

License Type: Apartment

851 NW 1 ST, MIAMI 331281340

Inspection Date: 05/31/2022

Inspection Number: 1518241

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MASKASEM, SUPPACHAI

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purpose only. Observed fire extinguisher missing from it's designated location by the laundry area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2308941

HIGHLAND PARK APARTMENTS

License Type: Apartment

1545 NW 8 AVE, MIAMI 33136

Inspection Date: 05/31/2022

Inspection Number: 1513781

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By apartment 108.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330824

PCR 1020 NW 7 AVE

License Type: Apartment

1020 NW 7 AVE, MIAMI 33136

Inspection Date: 05/31/2022

Inspection Number: 1535474

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: HENLEY, LATONYA

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Building 701, by unit 102 and building 109 by unit 102.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329398

VILLA PATRICIA II LLC

License Type: Apartment

7835 NE 2 AVE, MIAMI 33138

Inspection Date: 05/31/2022

Inspection Number: 1516291

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: LODENQUAI, BARRINGTON

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329189

RIVIERA HOTEL APARTMENTS

License Type: Hotel

2000 LIBERTY AVE, MIAMI BEACH 33139

Inspection Date: 06/03/2022

Inspection Number: 1164525

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CURRAS, YANLEE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2305153

SIERRAS #1 CORPORATION

License Type: Apartment

7124 BAY DR, MIAMI BEACH 33141

Inspection Date: 06/01/2022

Inspection Number: 1535525

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PRIETO, VICENTE

Violation Code

Observation

Violation Citation

01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device in fire extinguisher box by units 2 and 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device for fire extinguisher boxes by units 2 and 5. - From follow-up inspection 2022-06-01: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2314953

CITY BAY DRIVE

License Type: Apartment

2011 BAY DR, MIAMI BEACH 33141

Inspection Date: 06/02/2022

Inspection Number: 1501473

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at the main entrance. - From follow-up inspection 2022-06-02: Observed trouble alarm lights illuminated.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at the building entrance.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2303416

PRIMUS PALACE

License Type: Apartment

2295 NW 46 STREET, MIAMI 33142

Inspection Date: 05/31/2022

Inspection Number: 1520779

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: BROWN, JARON

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.  
Observed fire extinguisher next to unit 6 missing breakage device.  
Observed fire extinguisher next to unit 17 missing breakage device  
Observed fire extinguisher next to unit 24 missing breakage device

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2317917

GONZALEZ, PEDRO

License Type: Apartment

2611 NW 32 ST, MIAMI 33142

Inspection Date: 05/31/2022

Inspection Number: 1515287

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only.  
Observed 20lb propane tank under stairway across from unit 2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329415

VILLAGE ALLAPATTAH PI LLC

License Type: Apartment

2370 NW 17 AVE, MIAMI 33142

Inspection Date: 06/02/2022

Inspection Number: 1521040

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: BROWN, JARON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330500

THREE ROUND TOWER A LLC

License Type: Apartment

2870 NW 18 AVE, MIAMI 33142

Inspection Date: 06/01/2022

Inspection Number: 1529480

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2311072

BISCAYNE TOWERS

License Type: Apartment

11750 NE 16 AVE, MIAMI 33161

Inspection Date: 06/03/2022

Inspection Number: 1516586

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SUAREZ, LEOPOLDO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2311562

PRESTIGE CORNERSTONE

License Type: Apartment

12300 NE 4 AVE, NORTH MIAMI 33161

Inspection Date: 05/31/2022

Inspection Number: 1520110

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SUAREZ, LEOPOLDO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2303874

GRAND ISLAND PORTFOLIO LLC

License Type: Apartment

1495 NE 167 ST, NORTH MIAMI BEACH 33162

**Dade County**

Inspection Date: 05/26/2022

Inspection Number: 1535404

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: VILCHEZ, NABEL

Violation CodeObservationViolation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it' designated location (sign present indicating designated location). For reporting purposes only. At building 300 located on first and second floor. - From follow-up inspection 2022-05-26: At the time of callback inspection Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. At building 300 located on first and second floor. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-05-4

- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Next to apt #104. - From follow-up inspection 2022-05-26: At the time of callback inspection Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Next to apt #104. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

04-05-4

- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Apartment #306 - From follow-up inspection 2022-05-26: At the time of callback inspection no smoke detector provided in guest room/unit. For reporting purposes only. Apartment #306. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2324350

SUN POINT RENTALS

License Type: Apartment

11180 SW 107 ST, MIAMI 331768269

Inspection Date: 06/03/2022

Inspection Number: 1527561

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

01-05-4

- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Fire extinguisher located by unit 305 and unit 109 in building 11180. Fire extinguisher locate by unit 102 in building 11190. - From follow-up inspection 2022-05-18: Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Fire extinguisher located by unit 305 and unit 109 in building 11180. Fire extinguisher located by unit 10 in building 11190. \*\*Time Extended\*\* - From follow-up inspection 2022-06-03: Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Fire extinguisher located by unit 305 and unit 109 in building 11180. Fire extinguisher located by unit 10 in building 11190. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2601335

TWIN PALMS APARTMENTS

License Type: Apartment

1317 EASTER ST, JACKSONVILLE 32211

Inspection Date: 06/03/2022

Inspection Number: 1531887

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher between units 6 and 7 on 1311 building is in recharge zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613416

THE SOLERA AT KENDALL WEST

License Type: Apartment

1462 SOLERA TER, JACKSONVILLE 32211

Inspection Date: 06/02/2022

Inspection Number: 1520077

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: THOMAS, PHILIP

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher located between double garage doors on maintenance shed behind pickleball court has gauge in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2608324

RED ROOF INN

License Type: Motel

1063 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 06/04/2022

Inspection Number: 1222860

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
Boiler certification expired 09/20/2021. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613261

SAVANNAH SPRINGS APARTMENTS

License Type: Apartment

6945 MORSE AVE, JACKSONVILLE 32244

Inspection Date: 06/01/2022

Inspection Number: 1513834

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

03-05-4

Fire sprinkler head painted. For reporting purposes only.  
In bedroom closet in unit 821.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hardee County**

License Number: 3500217

BEST WESTERN HERITAGE INN &amp; SUITES

License Type: Hotel

2727 US HWY 17 N, BOWLING GREEN 33834

Inspection Date: 06/02/2022

Inspection Number: 1163221

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CATTLEY, RAYMOND

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble in panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3904247

COUNTRYWOOD APTS

License Type: Apartment

12401 ORANGE GROVE DR, TAMPA 336183400

Inspection Date: 05/27/2022

Inspection Number: 1515114

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKINNEY, JOHN

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.  
Possibly in units but no central alarm system observed and no accessible fire extinguishers were observed anywhere on the property.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Hillsborough County**

License Number: 3912329

HILTON GARDEN INN TAMPA NORTH

License Type: Hotel

13305 TAMPA OAKS BLVD, TEMPLE TERRACE 33637

Inspection Date: 06/01/2022

Inspection Number: 1163182

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: REGAS, ANTHONY

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed the boiler certificate expired 3-17-22, Jurisdiction 12450. - From follow-up inspection 2022-06-01: Observed the boiler certificate no renewed. \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Indian River County**

License Number: 4100202

HOLIDAY INN OCEANSIDE

License Type: Motel

3384 OCEAN DR, VERO BEACH 32963

Inspection Date: 05/31/2022

Inspection Number: 1222824

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation CodeObservationViolation Citation

08-06-4

Combustibles stored in hot water room. For reporting purposes  
only. Rolls of carpet

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Leon County**

License Number: 4700547

SUNRISE PLACE APARTMENTS

License Type: Apartment

2525 TEXAS ST, TALLAHASSEE 32301

Inspection Date: 06/02/2022

Inspection Number: 1526290

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: TRUESDALE, CHRIS

Violation CodeObservationViolation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only. Stairway blocked by discarded car parts and baby seat in front of unit H130.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Leon County**

License Number: 4703226

MILLSTREAM AT CASCADES

License Type: Apartment

850 S GADSDEN ST, TALLAHASSEE 32301

Inspection Date: 06/02/2022

Inspection Number: 1535257

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: TRUESDALE, CHRIS

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher on 8th floor pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Leon County**

License Number: 4702903

MARY'S DRIVE APTS

License Type: Apartment

912 MARYS DR, TALLAHASSEE 32308

Inspection Date: 06/03/2022

Inspection Number: 1513441

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Between 912 C and I

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5400040

SUNSET CITY LESSEE

License Type: Motel

508 SOUTH ST, KEY WEST 33040

Inspection Date: 06/01/2022

Inspection Number: 1221519

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire Alarm inside the door marked Fire alarm by the conference room. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5402759

COURTYARD BY MARRIOTT

License Type: Hotel

3031 N ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 06/01/2022

Inspection Number: 1162459

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: MARTINEZ, YANET

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-06-01: At the time of the callback inspection observed troublemaker light on the fire alarm control panel. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811148

RESIDENCE INN BY MARRIOTT ORLANDO DOWNTOWN

License Type: Hotel

680 N ORANGE AVE, ORLANDO 32801

Inspection Date: 06/02/2022

Inspection Number: 1162932

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONTGOMERY, DOREEN

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Orange County**

License Number: 5811313

BALDWIN HARBOR APARTMENTS

License Type: Apartment

1915 LAKEMONT AVE, ORLANDO 32814

Inspection Date: 06/02/2022

Inspection Number: 1521974

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: VAUGHAN, COURTNEY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
 Trouble light in FACP room, operator has already called fire service tech for it. \*\*Corrective Action Taken\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

---

License Number: 5808632

EXTENDED STAY AMERICA #174

License Type: Hotel

6451 WESTWOOD BLVD, ORLANDO 32821

**Orange County**

Inspection Date: 05/31/2022

Inspection Number: 1162120

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811256

CITILAKES

License Type: Apartment

12024 MEADOWBEND LOOP, ORLANDO 32821

Inspection Date: 06/03/2022

Inspection Number: 1523997

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5804136

MARRIOTT'S ORLANDO WORLD CENT

License Type: Hotel

8701 WORLD CENTER DR, ORLANDO 328216358

Inspection Date: 05/31/2022

Inspection Number: 1162840

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5900724

ONE WAY MAINGATE HOTEL

License Type: Motel

2930 POLYNESIAN ISLE BLVD, KISSIMMEE 34746

Inspection Date: 06/03/2022

Inspection Number: 1219725

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-06-03: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5911043

BEST WESTERN PLUS INN & SUITES

License Type: Hotel

3484 POLYNESIAN ISLE BLVD, KISSIMMEE 34746

Inspection Date: 06/03/2022

Inspection Number: 1162626

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-06-03: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014044

HAWTHORN SUITES WEST PALM BEACH

License Type: Hotel

301 LAMBERTON DR, WEST PALM BEACH 33401

Inspection Date: 05/31/2022

Inspection Number: 1163181

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: FRANCO, BROOKE

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2022-04-29: \*\*Time Extended\*\* - From follow-up inspection 2022-05-31: Inspector will not inspect boiler until part comes in. \*\*Time Extended\*\* \*\*Corrective Action Taken'

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Pinellas County**

License Number: 6203283

PALMS MOTEL

License Type: Motel

6730 N 4 ST, ST PETERSBURG 337026898

Inspection Date: 06/03/2022

Inspection Number: 1221765

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.  
For reporting purposes only.  
Unable to test hearing impaired smoke alarm since it has to be  
connected to other smoke alarm.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6203151

VISTA DEL MAR APTS

License Type: Apartment

449 129 AVE. E, MADEIRA BCH 337082696

Inspection Date: 06/01/2022

Inspection Number: 1515452

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HEFFNER, CHRISTOPHER

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.  
Outside of unit 16.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6201179

LENNOX COURT

License Type: Apartment

2035 KINGS HWY, CLEARWATER 33755

Inspection Date: 05/31/2022

Inspection Number: 1528171

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PEARCE, LAURA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No tool provided for Break panel at fire extinguisher boxes near apartment 75, 84, fire extinguishers on second floor of east building and some at the west side building

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6205421

SUPER 8 MOTEL

License Type: Motel

22950 HWY 19 N, CLEARWATER 33765

Inspection Date: 06/01/2022

Inspection Number: 1222568

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: PEARCE, LAURA

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel in closed in front desk area . For reporting purposes only. - From follow-up inspection 2022-06-01: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6215803

OPAL SANDS RESORT

License Type: Hotel

430 S GULFVIEW BLVD, CLEARWATER 33767

Inspection Date: 06/02/2022

Inspection Number: 1161935

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6201872

BREEZY PALMS APARTMENTS

License Type: Apartment

1500 W BAY DR, LARGO 33770

Inspection Date: 05/31/2022

Inspection Number: 1522032

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HEFFNER, CHRISTOPHER

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher by mailboxes outside of Unit 113.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6216143

THE ROSERY LARGO APARTMENTS

License Type: Apartment

811 ROSERY RD NW, LARGO 33770

Inspection Date: 06/01/2022

Inspection Number: 1517760

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MAJEWSKI, JEREMY

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. In building 811 with the office located inside, located on bottom floor just before the stairway to the second floor next to unit 1116.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Putnam County**

License Number: 6400334

FOREST GLEN I

License Type: Apartment

700 FOREST GLEN DR, PALATKA 321779316

Inspection Date: 05/31/2022

Inspection Number: 1518391

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.  
Observed fire extinguisher by unit 20 in locked box with no hamme

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Putnam County**

License Number: 6400785

ANDERSEN'S LODGE AND ANDERSEN'S BAR & GRILL

License Type: Motel

10 BOSTON ST, WELAKA 32193

Inspection Date: 06/02/2022

Inspection Number: 1222580

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher by room 15 on side deck. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6804704

HOLIDAY INN EXPRESS & SUITES SARASOTA EAST/I-75

License Type: Hotel

5730 GANTT RD, SARASOTA 34233

Inspection Date: 05/31/2022

Inspection Number: 1163291

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: CATTLEY, RAYMOND

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed trouble light on main panel. - From follow-up inspection 2022-04-01: \*\*Time Extended\*\* - From follow-up inspection 2022-05-31: Observed trouble light on main fire system. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6801281

HYATT REGENCY SARASOTA

License Type: Hotel

1000 BLVD OF THE ARTS, SARASOTA 34236

Inspection Date: 05/31/2022

Inspection Number: 1164540

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6800007

ROSE HILL APARTMENTS

License Type: Apartment

512 ARMADA RD, VENICE 34285

Inspection Date: 06/03/2022

Inspection Number: 1524753

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KEATING, PATRICK

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observed outlet outside back door of building 512 damaged and hanging by loose wires.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6903728

OVIEDO GROVE APTS

License Type: Apartment

1600 OVIEDO GROVE CIR, OVIEDO 32765

Inspection Date: 06/03/2022

Inspection Number: 1518414

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: GUTTERMAN, KENNETH

Violation Code

Observation

Violation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6902421

REGATTA SHORES APTS

License Type: Apartment

2335 W SEMINOLE BLVD, SANFORD 327717930

Inspection Date: 06/02/2022

Inspection Number: 1523047

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Notified Dan Taylor, Sanford Fire Inspector. 407-562-2788.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6901132

GEORGIA ARMS APARTMENTS

License Type: Apartment

2600 GEORGIA AVE, SANFORD 32773

Inspection Date: 06/02/2022

Inspection Number: 1528931

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No means to break the glass at 1304 & 1502& 1506, 1602, 1102

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Johns County**

License Number: 6501640

RESERVE AT NOCATEE

License Type: Apartment

215 HUNTERS LAKE WAY, PONTE VEDRA 32081

Inspection Date: 05/31/2022

Inspection Number: 1520103

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PERKINS, MARC

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Building 2 by the storage room S21, fire extinguisher in case in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**St. Johns County**

License Number: 6500269

SCOTTISH INNS

License Type: Motel

2580 SR 16, ST AUGUSTINE 32092

Inspection Date: 06/03/2022

Inspection Number: 1222747

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: PERKINS, MARC

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. In upstairs storage room with water heater, propane tank and red gas stank stored on the floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Lucie County**

License Number: 6602529

LIVE OAK VILLAS II APARTMENTS

License Type: Apartment

919 S 25 ST, FORT PIERCE 34947

Inspection Date: 06/02/2022

Inspection Number: 1535242

Inspection Type: Lodging-Licensing  
Inspection

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Building 2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406519

HAWAIIAN INN BEACH RESORT

License Type: Hotel

2301 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 06/03/2022

Inspection Number: 1164585

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only.

-laundry room, rear door

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406653

ENCLAVE AT 3230

License Type: Apartment

3230 S RIDGEWOOD AVE, SOUTH DAYTONA 32119

Inspection Date: 06/02/2022

Inspection Number: 1527176

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: COREY, DEREK

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
-panel states ALARM HISTORY: 0107, 0138, and 0206.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7400051

DAYS INN SPEEDWAY

License Type: Motel

2904 W INTL SPEEDWAY BLVD, DAYTONA BEACH 32124

Inspection Date: 05/31/2022

Inspection Number: 1222837

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: COREY, DEREK

Violation Code

Observation

Violation Citation

02-04-4

Gasoline can with gasoline and wood stored in storage area that has two water heaters. Operator removed gasoline can. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7405077

ALOHA MOTEL APTS

License Type: Motel

6700 TURTLE MOUND RD, NEW SMYRNA BCH 321694919

Inspection Date: 06/03/2022

Inspection Number: 1222071

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PICHARDO, RENEE

Violation Code

Observation

Violation Citation

12-04-4

High Priority - Walkway on second floor exterior wood rotted. east side near sliding glass door. **\*\*Warning\*\***

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.