

Bay County

License Number: 1300014

MY PLACE APARTMENTS

License Type: Apartment

801 W 13 ST, PANAMA CITY 32401

Inspection Date: 06/09/2022

Inspection Number: 1515286

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Outside unit 61.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside unit 1

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1606634

SUNSHINE APARTMENTS

License Type: Apartment

6840 PEMBROKE RD, PEMBROKE PINES 33023

Inspection Date: 06/08/2022

Inspection Number: 1515166

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: GANPAT, INDAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Opposite unit 212

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1605690

WILTON HOUSE APARTMENTS

License Type: Apartment

2727 N ANDREWS AVE, WILTON MANORS 33311

Inspection Date: 06/10/2022

Inspection Number: 1535462

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: AHLE, ROBERT

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. On at house j between 139 and 138

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1605149

NOVA ARMS APTS

License Type: Apartment

6150 SW 37 ST, DAVIE 33314-2573

Inspection Date: 06/06/2022

Inspection Number: 1518819

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher on south side at east end of building is in undercharged zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620976

216 SW 19TH ST

License Type: Apartment

216 SW 19 ST, FORT LAUDERDALE 33315

Inspection Date: 06/08/2022

Inspection Number: 1535583

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: GONZALEZ, DENNIS

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2000700

BRIARWOOD APARTMENTS

License Type: Apartment

4328 BRIARWOOD FLAT TRACE, MIDDLEBURG 32068

Inspection Date: 06/09/2022

Inspection Number: 1531994

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BADDING, MELANIE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
No hammer at fire extinguisher in laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102299

BEST WESTERN HOTEL & SUITES

License Type: Motel

6400 DUDLEY DR, NAPLES 34105

Inspection Date: 06/07/2022

Inspection Number: 1219848

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DOMKOWSKI, DANIEL

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certification and expiration date: 133059 12/13/2021, 133060 12/13/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2102368

PALMDALE APTS

License Type: Apartment

2884 PINE ST, NAPLES 34112

Inspection Date: 06/10/2022

Inspection Number: 1527440

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRAVES, PETER

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. There is no fire extinguisher on building 2281, 2282 This is a repeat violation from 4/14/2021, 6/25/2020. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. There is no-device to access the fire extinguisher in front of apartment 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2311337 11714
 License Type: Apartment 1636 NW 2 ST, MIAMI 33125

Inspection Date: 05/24/2022 Inspection Number: 1517145 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: SAENZ, HILDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at the fire extinguisher located between the meter room and apartment #2. Also the fire extinguisher located second floor b	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327152

ASPR CORPORATION

License Type: Apartment

1850 NW 22 CT, MIAMI 33125

Inspection Date: 06/09/2022

Inspection Number: 1515005

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SAENZ, HILDA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to mailboxes.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327589 ALOSO GOMEZ PROPERTIES I

License Type: Apartment 1371 NW 3 ST, MIAMI 33125

Inspection Date: 06/02/2022

Inspection Number: 1527912

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SAENZ, HILDA

Violation CodeObservationViolation Citation

01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed at fire extinguisher located on the stairs to the second floor east side.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed on stairs to the second level west side and also in front of apartment # 5 and # 10.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328340

1559 APT LLC

License Type: Apartment

1559 NW 15 ST RD, MIAMI 33125

Inspection Date: 06/08/2022

Inspection Number: 1535673

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartment 14 & 15 and 10 & 11.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300370

WEST DADE LTD II

License Type: Apartment

2330 NW 9 ST, MIAMI 331253200

Inspection Date: 04/26/2022

Inspection Number: 1535621

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2325791

COURTYARD MIAMI AIRPORT

License Type: Hotel

1201 NW 42 AVE, MIAMI 33126

Inspection Date: 06/10/2022

Inspection Number: 1164421

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTINEZ, YANET

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate expired since October, 2021 **Repeat Violation**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329205

RESIDENCE INN BY MARRIOTT MIAMI AIRPORT SOUTH

License Type: Hotel

1201 NW LEJEUNE RD, MIAMI 33126

Inspection Date: 06/10/2022

Inspection Number: 1164420

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTINEZ, YANET

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate expired since October, 2021.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310567

737 APARTMENTS

License Type: Apartment

737 NW 1 ST, MIAMI 33128

Inspection Date: 06/10/2022

Inspection Number: 1517155

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apartment #5 on second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324074

QUARTZ BALL LLC

License Type: Apartment

817 NW 2 ST, MIAMI 33128

Inspection Date: 06/10/2022

Inspection Number: 1526809

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed near to apartment #4 on second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329697

TRIPOLIS CORPORATION

License Type: Apartment

863 NW 3RD ST, MIAMI 33128

Inspection Date: 06/10/2022

Inspection Number: 1519368

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apartment #4 on second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329866

JACK ORR PLAZA

License Type: Apartment

550 NW 5 ST, MIAMI 33128

Inspection Date: 06/09/2022

Inspection Number: 1524040

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available
For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300031

AVAV HOLDINGS LLC

License Type: Apartment

920 SW 5 ST, MIAMI 33130

Inspection Date: 06/06/2022

Inspection Number: 1530789

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300223

GRUPO HABITA 929 LLC

License Type: Apartment

929 SW 5 ST, MIAMI 33130

Inspection Date: 06/06/2022

Inspection Number: 1521541

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2307660

YURIANI INVESTMENTS LLC

License Type: Apartment

835 SW 7 ST, MIAMI 33130

Inspection Date: 06/08/2022

Inspection Number: 1516357

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Next to unit 2 and 9.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329462

RUDG MBCDC I LLC

License Type: Apartment

126 SW 8 AVE, MIAMI 33130

Inspection Date: 06/08/2022

Inspection Number: 1529343

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329875

BRISAS DEL MAR APARTMENTS

License Type: Apartment

556 WEST FLAGLER STREET, MIAMI 33130

Inspection Date: 06/09/2022

Inspection Number: 1514510

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SANCHEZ, JAVIER

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Corrected On-Site****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329925

SOMA AT BRICKELL

License Type: Apartment

145 SW 13 ST, MIAMI 33130

Inspection Date: 06/08/2022

Inspection Number: 1529227

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2301253

BRADFORD APTS

License Type: Apartment

1868 SW 4 ST, MIAMI 331353419

Inspection Date: 06/06/2022

Inspection Number: 1522721

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SANCHEZ, JAVIER

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2318853

APARTAMENTOS EL COLONIAL

License Type: Apartment

1534 SW 5 ST, MIAMI 331353735

Inspection Date: 06/09/2022

Inspection Number: 1525148

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. 1 st floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2319477

ROYAL APARTMENTS

License Type: Apartment

2760 SW 10 TERR, MIAMI 331354649

Inspection Date: 06/08/2022

Inspection Number: 1527541

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device for extinguisher located next to unit 1 and for the one on the second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303972

VG RE OVERTOWN 613

License Type: Apartment

123 - 133 NW 18 ST, MIAMI 33136

Inspection Date: 06/09/2022

Inspection Number: 1517268

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Building 123, first floor. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329197

TUSCAN VIEW APARTMENTS

License Type: Apartment

670 NW 6 ST, MIAMI 33136

Inspection Date: 06/08/2022

Inspection Number: 1525536

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. First floor, by the elevators.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330089

ESTHER ENTERPRISES

License Type: Apartment

365 NW 8 ST, MIAMI 33136

Inspection Date: 06/09/2022

Inspection Number: 1526512

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed by apartment 105.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309513

SANFORD APARTMENTS

License Type: Apartment

1907 NW 2 CT, MIAMI 331361333

Inspection Date: 06/07/2022

Inspection Number: 1527505

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By apartments 10 and 12.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329429

PINNACLE PLACE LTD

License Type: Apartment

5600 NE 4 AVE, MIAMI 33137

Inspection Date: 06/06/2022

Inspection Number: 1516242

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed in the main fire panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326548

BELLE MEADE STUDIOS LLC

License Type: Apartment

7623 BISCAYNE BLVD, MIAMI 33138

Inspection Date: 06/10/2022

Inspection Number: 1520982

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: SEYBA, JAMES

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328865

TDK REAL ESTATE LLC

License Type: Bed and Breakfast

1545 MERIDIAN AVE, MIAMI BEACH 33139

Inspection Date: 06/09/2022

Inspection Number: 1094457

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329295

BOULAN HOTEL

License Type: Hotel

220 21 ST, MIAMI BEACH 33139

Inspection Date: 06/07/2022

Inspection Number: 1164078

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CURRAS, YANLEE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308057

GRANEK APTS

License Type: Apartment

750 LENOX AVE, MIAMI BEACH 331395938

Inspection Date: 06/07/2022

Inspection Number: 1513227

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Located near unit 5. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310433

MARINA DEL REY APTS

License Type: Apartment

1006 BAY DR, MIAMI BEACH 331413708

Inspection Date: 06/09/2022

Inspection Number: 1520422

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PRIETO, VICENTE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking devices for ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302045

7717-25 BYRON AVE APTS

License Type: Apartment

7717 BYRON AVE, MIAMI BEACH 331416103

Inspection Date: 06/09/2022

Inspection Number: 1515732

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302435

MADRUGA INVESTMENT INC

License Type: Apartment

3121 NW 22 AVE, MIAMI 33142

Inspection Date: 06/10/2022

Inspection Number: 1522022

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apartments 3 and 11.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329416

VILLAGE ALLAPATTAH PII LLC

License Type: Apartment

2378 NW 17 AVE, MIAMI 33142

Inspection Date: 06/09/2022

Inspection Number: 1530426

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329799

COLLINS PARK APARTMENTS LLC

License Type: Apartment

3625 NW 20 AVE, MIAMI 33142

Inspection Date: 06/09/2022

Inspection Number: 1519273

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed und the building in the parking area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329849

DANTE FASCELL PRESERVATION LLC

License Type: Apartment

2929 NW 18 AVE, MIAMI 33142

Inspection Date: 06/08/2022

Inspection Number: 1524028

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330279

MOTION AT DADELAND

License Type: Apartment

8400 S DIXIE HWY, MIAMI 33143

Inspection Date: 06/10/2022

Inspection Number: 1535635

Inspection Type: Lodging-Licensing

Inspection Disposition: Warning

Inspector Name: PICO, JORGE

Inspection

Issued

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2307426

BAYSIDE APARTMENTS

License Type: Apartment

1085 94 ST, BAY HARBOR ISLANDS 33154

Inspection Date: 06/06/2022

Inspection Number: 1513798

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting
purposes only. Located behind Apts 9401 & 9405.509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to
public lodging establishments or public food
establishments, and the identification of such violation
does not require any firesafety inspection certification.
For reporting purposes only.

Dade County

License Number: 2308294

CASA BONITA

License Type: Apartment

390 NE 125 ST, MIAMI 33161

Inspection Date: 06/06/2022

Inspection Number: 1527825

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SUAREZ, LEOPOLDO

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By apt 404.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303874

GRAND ISLAND PORTFOLIO LLC

License Type: Apartment

1495 NE 167 ST, NORTH MIAMI BEACH 33162

Dade County

Inspection Date: 06/06/2022

Inspection Number: 1535404

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: VILCHEZ, NABEL

Violation CodeObservationViolation Citation

01-03-4	<p>- From initial inspection : Portable fire extinguisher missing from it' designated location (sign present indicating designated location). For reporting purposes only. At building 300 located on first and second floor. - From follow-up inspection 20</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
01-05-4	<p>- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Next to apt #104. - From follow-up inspection 2022-05-26: At the time of callback inspection Portable fire extinguisher obstructed/not acce</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Dade County

04-05-4	- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Apartment #306 - From follow-up inspection 2022-05-26: At the time of callback inspection no smoke detector provided in guest room/unit. For rep	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

License Number: 2330833	BISCAYNE 112 APARTMENTS	
License Type: Apartment	11200 BISCAYNE BLVD, NORTH MIAMI	33181
Inspection Date: 06/09/2022	Inspection Number: 1535656	Inspection Type: Lodging-Licensing
Inspector Name: SUAREZ, LEOPOLDO		Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613368

ALDERMAN

License Type: Apartment

1217 UNDERHILL DR, JACKSONVILLE 32211

Inspection Date: 06/06/2022

Inspection Number: 1519574

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
First extinguisher in red box under car port covered area and stairway is in recharge zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2608324

RED ROOF INN

License Type: Motel

1063 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 06/04/2022

Inspection Number: 1222860

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Boiler certification expired 09/20/2021. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613193

FAIRFIELD INN & SUITES

License Type: Hotel

1616 1 ST N, JACKSONVILLE BEACH 32250

Inspection Date: 06/07/2022

Inspection Number: 1162280

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Two active boilers with expired posted certificates in boiler room but current certificate on Boilers website shows current with info
Jurisdiction 098188 exp

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hendry County

License Number: 3600024

RELAX INN

License Type: Motel

820 E SUGARLAND HWY, CLEWISTON 33440

Inspection Date: 06/09/2022

Inspection Number: 1222572

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Extinguisher between units 107 & 108 in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900701

PALM VIEW APARTMENTS

License Type: Apartment

115 N HUBERT, TAMPA 336092129

Inspection Date: 06/06/2022

Inspection Number: 1527589

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to apt 1

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3905450

ECONOMY INN

License Type: Motel

1810 E BUSCH BLVD, TAMPA 336128664

Inspection Date: 06/06/2022

Inspection Number: 1217803

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CESAR, RACHEL

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.
For reporting purposes only. Hearing impaired detector is not
flashing while being tested. ****Warning****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3906758

THE DAWSON

License Type: Apartment

15501 BRUCE B DOWNS BLVD, TAMPA 33647

Inspection Date: 06/06/2022

Inspection Number: 1534875

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: POWELL, DAVID

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher dials displaying recharge on several buildings - From follow-up inspectio

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

- From initial inspection : Portable fire extinguisher missing from it' designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguishers missing from several buildings - From follow-up inspe

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605574

MAPLE CREST APARTMENTS

License Type: Apartment

3607 CRESTWOOD LAKE AVE, FORT MYERS 33901

Inspection Date: 06/09/2022

Inspection Number: 1514135

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher near Units 306 and 308, Building 5.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4600257

OUTRIGGER BCH RESORT

License Type: Motel

6200 ESTERO BLVD, FT MYERS BCH 339314498

Inspection Date: 06/06/2022

Inspection Number: 1222319

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Observed no smoke alarm in room 168. Maintenance installed one during inspection. ****Corrected On-Site****

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4701982

CAMELIA KNOLL

License Type: Apartment

210 DIXIE DR, TALLAHASSEE 323043084

Inspection Date: 06/06/2022

Inspection Number: 1514446

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HAASE, TINA

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purpose only. Observed fire extinguishers missing from sides of building I, L and B.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5402201

FAIRFIELD INN & SUITES BY MARRIOTT KEY WEST

License Type: Motel

2400 N ROOSEVELT BLVD, KEY WEST 33040-3838

Inspection Date: 06/06/2022

Inspection Number: 1220081

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTINEZ, YANET

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located between unit 114 and 113.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5401245

PEGASUS INT HOTEL

License Type: Hotel

501 SOUTHARD ST, KEY WEST 330406835

Inspection Date: 06/06/2022

Inspection Number: 1159850

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
From follow-up inspection 2022-06-06: No boiler certificate or insurance inspector's boiler report available. For repor

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811311

THE STATION AT ALAFAYA

License Type: Apartment

300 DALHAUSSER LANE, OVIEDO 32765

Inspection Date: 06/07/2022

Inspection Number: 1515062

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GUTTERMAN, KENNETH

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800547

610 PALMER LLC

License Type: Apartment

610 E PALMER ST, ORLANDO 32801

Inspection Date: 06/10/2022

Inspection Number: 1529301

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VAUGHAN, COURTNEY

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Up stairs between unit 3 and 5 fire extinguisher in the red overcharge zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800281

PROSPERITY PLACE

License Type: Apartment

621 W S ST, ORLANDO 32805

Inspection Date: 06/10/2022

Inspection Number: 1526486

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purpose only. Between units 7 and 8 ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800439

PROSPERITY PLACE

License Type: Apartment

635 W S ST, ORLANDO 32805

Inspection Date: 06/10/2022

Inspection Number: 1526487

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purpose only. Both first and second floor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811337

NEW HORIZONS

License Type: Apartment

541 COTTAGE HILL RD, ORLANDO 32805

Inspection Date: 06/10/2022

Inspection Number: 1522222

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purpose only. By unit 53

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5805056

RED ROOF PLUS ORLANDO

License Type: Hotel

8342 JAMAICAN CT, ORLANDO 32819

Inspection Date: 06/10/2022

Inspection Number: 1164605

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation Code

Observation

Violation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.
 Room 204 and 341 missing face plate for smoke detector
 Maintenance person working on replacing face plates. **Corrective Action Taken**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809335

PORTO FINO BAY HOTEL

License Type: Hotel

5601 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 06/10/2022

Inspection Number: 1163589

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
System trouble ground fault loop 6

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811149

HAMPTON INN AND SUITES ORLANDO SEAWORLD

License Type: Hotel

7003 SEA HARBOR DR, ORLANDO 32821

Inspection Date: 06/07/2022

Inspection Number: 1162762

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: LINDSAY, SHARON

Violation Code

Observation

Violation Citation

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only./ room 220 , the alarm sounds but the light doesn't flash to indicate the alarm is sounding. ****Warning**** - From follow-up inspec

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5912068

MM LAKE HOTEL LLC

License Type: Hotel

4944 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 06/06/2022

Inspection Number: 1163168

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Boiler FL 138722. - From follow-up inspection 2022-06-06: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900227

SILVER LAKE RESORT

License Type: Vacation Rental - Condo

7751 BLACK LAKE RD, KISSIMMEE 347471760

Inspection Date: 06/06/2022

Inspection Number: 1089453

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available
For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014234

NORTHLAND BARCELONA LLC

License Type: Apartment

111 SIERRA DR, JUPITER 33458

Inspection Date: 06/08/2022

Inspection Number: 1534347

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. 106 Majorca Building.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6207861

RODEWAY INN

License Type: Motel

16405 US HWY 19 N, CLEARWATER 33764-6703

Inspection Date: 06/06/2022

Inspection Number: 1222836

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.
 For reporting purposes only.
 1 of 2 hearing impaired smoke alarms doesn't not strobe when tested

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6301099

STAY PLUS INN

License Type: Motel

33224 HWY 27 S, HAINES CITY 33844

Inspection Date: 06/06/2022

Inspection Number: 1222872

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: WHITE, CHERYL

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 159 in disrepair.

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900591

OAKS OF SPRING VALLEY (THE)

License Type: Apartment

497 SPANISH TRACE DR, ALTAMONTE SPGS 32714

Inspection Date: 06/09/2022

Inspection Number: 1523704

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VALERIO, GRACE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
 - At laundry room next to pool.
 - On second floor between apts 469 and 471.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904018

OAKMONTE VILLAGE AT LAKE MARY

License Type: Apartment

1021 ROYAL GARDENS CIR, LAKE MARY 32746

Inspection Date: 06/03/2022

Inspection Number: 1520100

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 133148, 5/8/22, 133147 , 5/8/22 133145 5/8/22, 133146 5/8/22
Boilers in 2 different rooms

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904050

LOFTS AT EDEN

License Type: Apartment

1840 RINEHART RD, SANFORD 32771

Inspection Date: 06/10/2022

Inspection Number: 1535556

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: ANGEL, TERRY

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Left Voicemail. 407-562-2788.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904053

ALEXANDER AT SABAL POINT

License Type: Apartment

2700 SABAL ALEXANDER CIR, LONGWOOD 32779

Inspection Date: 06/06/2022

Inspection Number: 1524430

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. At the box between 126 and 130 bldg 3

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
System is in trouble

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6500447

DUNES (THE)

License Type: Apartment

1555 A1A SOUTH, SAINT AUGUSTINE 32080

Inspection Date: 06/07/2022

Inspection Number: 1528638

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Fire extinguisher in back of unit 33 with no hammer, also no hammer at fire extinguisher at back of unit 9.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501024

SEASIDE INN

License Type: Motel

311 A1A BEACH BLVD, SAINT AUGUSTINE 32080

Inspection Date: 06/07/2022

Inspection Number: 1222036

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: GROTZ, CINDY

Violation Code

Observation

Violation Citation

12-04-4

- From initial inspection : High Priority - Balcony/starway/platform collapsed.
Deck/platform in front of North Building next to office is in disrepair.
Warning - From follow-up inspection 2022-05-03: Owner has posted caution tape and blocked off

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

St. Johns County

License Number: 6501499

REGENCY INN & SUITES

License Type: Motel

331 A1A BEACH BLVD, SAINT AUGUSTINE 32080

Inspection Date: 06/09/2022

Inspection Number: 1222052

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available
For reporting purposes only.
Data plate on large boiler in second story electrical room states
500000 input BTUs

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501644

ISLA ANTIGUA

License Type: Apartment

655 WMARINA COVE DR, ST. AUGUSTINE 32080

Inspection Date: 06/06/2022

Inspection Number: 1529485

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BADDING, MELANIE

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. Fire panel has trouble light illuminated, reading code 001 Dialer Delivery Fail.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6500050

HASTINGS APTS

License Type: Apartment

805 MERKERSON ST, HASTINGS 32145

Inspection Date: 06/08/2022

Inspection Number: 1514796

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BADDING, MELANIE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
No hammer provided for locked fire extinguisher in laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406510

REGAL INN

License Type: Motel

1020 S RIDGEWOOD AVE, DAYTONA BEACH 32114

Inspection Date: 06/09/2022

Inspection Number: 1222076

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Room 4 **Corrected On-Site**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406597

1381 APARTMENT LLC

License Type: Apartment

1381 VIRGINIA AVE, DAYTONA BEACH 32114

Inspection Date: 06/09/2022

Inspection Number: 1524335

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

02-08-4

Small Propane tank stored next to a stairwell on north side of building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406664

CLYDE MORRIS LANDINGS APARTMENT HOMES

License Type: Apartment

1381 N CLYDE MORRIS BLVD, DAYTONA BEACH 32117

Inspection Date: 06/09/2022

Inspection Number: 1529694

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel in front office. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401228

COVE MOTEL

License Type: Motel

1306 N ATL, DAYTONA BEACH 32118

Inspection Date: 06/10/2022

Inspection Number: 1222633

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7403605

FLAMINGO INN

License Type: Motel

2011 S AT, DAYTONA BEACH SHORES 32118

Inspection Date: 06/10/2022

Inspection Number: 1222666

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7403480

THE GRANITE AT PORPOISE BAY

License Type: Apartment

101 PORPOISE BAY RD, DAYTONA BEACH 32119

Inspection Date: 06/08/2022

Inspection Number: 1530803

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: COREY, DEREK

Violation CodeObservationViolation Citation

04-03-4

Alarm damaged as to appear to be inoperable. For reporting purposes only.

-alarm pull switch in disrepair, front of building #10

-fire alarm strobe light hanging off wall by wires, building #4

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400051

DAYS INN SPEEDWAY

License Type: Motel

2904 W INTL SPEEDWAY BLVD, DAYTONA BEACH 32124

Inspection Date: 06/06/2022

Inspection Number: 1222853

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: COREY, DEREK

Violation Code

Observation

Violation Citation

02-04-4

Gasoline can with gasoline and wood stored in storage area that has two water heaters. Operator removed gasoline can. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405077

ALOHA MOTEL APTS

License Type: Motel

6700 TURTLE MOUND RD, NEW SMYRNA BCH 321694919

Inspection Date: 06/06/2022

Inspection Number: 1222071

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -

Inspector Name: PICHARDO, RENEE

Admin. complaint recommended

Violation Code

Observation

Violation Citation

12-04-4

- From initial inspection : High Priority - Walkway on second floor exterior wood rotted. east side near sliding glass door. ****Warning***
 - From follow-up inspection 2022-06-06: Area cordoned off to prev access. ****Time Extended****

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Volusia County

License Number: 7400712

CORAL SANDS INN

License Type: Motel

1009 OCEANSHORE BLVD, ORMOND BEACH 32176

Inspection Date: 06/06/2022

Inspection Number: 1221172

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401413

TROPICAL RESORT AND MARINA

License Type: Motel

1485 LAKEVIEW DR, DELAND 32720

Inspection Date: 06/09/2022

Inspection Number: 1221244

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: OCASIO-LOPEZ, LISA

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 202,

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.