

Observation

**Alachua County**

License Number: 1100888

WOODRIVER APARTMENTS

License Type: Apartment

920 SW DEPOT ST, GAINSVILLE 326017872

Inspection Date: 06/16/2022

Inspection Number: 1515581

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
Fire extinguisher missing from box in between apartments 11 and 12.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Brevard County**

License Number: 1500238

BUDGET MOTEL TITUSVILLE

License Type: Motel

612 S WASHIGTON AVE, TITUSVILLE 32796

Inspection Date: 06/14/2022

Inspection Number: 1220776

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANZ, LINDA

Violation Code

Observation

Violation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Please tank on the second floor under the overhang, also charcoal grill with fuel in same area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Brevard County**

License Number: 1505703

EXTENDED STAY AMERICA #9514

License Type: Hotel

2265 COASTAL LANE, WEST MELBOURNE 32904

Inspection Date: 06/13/2022

Inspection Number: 1163557

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.  
For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Observation

**Broward County**

License Number: 1621094

ALVIFIN CORPORATION

License Type: Apartment

1830 SHERIDAN ST, HOLLYWOOD 33020

Inspection Date: 06/15/2022

Inspection Number: 1521331

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: GANPAT, INDAR

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to unit #10.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Collier County**

License Number: 2100459

RED ROOF FLUS +& SUITES

License Type: Hotel

1925 DAVIS BLVD, NAPLES 34104

Inspection Date: 06/14/2022

Inspection Number: 1163725

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: DILLON, TIMOTHY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only. Observed a trouble light on the fire pane This is a repeat violation from 12/09/21. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Collier County**

License Number: 2102232

MEADOW LAKES APARTMENTS

License Type: Apartment

105 MANOR BLVD, NAPLES 34104

Inspection Date: 06/13/2022

Inspection Number: 1528285

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAVES, PETER

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. The fire extinguisher at apartment 807 is in need of recharge.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Observation

**Dade County**

License Number: 2311339

ECONOLOGDE INN & SUITES

License Type: Motel

1223 NE 1 AVE, FLORIDA CITY 33034

Inspection Date: 06/15/2022

Inspection Number: 1222902

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only. Observed no smoke detector at room 107.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2330001

THE FLATS AT CITY PLACE

License Type: Apartment

3555 NW 83 AVE STE 100, DORAL 33122

Inspection Date: 06/14/2022

Inspection Number: 1529385

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SANCHEZ, JAVIER

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2307946

2001 NW FLAGLER TER

License Type: Apartment

2001 NW FLAGLER TER, MIAMI 33125

Inspection Date: 06/16/2022

Inspection Number: 1514465

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. observed at fire extinguisher located next to back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2329660

BUENA VISTA GARDENS

License Type: Apartment

5601 NW 1 AVE, MIAMI 33127

Inspection Date: 06/13/2022

Inspection Number: 1535710

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at the fire extinguisher next to the laundry area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2330088

AUDREY M EDMONSON TRANSIT VILLAGE APARTMENTS II

License Type: Apartment

6145 NW 7 AVE, MIAMI 33127

Inspection Date: 06/15/2022

Inspection Number: 1526635

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo  
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2330122

VISTA GARDENS LLC

License Type: Apartment

4740 NW 7 AVE, MIAMI 33127

Inspection Date: 06/16/2022

Inspection Number: 1514859

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartment #5 & 6, and also at fire extinguisher next to mailboxes. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2314408

GRANDA APT

License Type: Apartment

926 NW 5 ST, MIAMI 331281230

Inspection Date: 06/14/2022

Inspection Number: 1513361

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CUDEMOS, VIRNA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located near apartment #1.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Observation

**Dade County**

License Number: 2301233

VILLA LOURDES

License Type: Apartment

337 SW 5 AVENUE, MIAMI 33130

Inspection Date: 05/24/2022

Inspection Number: 1535772

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SWIGERT, RICHARD

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2301266

PANCHO'S APARTMENTS

License Type: Apartment

969 SW 2 ST, MIAMI 33130

Inspection Date: 06/17/2022

Inspection Number: 1523143

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no access device in fire extinguisher located on first floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2301977 701-731 SW 5TH STREET LLC

License Type: Apartment 731 SW 5 ST, MIAMI 33130

Inspection Date: 06/15/2022      Inspection Number: 1514388      Inspection Type: Routine - Lodging      Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRUZ, EDGAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-02-4	<p>Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed in front of unit 3 and unit 8 on building 721 **Repeat Violation**</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Observation

**Dade County**

License Number: 2306728 VQ EVERGLADES BUILDINGS  
 License Type: Apartment 923 SW 7 ST, MIAMI 33130

Inspection Date: 06/16/2022 Inspection Number: 1521468 Inspection Type: Routine - Lodging Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GOMEZ-SANCHEZ, NELLY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apartment #2 and #5 without device to access properly.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2308519

14ON4 LLC

License Type: Apartment

850 SW 3 ST, MIAMI 33130

Inspection Date: 06/17/2022

Inspection Number: 1526529

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BROWN, JARON

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher between units 3 and 4 missing breakage device.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2310890 QUERO APARTMENTS  
 License Type: Apartment 444 SW 10 ST, MIAMI 33130

Inspection Date: 06/15/2022 Inspection Number: 1523918 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: ELDER, AUDREY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located near unit 6.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2312541

BUENA VISTA APARTMENTS

License Type: Apartment

529 SW 4 ST, MIAMI 33130

Inspection Date: 06/16/2022

Inspection Number: 1523140

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located near unit 104.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2316565

VILLA ELENA APARTMENTS

License Type: Apartment

636 SW 6 STREET, MIAMI 33130

Inspection Date: 06/16/2022

Inspection Number: 1530198

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: CRUZ, EDGAR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo  
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Observation

**Dade County**

License Number: 2329656

VISTA GRANDE APARTMENTS

License Type: Apartment

850 SW 2 AVE, MIAMI 33130

Inspection Date: 06/17/2022

Inspection Number: 1526532

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BROWN, JARON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2330054

IBERIA APTS LLC

License Type: Apartment

629 SW 2 ST, MIAMI 33130

Inspection Date: 06/01/2022

Inspection Number: 1535773

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SWIGERT, RICHARD

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2330555 VQ EVERGLADES BUILDINGS

License Type: Apartment 888 SW 6 ST, MIAMI 33130

Inspection Date: 06/16/2022 Inspection Number: 1524936 Inspection Type: Routine - Lodging Inspection Disposition: Inspection

Inspector Name: BROWN, JARON Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher between units 603 and 605 missing breakage device.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2307306 869 APARTMENTS  
 License Type: Apartment 869 SW 3 ST, MIAMI 331302220

Inspection Date: 06/17/2022 Inspection Number: 1525198 Inspection Type: Routine - Lodging Inspection Disposition: Call Back - Extension given, pending  
 Inspector Name: CABANAS, NATALIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed at fire extinguisher near unit 2. - From follow-up inspection 2022-06-17: Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed at fire extinguisher near unit 2. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed at fire extinguisher near unit 2.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2301680

JOSE RESTREPO APARTMENTS

License Type: Apartment

845 SW 4 ST, MIAMI 331302248

Inspection Date: 06/15/2022

Inspection Number: 1522725

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no device to access on both fire extinguisher located on first and second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2307247

BRICKELL WEST APARTMENTS

License Type: Apartment

180 SW 9 ST, MIAMI 331303568

Inspection Date: 06/16/2022

Inspection Number: 1522837

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SWIGERT, RICHARD

Violation Code

Observation

Violation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2309213

SERGIO RIBERA APTS

License Type: Apartment

537 SW 10 ST, MIAMI 331303828

Inspection Date: 06/16/2022

Inspection Number: 1527386

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apartments C.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Observation

**Dade County**

License Number: 2300634 PARADISE APARTMENTS LLC  
 License Type: Apartment 1936 SW 2 ST, MIAMI 33135

Inspection Date: 06/16/2022 Inspection Number: 1517491 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-04-4	Fire alarm control panel has no power. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2301360

LITTLE HAVANA - 1920 SW 2ND ST

License Type: Apartment

1920 SW 2ND ST, MIAMI 33135

Inspection Date: 06/16/2022

Inspection Number: 1518576

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SANCHEZ, JAVIER

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Observation

**Dade County**

License Number: 2307715

DOUGLAS TOWNHOUSE

License Type: Apartment

3691 SW 5 TERR, MIAMI 331352573

Inspection Date: 06/15/2022

Inspection Number: 1518078

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SANCHEZ, JAVIER

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation**Dade County**

License Number: 2300976

FAIRMONT APTS

License Type: Apartment

2255 SW 7 ST, MIAMI 331353111

Inspection Date: 06/15/2022

Inspection Number: 1520480

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SANCHEZ, JAVIER

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge located in the laundry area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-04-4

Fire alarm control panel has no power. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2303084

DAVCHI DEVELOPMENT LLC

License Type: Apartment

1210 NW 2 AVE, MIAMI 33136

Inspection Date: 06/17/2022

Inspection Number: 1531638

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Apartments 4 and 9.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2328257

BAHIA 1201 1232

License Type: Apartment

1232 NW 1 PLACE, MIAMI 33136

Inspection Date: 06/14/2022

Inspection Number: 1531820

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By apartments 1, 6, 11, 22, 17, 13, 28, and 33.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Observation

**Dade County**

License Number: 2328267 WYNTOWN APARTMENTS LLC

License Type: Apartment 1720 NW 1 PL, MIAMI 33136

Inspection Date: 06/16/2022 Inspection Number: 1529016 Inspection Type: Routine - Lodging Inspection Disposition: Inspection

Inspector Name: HENLEY, LATONYA Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4 Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. By apartment 9. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2329895 ISLAND LIVING APARTMENTS  
 License Type: Apartment 1201 NW 3 AVE, MIAMI 33136

Inspection Date: 06/17/2022 Inspection Number: 1531055 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued  
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. First floor, by the corridor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2330628

REFLECTIONS

License Type: Apartment

1000 NW 7 ST, MIAMI 33136

Inspection Date: 06/17/2022

Inspection Number: 1529666

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2310669

DOMINION TOWER

License Type: Apartment

1400 NW 10 AVE, MIAMI 331361000

Inspection Date: 06/13/2022

Inspection Number: 1518099

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only. First floor by the security booth.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





Observation

**Dade County**

License Number: 2329303

1 HOTEL SOUTH BEACH

License Type: Hotel

2341 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 06/13/2022

Inspection Number: 1164032

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2328333

ISLAND HOUSE

License Type: Apartment

715 82 ST, MIAMI BEACH 33141

Inspection Date: 06/13/2022

Inspection Number: 1520967

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No breaking device for extinguisher located on the stairs.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Observation

**Dade County**

License Number: 2330283

VOLODYMYR TARASHCHUK

License Type: Apartment

8320 BYRON AVE APT #5, MIAMI BEACH 33141

Inspection Date: 06/13/2022

Inspection Number: 1522075

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: UNZAGA, MILADYS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher located on the first floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2307927

CARLYLE VILLAS APTS

License Type: Apartment

6955 CARLYLE AVE, MIAMI BEACH 331413152

Inspection Date: 06/16/2022

Inspection Number: 1518195

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located next to Apt 2 & 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2329776

GIBALTAR APARTMENTS

License Type: Apartment

2350 SW 27 AVE, MIAMI 33145

Inspection Date: 06/17/2022

Inspection Number: 1514394

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: GARCIA, B OSCAR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only. **\*\*Admin Complaint\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Observation

**Dade County**

License Number: 2301488

HARBOUR KEY

License Type: Apartment

11033 SW 88 ST, MIAMI 33176-1200

Inspection Date: 06/17/2022

Inspection Number: 1520994

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible, fire extinguisher located by laundry room in building G, fire extinguisher not accessible located by meter room in building E. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Dade County**

License Number: 2327631

CAMDEN DORAL

License Type: Apartment

4790 NW 107TH AVENUE, MIAMI 33178

Inspection Date: 06/16/2022

Inspection Number: 1530374

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: CABANAS, NATALIE

Violation Code

Observation

Violation Citation

01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed at fire extinguisher next to unit 1502.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at building 1601.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Duval County**

License Number: 2613284

JFRD HOLDINGS LLC

License Type: Apartment

1445 FLAGLER AVE, JACKSONVILLE 32207

Inspection Date: 06/10/2022

Inspection Number: 1522380

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YOUNG, JENNIFER

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.  
Very low hanging electrical wires on the right side of building hanging extremely low connected to city electrical pole.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Duval County**

License Number: 2610083

PELICAN POINTE APARTMENTS

License Type: Apartment

1333 DUNN AVE, JACKSONVILLE 32218

Inspection Date: 06/13/2022

Inspection Number: 1515429

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

12-04-4

High Priority - Balcony/starway/platform collapsed.

Large hole in handicap ramp for unit 401.

Hole and loose railing handicap ramp for unit 409 . **\*\*Warning\*\***

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.



Observation

**Duval County**

License Number: 2608615

MOTEL 6 JACKSONVILLE ORANGE PARK

License Type: Motel

6107 YOUNGERMAN CIR, JACKSONVILLE 32244

Inspection Date: 06/17/2022

Inspection Number: 1222934

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
Certificate in boiler room expired 6/28/2020

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Duval County**

License Number: 2610247

ELEMENTS OF BELLE RIVE APTS

License Type: Apartment

10010 BELLE RIVE BLVD, JACKSONVILLE 32256

Inspection Date: 06/16/2022

Inspection Number: 1531185

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JEFFERS, MARY-BETH

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.  
Fire extinguisher between garages 1704 & 1705 obstructed by multiple towels hanging on it.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Duval County**

License Number: 2613445

JUSTINA COURT APARTMENTS

License Type: Apartment

5844 JUSTINA CT, JACKSONVILLE 32277

Inspection Date: 06/17/2022

Inspection Number: 1527276

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation Code

Observation

Violation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only.  
LP gas 20lb tank stored under stairwell

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Escambia County**

License Number: 2702634

QUEEN MARY

License Type: Motel

8240 N DAVIS HWY, PENSACOLA 32514

Inspection Date: 06/16/2022

Inspection Number: 1222928

Inspection Type: Complaint Partial

Inspection Disposition: Warning  
Issued

Inspector Name: BARNARD, JOHN

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.  
Room 3312

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3903741

TOWNHOUSE APARTMENTS

License Type: Apartment

15530 NEBRASKA AVE, LUTZ 335496178

Inspection Date: 06/13/2022

Inspection Number: 1522955

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
-on wall between b and c

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3913872

LANTOWER ASTURIA

License Type: Apartment

15175 INTEGRA JUNCTION, ODESSA 33556

Inspection Date: 06/13/2022

Inspection Number: 1522352

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

-ground level next to G7-F @ building 2140

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3905029

HILTON DOWNTOWN TAMPA

License Type: Hotel

211 N TAMPA ST, TAMPA 33602

Inspection Date: 06/16/2022

Inspection Number: 1162559

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AUDETTE, DAKOTA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Location inspected 04/25/22 and inspector verified that system is in working order and certificates will be issued.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3913745

THE SLADE AT CHANNELSIDE

License Type: Apartment

1190 E WASHINGTON ST, TAMPA 33602

Inspection Date: 06/13/2022

Inspection Number: 1522398

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Observation

**Hillsborough County**

License Number: 3906271

JANIE B APARTMENTS

License Type: Apartment

5305 N BLVD ST, TAMPA 33603

Inspection Date: 06/13/2022

Inspection Number: 1529477

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By unit 113.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

---

License Number: 3905141

TAMPA AIRPORT HILTON

License Type: Hotel

2225 LOIS AVE, TAMPA 33607

Observation

**Hillsborough County**

Inspection Date: 06/16/2022

Inspection Number: 1162942

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection

Inspector Name: KLUSENDORF, JEANNE

Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Management said they are waiting on certificate	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3913667

THE MILLENNIUM WESTSHORE

License Type: Apartment

4400 WEST SPRUCE ST, TAMPA 33607

Inspection Date: 06/13/2022

Inspection Number: 1519989

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble listed on panel.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-01-4	Light fixture hanging down in front of 456. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3902009

SUNSET INN MOTEL

License Type: Motel

4712 E HILLSBOROUGH AVE, TAMPA 33610

Inspection Date: 06/14/2022

Inspection Number: 1222913

Inspection Type: Complaint Full

Inspection Disposition: Administrative complaint recommended

Inspector Name: KLUSENDORF, JEANNE

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 3

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3913559

WEXFORD APARTMENTS

License Type: Apartment

7801 WEXFORD PARK DR, TAMPA 33610

Inspection Date: 06/16/2022

Inspection Number: 1531533

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VAUGHAN, COURTNEY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
 Building 10 trouble fire panel called fire to come check it out  
 \*\*Corrective Action Taken\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3913653

HOME 2 SUITES TAMPA USF NEAR BUSCH GARDENS

License Type: Hotel

11606 MCKINLEY DR, TAMPA 33612

Inspection Date: 06/14/2022

Inspection Number: 1163935

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: CESAR, RACHEL

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. **\*\*Warning\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3913763

PALM TREE APTS INC

License Type: Apartment

13113 N 22 ST, TAMPA 33612

Inspection Date: 06/15/2022

Inspection Number: 1523756

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: MITTEN, JAMES

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.  
Building 13111  
Building 13109

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Observation

**Hillsborough County**

License Number: 3913973

OAKS AT UNIVERSITY APARTMENTS - PARCEL 3

License Type: Apartment

1510 EAST 127TH AVE, TAMPA 33612

Inspection Date: 06/14/2022

Inspection Number: 1529597

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MITTEN, JAMES

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. By apartment 2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3902547

TOWN & COUNTRY APTS

License Type: Apartment

5625 FOREST HAVEN CIRCLE, TAMPA 33615

Inspection Date: 06/16/2022

Inspection Number: 1535731

Inspection Type: Complaint Partial

Inspection Disposition: Warning Issued

Inspector Name: ZHANG, JACKY

Violation Code

Observation

Violation Citation

07-04-4

Electrical panel in disrepair. For reporting purposes only.  
Per maintenance supervisor Nelson- Electric panel missing two covers over breaker. Apt#9-105.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3903555

RIVERSIDE PALMS APARTMENTS

License Type: Apartment

5008 SIERRA PL, TAMPA 33617

Inspection Date: 06/15/2022

Inspection Number: 1535730

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: REGAS, ANTHONY

Violation Code

Observation

Violation Citation

12-04-4

High Priority - 12-04-4 Observed: Balcony/starway/platform collapsed.

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Observed the stairwell and platform for building 8413 units 506,606, and 607. Is collapsed. The area is closed and being blocked by caution tape for the upstairs units. The residents have been moved to a new apartments. The downstairs unit 506 is safe per The City of Tampa and the Fire Marshal for tenant to move back into. City of Tampa and the Fire Marshal have been out and have cited the Establishment for issues regarding stairway. Operator states that they are pulling permits and getting bids for the work to be done.

Establishment on warning from previous inspection callback due on 7/16/2022. \*\*Repeat Violation\*\* \*\*Warning\*\*

Observation

**Hillsborough County**

License Number: 3906778

RED ROOF INN

License Type: Motel

10121 HORACE AVE, TAMPA 33619

Inspection Date: 06/15/2022

Inspection Number: 1222507

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: MOULDER, BRITTANY

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
Observed extinguisher missing from location near 3rd floor guest laundry room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3901892

RANCH HOUSE MOTEL

License Type: Motel

2909 S 50 ST, TAMPA 336196045

Inspection Date: 06/15/2022

Inspection Number: 1222609

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: AUDETTE, DAKOTA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Next to room 18. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Hillsborough County**

License Number: 3913668

HUNTERS RUN PARTNERS II LTD

License Type: Apartment

6402 ROYAL HUNT DR, TAMPA 33625

Inspection Date: 06/15/2022

Inspection Number: 1529293

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Lee County**

License Number: 4604656

LAGO DEL SOL APARTMENTS

License Type: Apartment

10770 CLEAR LAKE LOOP, FORT MYERS 33908

Inspection Date: 06/14/2022

Inspection Number: 1525888

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

04-06-4

- From initial inspection : Fire alarm control panel emitting an audible alarm. For reporting purposes only. Buildings 15061 and 15101. **\*\*Repeat Violation\*\*** - From follow-up inspection 2022-06-14:

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Leon County**

License Number: 4702740

SAXON STREET APTS

License Type: Apartment

2500 SAXON ST THRU 2526, TALLAHASSEE 32310

Inspection Date: 06/16/2022

Inspection Number: 1516843

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SMITH, PAUL

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Empty box 2602.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Observation

**Manatee County**

License Number: 5102009

VENTURE RENTALS LTD

License Type: Apartment

3800 LAKE BAYSHORE DR, BRADENTON 342059001

Inspection Date: 06/14/2022

Inspection Number: 1518862

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: BECHTOLD, NEIL

Violation Code

Observation

Violation Citation

04-04-4

- From initial inspection : Fire alarm control panel has no power. For reporting purposes only. Operator stated that the fire department is aware of the issue. Parts are on back order for repair. - From follow-up inspection 2022-06-14: Signs still posted on alarm pull tabs that alarm is still not functioning. Operator stated they are still waiting for the parts. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Manatee County**

License Number: 5102652

VENTURE RENTALS

License Type: Apartment

3600 LAKE BAYSHORE DR #16, BRADENTON 342059026

Inspection Date: 06/14/2022

Inspection Number: 1530027

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: BECHTOLD, NEIL

Violation Code

Observation

Violation Citation

04-04-4

- From initial inspection : Fire alarm control panel has no power for zone 1. For reporting purposes only. Operator stated that the fire department is aware of the issue. Parts are on back order for repair. This issue only applies to the south side building of 16R zone 1 that includes 101-105, 201-205, 301-305, 401-405, and 501-505. - From follow-up inspection 2022-06-14: Operator stated that they are still waiting on parts to fix the problem. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Monroe County**

License Number: 5401786

WATERSIDE SUITES & MARINA

License Type: Motel

201 OCEAN DR, KEY LARGO 33037

Inspection Date: 06/14/2022

Inspection Number: 1222186

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: GONZALEZ, RICARDO

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\*** - From follow-up inspection 2022-06-14: Trouble/alarm light illuminated on the fire alarm control panel. **\*\*Time Extended\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Orange County**

License Number: 5801687

HANDS OF CENTRAL FLORIDA INC

License Type: Apartment

1301 CATHERINE ST, ORLANDO 328014221

Inspection Date: 06/13/2022

Inspection Number: 1522340

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MITTEN, JAMES

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Across from apartment 307

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Orange County**

License Number: 5804772

DAYS INN & SUITES

License Type: Motel

1853 MCCOY RD, BELLE ISLE 32809

Inspection Date: 06/14/2022

Inspection Number: 1217345

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: PASIECKI, VICTORIA

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside room 130 - From follow-up inspection 2022-06-14: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Orange County**

License Number: 5811199

ELEMENT ORLANDO INTERNATIONAL DRIVE

License Type: Hotel

5750 CENTRAL FLORIDA PARKWAY, ORLANDO 32821

Inspection Date: 06/16/2022

Inspection Number: 1164612

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LINDSAY, SHARON

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Per engineer the hot water heater is capable of 500,000 btu.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Palm Beach County**

License Number: 6007233

DOUBLETREE WEST PALM BEACH AIRPORT

License Type: Hotel

1808 S AUSTRALIAN AVE, WEST PALM BEACH 33409

Inspection Date: 06/15/2022

Inspection Number: 1164550

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOLDMAN, BARRY

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. J#123144, 050720 - 03/10/2022 - waiting on inspection. **\*\*Corrective Action Taken\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Pinellas County**

License Number: 6215282

REGENCY MANOR

License Type: Apartment

N 750 7 AVE, ST PETERSBURG 33701

Inspection Date: 06/14/2022

Inspection Number: 1520706

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: MURPHY, JAMES

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. On second floor landing of main building, fire extinguisher is overcharged

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Observation

**Pinellas County**

License Number: 6216062

HEN PADS 2 LLC

License Type: Apartment

819 6 ST N, ST PETERSBURG 33701

Inspection Date: 06/16/2022

Inspection Number: 1529061

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: MURPHY, JAMES

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
Fire extinguisher area is marked outside of apartment 5 of first building, however, no fire extinguisher is present.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Pinellas County**

License Number: 6209560

HILTON ST PETERSBURG BAYFRONT

License Type: Hotel

333 1 ST S, ST. PETERSBURG 33701

Inspection Date: 06/17/2022

Inspection Number: 1159435

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MURPHY, JAMES

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  
Boilers have been replaced and no new boiler certificate is on file

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Pinellas County**

License Number: 6205451

MILO BAYSIDE

License Type: Apartment

509 77 AVE N, ST. PETERSBURG 33702

Inspection Date: 06/16/2022

Inspection Number: 1535448

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: LOZANO, KELVIN

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No means to break glass next to building 2 unit 205

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Pinellas County**

License Number: 6205583

BRECKENRIDGE BEACH RESORT

License Type: Motel

5700 GULF BLVD, ST. PETE BEACH 33706

Inspection Date: 06/17/2022

Inspection Number: 1220095

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: DAY-WALKER, LISA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate expired 8/21/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Pinellas County**

License Number: 6201368

CLUB COPA CAPRI

License Type: Apartment

11750 CAPRI CIR S, TREASURE ISLAND 33706

Inspection Date: 06/16/2022

Inspection Number: 1526181

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Across from apartment 4.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

---

License Number: 6209700

SURE STAY BY BEST WESTERN

License Type: Motel

3655 HOSPITALITY LN, CLEARWATER 33762

Observation

**Pinellas County**

Inspection Date: 06/15/2022

Inspection Number: 1222137

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection

Inspector Name: WILMOT, TASHARA

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-01-4	<p>Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. -to the right of room 113</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
08-01-4	<p>Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. -050753 2/9/2017</p>	<p>61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Observation

**Pinellas County**

License Number: 6214461

SONESTA SIMPLY SUITES CLEARWATER

License Type: Motel

13231 49 ST N, CLEARWATER 33762

Inspection Date: 06/15/2022

Inspection Number: 1222125

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

134155 6/8/2022

Operator stated that boiler is not in use





Observation

**Pinellas County**

License Number: 6215824

MJH PROPERTIES

License Type: Apartment

2754 PARK DR, CLEARWATER 33763

Inspection Date: 06/15/2022

Inspection Number: 1513862

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: PEARCE, LAURA

Violation Code

Observation

Violation Citation

01-02-4

-Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only . between apartment 2760 A-B  
 -Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Near apartment 2760 C

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Observation

**Polk County**

License Number: 6306553

COURTYARD LAKELAND

License Type: Hotel

3725 HARDEN BLVD, LAKELAND 33803

Inspection Date: 06/14/2022

Inspection Number: 1162220

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Polk County**

License Number: 6303266

IMPERIAL SWAN HOTEL & SUITES

License Type: Hotel

4141 S FLORIDA AVE, LAKE LAND 33813

Inspection Date: 06/14/2022

Inspection Number: 1164596

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
4th floor meeting room lighting up.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

---

**Seminole County**

Observation

---

**Seminole County**

---

License Number: 6900381

OPAL HOTEL & SUITES

License Type: Motel

230 W SR 436, ALTAMONTE SPRINGS 32714

Observation

**Seminole County**

Inspection Date: 06/13/2022

Inspection Number: 1221983

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: VAZQUEZ, JULITZA

Violation Code

Observation

Violation Citation

05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. <b>**Warning**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



Observation

**St. Johns County**

License Number: 6501410

HAMPTON INN

License Type: Hotel

2525 CO RD 208, ST AUGUSTINE 32092

Inspection Date: 06/13/2022

Inspection Number: 1164512

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERKINS, MARC

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.  
Hearing impaired smoke alarm in room 220, does not light up when placed in test mode, only creates a lamer sound. Hearing impaired light for alarm works when button outside of room is pressed down.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Volusia County**

License Number: 7406440

PORT ORANGE APARTMENT ASSOC I LLC

License Type: Apartment

1200 FLORAL SPRINGS BLVD, PORT ORANGE 32129

Inspection Date: 06/13/2022

Inspection Number: 1515120

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: COREY, DEREK

Violation Code

Observation

Violation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.  
-trouble building #16

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Observation

**Volusia County**

License Number: 7403173

SUGARTREE APTS #2379/#2449

License Type: Apartment

1801 SUGARTREE CIR, NEW SMYRNA BCH 321681521

Inspection Date: 06/17/2022

Inspection Number: 1522541

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PICHARDO, RENEE

Violation Code

Observation

Violation Citation

07-01-4

Exposed, loose electrical wire(s). For reporting purposes only.  
Side of 1950

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.