

Alachua County

License Number: 1100249

COLLEGE MANOR

License Type: Apartment

1216 SW 2 AVE, GAINESVILLE 326016160

Inspection Date: 06/20/2022

Inspection Number: 1513179

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in front of apartment 17 on floor one.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Alachua County

License Number: 1102671

THE PADDOCK CLUB GAINESVILLE

License Type: Apartment

1105 FT CLARKE BLVD, GAINESVILLE 32606

Inspection Date: 06/20/2022

Inspection Number: 1526315

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Garages 51-52, 89-90, 97-98.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Alachua County

License Number: 1102568

LEXINGTON CROSSING

License Type: Apartment

3700 SW 27TH STREET, GAINESVILLE 32608

Inspection Date: 06/22/2022

Inspection Number: 1513570

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: TORRES, WILLIAM

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. Observed emergency fire alarm pull handle hanging from wires in building H

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Alachua County

License Number: 1102232

FLINT HILL

License Type: Apartment

300 NW 20 AVE, GAINESVILLE 32609

Inspection Date: 06/21/2022

Inspection Number: 1530828

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BAILEY, KIMBERLY

Violation Code

Observation

Violation Citation

07-01-4

Electrical box missing cover exposing wires on the other side of apartment 1 by road.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Alachua County

License Number: 1100724

BEL AIR APARTMENTS

License Type: Apartment

636 NW 26 AVE, GAINESVILLE 326092973

Inspection Date: 06/21/2022

Inspection Number: 1521594

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in front of the laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505884

ALYA PLACE LLC

License Type: Apartment

718 S ATLANTIC AVE, COCOA BEACH 32931

Inspection Date: 06/24/2022

Inspection Number: 1535722

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: HICKS, GEORGE RANDY

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By 203, 301, 303.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1502223

COCOA VILLAGE APRTMENTS

License Type: Apartment

22 SOUTH ST, ROCKLEDGE 32955

Inspection Date: 06/22/2022

Inspection Number: 1519339

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: FICHTER, GARRICK

Violation Code

Observation

Violation Citation

01-02-4	<p>- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in south building hallway is in red zone - From follow-up inspection 2022-06-22: No change **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
01-02-4	<p>Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in south building hallway is in red zone</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Broward County

License Number: 1610916

MOTEL 6 #376

License Type: Motel

825 E DANIA BEACH BLVD, DANIA BEACH 33004

Inspection Date: 06/21/2022

Inspection Number: 1222945

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher by door to room 105 shows under charged.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1601618

GRAND SOUTH REALTY LLC

License Type: Apartment

522 N 19 AVE, HOLLYWOOD 33020

Inspection Date: 06/20/2022

Inspection Number: 1518863

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BARTON, GEOFFREY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher by door to unit 11 in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1602567

NAPOLI APARTMENT MOTEL

License Type: Apartment

701 N BIRCH RD, FORT LAUDERDALE 33304-4024

Inspection Date: 06/23/2022

Inspection Number: 1518773

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: BRANN, JUSTIN

Violation Code

Observation

Violation Citation

01-01-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
By Apt 122. ****Repeat Violation**** - From follow-up inspection 2022-06-23: Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
By Apt 122. ****Repeat Violation**** ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621442

THE PEARL

License Type: Apartment

3880 W BROWARD BLVD, PLANTATION 33312

Inspection Date: 06/22/2022

Inspection Number: 1527284

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARTON, GEOFFREY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher undercharged next to door at unit 111 in building 3960

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621426

BP AVENUE LLC

License Type: Apartment

6220 REESE RD, DAVIE 33314

Inspection Date: 06/22/2022

Inspection Number: 1519786

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BARTON, GEOFFREY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguisher located by door to unit 101 in building 2 shows as undercharged.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.
Trouble light illuminated on hallway E3 Fire Control Panel on ground floor of building 2.
Lightning strike caused system failure. Replacement part on orde

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1617368

AQUA LOFTS TOWNHOMES LLC

License Type: Apartment

613 SE 19 ST, FORT LAUDERDALE 33316

Inspection Date: 06/02/2022

Inspection Number: 1524238

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: MCKINNEY, JOHN

Violation Code

Observation

Violation Citation

07-02-4

Frayed electrical wire(s). For reporting purposes only.
Building 613:
 Identified above door to unit 3, electrical wires hanging from lighting fixture location.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2001047

ALLEGRO

License Type: Apartment

3651 U.S HIGHWAY 17, FLEMING ISLAND 32003

Inspection Date: 06/21/2022

Inspection Number: 1515197

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In unit 124.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2000961

HAMPTON BY HILTON @ JACKSONVILLE - ORANGE PARK

License Type: Hotel

141 PARK AVE, ORANGE PARK 32073

Inspection Date: 06/21/2022

Inspection Number: 1162481

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.
For reporting purposes only.
Establishment does not know how to test the hearing impaired
smoke detectors. ****Warning****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302352

MORILLO'S APTS

License Type: Apartment

955 W 29 ST, HIALEAH 330125686

Inspection Date: 03/25/2022

Inspection Number: 1527475

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed two red lights illuminated in the fire panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330674

BONITA POINTE APARTMENTS

License Type: Apartment

613 E PALM DR, FLORIDA CITY 33034-3500

Inspection Date: 06/23/2022

Inspection Number: 1535858

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: LEIDECKER, EDILMA

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only. One located at building 1.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303605

MITCHELL'S APARTMENTS

License Type: Apartment

2940 NW 135 ST, OPA LOCKA 330544862

Inspection Date: 06/21/2022

Inspection Number: 1529947

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303115

CLH APARTMENTS

License Type: Apartment

440 NW 47 AVE, MIAMI 33126

Inspection Date: 06/22/2022

Inspection Number: 1526407

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2312572 IMS INVESTMENTS GROUP LLC

License Type: Apartment 4393 NW 11 ST, MIAMI 33126

Inspection Date: 06/22/2022

Inspection Number: 1528526

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located between unit 2 and 3, first floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329057

NEW HORIZONS APARTMENTS

License Type: Apartment

690 NW 60 ST, MIAMI 33127

Inspection Date: 06/21/2022

Inspection Number: 1523565

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: SAENZ, HILDA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only.Observed at the main entrance.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330088

AUDREY M EDMONSON TRANSIT VILLAGE APARTMENTS II

License Type: Apartment

6145 NW 7 AVE, MIAMI 33127

Inspection Date: 06/22/2022

Inspection Number: 1535895

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-06-22: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303268

1809 BRICKELL LP

License Type: Apartment

1809 BRICKELL AVE, MIAMI 33129

Dade County

Inspection Date: 06/20/2022

Inspection Number: 1481347

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

04-01-4	<p>- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-06-20: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Unable to check **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
08-01-4	<p>- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2022-06-20: Boiler certificate or insurance inspector's boiler report expired. For reporting purpose: only. Unable to check. **Time Extended**</p>	<p>61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Dade County

License Number: 2329379

ONE PLAZA CORP

License Type: Apartment

1818 SW 1 AVE, MIAMI 33129

Inspection Date: 06/20/2022

Inspection Number: 1518714

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309931

Z & RALPH LLC

License Type: Apartment

660 SW 9 ST, MIAMI 33130

Inspection Date: 06/20/2022

Inspection Number: 1519373

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: CRUZ, EDGAR

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between units 1 and two and 3 and 4.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2319919

BORINQUEN APARTMENTS

License Type: Apartment

425-435 SW 10 AVE, MIAMI 33130

Dade County

Inspection Date: 06/21/2022

Inspection Number: 1535261

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Observed at fire extinguisher next to unit 308. - From follow-up inspection 2022-06-21: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Observed at fire extinguisher next to unit 308. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-05-4

- From initial inspection : Portable fire extinguisher obstructed/no accessible. For reporting purposes only.
Observed fire extinguisher next to unit 318 missing breaking device at building 435.
Observed fire extinguisher next to unit 300 missing breaking device at building 425. - From follow-up inspection 2022-06-21
Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed fire extinguisher next to unit 318 missing breaking device at building 435.
Observed fire extinguisher next to unit 300 missing breaking device at building 425. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328456

EKA PATRAS

License Type: Apartment

1248 - 1254 SW 3 ST, MIAMI 33130

Inspection Date: 06/21/2022

Inspection Number: 1524496

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: CRUZ, EDGAR

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329832

WEST BRICKELL LODGING HOUSE

License Type: Apartment

202 SW 7 AVE, MIAMI 33130

Inspection Date: 06/21/2022

Inspection Number: 1530962

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330159

MONARC AT MET

License Type: Apartment

201 SE 2 AVE, MIAMI 33131

Dade County

Inspection Date: 06/21/2022

Inspection Number: 1524334

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel located in room, across from dumpster area. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler jurisdiction #134399; expired on 10/04/2020. Emailed boiler invoice regarding license to Sharon Fothergill, Senior Community Manager for apartment building. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330492

PANORAMA TOWER

License Type: Apartment

1100 BRICKELL BAY DR, MIAMI 33131

Inspection Date: 06/21/2022

Inspection Number: 1520161

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 3 boilers on the 52nd floor: FL 135741, expires 06/17/21; FL 135742, expires 06/17/21; FL 135743, expires 06/17/21. 2 boilers on the 86th floor: FL 135748, expires 6/17/21; FL 135747, expires 6/17/21.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300503

ALHAMBRA APARTMENTS

License Type: Apartment

3100 W FLAGLER ST, MIAMI 33135

Inspection Date: 06/24/2022

Inspection Number: 1527882

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Most fire extinguisher throughout the building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308087

VQ EVERGLADES INVESTMENT LLC

License Type: Apartment

1545 SW 6 ST, MIAMI 33135

Inspection Date: 06/24/2022

Inspection Number: 1528395

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. All fire extinguisher throughout. ****Warning****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330359 WESTON SILVER LLC
 License Type: Apartment 1453 SW 7 ST, MIAMI 33135

Inspection Date: 05/27/2022 Inspection Number: 1535972 Inspection Type: Routine - Lodging Inspection Disposition: Warning Issued
 Inspector Name: SWIGERT, RICHARD

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apartment 5.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330408

THE JASMINE

License Type: Apartment

100 SW 22ND AVE, MIAMI 33135

Inspection Date: 06/20/2022

Inspection Number: 1526979

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: GARCIA, B OSCAR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only. ****Admin Complaint****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300222

ESPINOSA APARTMENTS

License Type: Apartment

1450 SW 4 ST, MIAMI 331352258

Inspection Date: 06/24/2022

Inspection Number: 1520390

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2320030

TRANSCARIBE APTS

License Type: Apartment

1772 SW 5 ST, MIAMI 331353554

Inspection Date: 05/24/2022

Inspection Number: 1535917

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. 1st floor extinguisher. ****Warning****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329683

ST JOHN VILLAGE 1410 LLC

License Type: Apartment

1410 NW 1ST AVE, MIAMI 33136

Inspection Date: 06/22/2022

Inspection Number: 1529073

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By 103.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330141

2500 BISCAYNE

License Type: Apartment

2500 BISCAYNE BLVD, MIAMI 33137

Inspection Date: 06/24/2022

Inspection Number: 1531393

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed at the main panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310225

DESIGN PLACE

License Type: Apartment

5035 NE 2 AVE, MIAMI 331372917

Inspection Date: 06/23/2022

Inspection Number: 1519415

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fir
alarm control panel. For reporting purposes only.
Observed at building 5265. - From follow-up inspection
2022-06-23: **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent,
shall notify the local firesafety authority or the State
Fire Marshal of any readily observable violation of a
rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Dade County

License Number: 2313190

AUDY APARTMENTS #2

License Type: Apartment

601 NE 22 ST, MIAMI 331375149

Inspection Date: 05/12/2022

Inspection Number: 1515673

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

Observed between apartments 10 and 12, between apartments 2 and 22, between apartments 30 and 32, between apartments 40 and 42.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303085

7ST LLC

License Type: Apartment

1000 7 ST, MIAMI BEACH 33139

Inspection Date: 06/22/2022

Inspection Number: 1531136

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located near unit 9.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328865

TDK REAL ESTATE LLC

License Type: Bed and Breakfast

1545 MERIDIAN AVE, MIAMI BEACH 33139

Inspection Date: 06/20/2022

Inspection Number: 1094885

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel located by entrance door way of establishment. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2307246

AVON APARTMENTS

License Type: Apartment

1530 JEFFERSON AVE, MIAMI BEACH 331393436

Inspection Date: 06/22/2022

Inspection Number: 1529882

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CURRAS, YANLEE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between unit 19-18, 6-7, 20-21.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2304428

PARK SURF APARTMENTS

License Type: Apartment

341 73 ST, MIAMI BEACH 331412784

Inspection Date: 02/14/2022

Inspection Number: 1513292

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PRIETO, VICENTE

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking devices of fire extinguisher boxes between units 8 and 9 and between units 2 and 3. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2304399

5974 SW 5 TER

License Type: Apartment

5974 SW 5 TER, MIAMI 33144

Inspection Date: 06/21/2022

Inspection Number: 1526031

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartments#1 & #2 and also next to apartmer #9.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330066

MABRUK USA

License Type: Apartment

6315 SW 8 ST, MIAMI 33144

Inspection Date: 06/21/2022

Inspection Number: 1523720

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SAENZ, HILDA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next to apartment # 201.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309313

ORAI DA APARTMENTS I

License Type: Apartment

6487 W FLAGLER ST, MIAMI 331443077

Inspection Date: 06/22/2022

Inspection Number: 1531194

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: GOMEZ-SANCHEZ, NELLY

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed near to apartment #3 and #11.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309020

DEL PRADO APARTMENTS

License Type: Apartment

660 SW 57 AVE, MIAMI 33144-3978

Inspection Date: 06/22/2022

Inspection Number: 1524407

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device on extinguisher located next to apt 1.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329518

OPA LOCKA HOLDINGS

License Type: Apartment

7104 NW 14 PL #26 #36 #46 #60 #86, MIAMI 33147

Inspection Date: 06/23/2022

Inspection Number: 1535960

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Observed in building 7126 fire extinguisher between units 5 and 6 in recharge zone
Observed in building 7126 fire extinguisher between units 1 and 2 in recharge zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed in building 7104 fire extinguisher with no breakage device between units 7 and 8

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2311117

MAJESTIC APARTMENTS

License Type: Apartment

12990 NE 6 AVE, NORTH MIAMI 33161

Inspection Date: 06/21/2022

Inspection Number: 1525543

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330236

4TH STREET COMMONS

License Type: Apartment

10899 SW 4 ST, MIAMI 33174

Inspection Date: 06/24/2022

Inspection Number: 1519738

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: PICO, JORGE

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
Observed the property has Five boilers that produce 500000 btus
- From follow-up inspection 2022-06-24: Observed the operator is waiting for the fire department to come to certify the boilers..
Time Extended

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302683

BRENTWOOD APARTMENTS

License Type: Apartment

1660 NE 150 ST, MIAMI 33181

Inspection Date: 06/21/2022

Inspection Number: 1523539

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SUAREZ, LEOPOLDO

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2307837

CENTER COURT APARTMENTS

License Type: Apartment

14795 NE 18 AVE, NORTH MIAMI 33181

Inspection Date: 06/21/2022

Inspection Number: 1516915

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SUAREZ, LEOPOLDO

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2600495

THE PARK AT RIVER CITY

License Type: Apartment

10621 MONACO DR, JACKSONVILLE 32218

Inspection Date: 06/22/2022

Inspection Number: 1522187

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by unit 34 on balcony by door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2603121

APM INN & SUITES JACKSONVILLE

License Type: Motel

510 LN AVE S, JACKSONVILLE 32254

Inspection Date: 06/22/2022

Inspection Number: 1222950

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher by room 347 has needle in recharge zone. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguisher box by room 302, no fire extinguisher.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913678

HYATT PLACE / HYATT HOUSE TAMPA DOWNTOWN

License Type: Hotel

325 N FLORIDA AVE, TAMPA 33602

Inspection Date: 06/20/2022

Inspection Number: 1161835

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: EHLERS, MICHAEL

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
Hot water heaters have a 210 F temperature. 2 boilers with btu over 400,000.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913970

WESTSHORE CROSSING

License Type: Apartment

4515 N ROME AVE, TAMPA 33603

Inspection Date: 06/24/2022

Inspection Number: 1535973

Inspection Type: Complaint Partial

Inspection Disposition: Warning
Issued

Inspector Name: VALENCIA, ASHLEY

Violation Code

Observation

Violation Citation

07-03-4

Scorch marks around an electrical panel meter. For reporting purposes only. Building P outside electric meter panel

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3901297

ALASKA MOTEL

License Type: Motel

1307 E HILLSBOROUGH AVE, TAMPA 336047209

Inspection Date: 06/24/2022

Inspection Number: 1222800

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: COLEMAN, TONYA

Violation Code

Observation

Violation Citation

04-03-4

- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Smoke detector removed from wall room 4. -
From follow-up inspection 2022-06-24: ****Time Extended****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913584

HAMPTON INN & SUITES

License Type: Hotel

1301 E 7 AVE, TAMPA 33605

Inspection Date: 06/20/2022

Inspection Number: 1164045

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: AUDETTE, DAKOTA

Violation Code

Observation

Violation Citation

04-01-4

Observed: Trouble/alarm light illuminated on the fire alarm contro panel. For reporting purposes only.
Priority: Reporting

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913634

QUALITY INN AND SUITES TAMPA FAIRGROUND

License Type: Hotel

4955 E 18 AVE, TAMPA 33605

Inspection Date: 06/22/2022

Inspection Number: 1161052

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: KLUSENDORF, JEANNE

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Room 210

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3902852

THE GODFREY HOTEL AND CABANAS

License Type: Hotel

7700 W COURTNEY CAMPBELL CAUSEWAY, TAMPA 33607

Hillsborough County

Inspection Date: 06/21/2022

Inspection Number: 1164385

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3910835

HYATT PLACE TAMPA AIRPORT/WESTSHORE

License Type: Hotel

4811 W MAIN ST, TAMPA 33607

Inspection Date: 06/21/2022

Inspection Number: 1163209

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913577

EXTENDED STAY AMERICA #1805

License Type: Hotel

4312 W SPRUCE ST, TAMPA 33607

Inspection Date: 06/20/2022

Inspection Number: 1163219

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913627

WESTIN TAMPA BAY

License Type: Hotel

7627 COURTNEY CAMPBELL CAUSEWAY, TAMPA 33607

Inspection Date: 06/20/2022

Inspection Number: 1162267

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation Code

Observation

Violation Citation

08-01-4

Observed: Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Priority: Reporting

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3905288

RED ROOF INN TAMPA FAIRGROUNDS

License Type: Motel

5001 US 301 N, TAMPA 33610

Inspection Date: 06/20/2022

Inspection Number: 1222926

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: COLEMAN, TONYA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only. Repairing in process with work on underground cable.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913927

STANDARD AT TAMPA

License Type: Apartment

2850 UNIVERSITY SQUARE DR, TAMPA 33612

Inspection Date: 06/22/2022

Inspection Number: 1531598

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HARROD, JESSICA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

Fire panel in trouble queue has work order in was struck by lightning.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913897

CORTLAND BAYPORT

License Type: Apartment

10510 PARKER'S LANDING DRIVE, TAMPA 33615

Inspection Date: 06/22/2022

Inspection Number: 1517651

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HARROD, JESSICA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Near apartment 115 building 10611

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3903555

RIVERSIDE PALMS APARTMENTS

License Type: Apartment

5008 SIERRA PL, TAMPA 33617

Inspection Date: 06/22/2022

Inspection Number: 1535730

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: REGAS, ANTHONY

Violation CodeObservationViolation Citation

12-04-4

- From initial inspection : High Priority - 12-04-4 Observed:
Balcony/starway/platform collapsed.

61C-1.004(5) FAC High Priority: All building structural
components, attachments and fixtures shall be kept in
good repair.

Observed the stairwell and platform for building 8413 units
506,606, and 607. Is collapsed. The area is closed and being
blocked by caution tape for the upstairs units. The residents have
been moved to a new apartments. The downstairs unit 506 is safe
per The City of Tampa and the Fire Marshal for tenant to move
back into. City of Tampa and the Fire Marshal have been out and
have cited the Establishment for issues regarding stairway.
Operator states that they are pulling permits and getting bids for
the work to be done.

Establishment on warning from previous inspection callback due
on 7/16/2022. ****Repeat Violation** **Warning**** - From follow-up
inspection 2022-06-22: Still pending permits and bids for repairs
****Time Extended****

Hillsborough County

License Number: 3902682

QUALITY INN TAMPA-BRANDON

License Type: Motel

9331 E ADAMO DR, TAMPA 33619

Inspection Date: 06/22/2022

Inspection Number: 1221953

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MOULDER, BRITTANY

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3912764

CROSSWYNDE APARTMENTS

License Type: Apartment

1502 MARSH COVE CT, TAMPA 33619

Inspection Date: 06/22/2022

Inspection Number: 1535075

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: AUDETTE, DAKOTA

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913615

STAYBRIDGE SUITES TAMPA EAST/BRANDON

License Type: Hotel

3624 N FALKENBURG RD, TAMPA 33619

Hillsborough County

Inspection Date: 06/23/2022

Inspection Number: 1164404

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: KLUSENDORF, JEANNE

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 121762

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 135178

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913629

FAIRFIELD INN & SUITES

License Type: Hotel

6720 LAKEVIEW CENTER DR, TAMPA 33619

Inspection Date: 06/23/2022

Inspection Number: 1164279

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: KLUSENDORF, JEANNE

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913602

TUSCANY BAY APARTMENTS

License Type: Apartment

12065 TUSCANY BAY DR, TAMPA 33626

Inspection Date: 06/20/2022

Inspection Number: 1526691

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913907

5 OAKS AT WESTCHASE

License Type: Apartment

8820 THOMAS OAKS DR, TAMPA 33626

Inspection Date: 06/21/2022

Inspection Number: 1520090

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913591

MALLORY SQUARE APARTMENTS

License Type: Apartment

11306 MALLORY SQUARE DR, TAMPA 33635

Inspection Date: 06/21/2022

Inspection Number: 1521325

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4700001

DES VERGERS APARTMENTS

License Type: Apartment

525 W PARK AVE, TALLAHASSEE 323011449

Inspection Date: 06/21/2022

Inspection Number: 1519261

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing fire extinguisher outside unit 2

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4700325

COLLEGEWOOD

License Type: Apartment

472 W JEFFERSON ST, TALLAHASSEE 323011642

Inspection Date: 06/21/2022

Inspection Number: 1527225

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Outside 108, Florida towers.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4703090

PASCO PLACE APARTMENTS

License Type: Apartment

2115 -2125 PASCO ST, TALLAHASSEE 32310

Inspection Date: 06/20/2022

Inspection Number: 1526251

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. On side of 2121.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5402759

COURTYARD BY MARRIOTT

License Type: Hotel

3031 N ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 06/21/2022

Inspection Number: 1162459

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: MARTINEZ, YANET

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-06-01: At the time of the callback inspection observed troublemaker light on the fire alarm control panel. ****Time Extended**** - From follow-up inspection 2022-06-21: At the time of the callback inspection observed troublemaker light on the fire alarm control panel. ****Time Extended****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811433

BROOKSIDE APTS

License Type: Apartment

3997 ROSEWOOD WAY, ORLANDO 32808

Inspection Date: 06/21/2022

Inspection Number: 1535725

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: MONTGOMERY, DOREEN

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
Boiler in room by building 5225 & boiler in room by building 5365 have no boiler certificates

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811128

KATERINA HOTEL ORLANDO

License Type: Hotel

830 LEE RD, ORLANDO 32810

Inspection Date: 06/20/2022

Inspection Number: 1164620

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONTGOMERY, DOREEN

Violation Code

Observation

Violation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only.

First floor emergency exit door on East side is blocked by tape and sheet rock due to door being broken, unable to access door i or out of property

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811191

TRU BY HILTON ORLANDO CONVENTION CENTER

License Type: Hotel

6461 WESTWOOD BOULEVARD, ORLANDO 32821

Inspection Date: 06/21/2022

Inspection Number: 1162084

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only./ h water heater has capability of 500,000 BTU per hour and requires a boiler certificate. ****Repeat Violation**** - From follow-up inspection 2022-06-21: Current in process of obtaining ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811212

SPOT X HOTEL ORLANDO

License Type: Hotel

12235 REGENCY VILLAGE DR, ORLANDO 32821

Orange County

Inspection Date: 06/21/2022

Inspection Number: 1163703

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. From follow-up inspection 2022-06-21: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-06-4

- From initial inspection : Combustibles stored in boiler room. For reporting purposes only./ paint buckets - From follow-up inspection 2022-06-21: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 06/22/2022

Inspection Number: 1164639

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: BORRERO, AUDREY

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5908462

BOHEMIAN HOTEL CELEBRATION

License Type: Hotel

700 BLOOM ST, CELEBRATION 34747

Inspection Date: 06/23/2022

Inspection Number: 1164589

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: IRVEN, RYAN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

Osceola County

Inspection Date: 06/21/2022

Inspection Number: 1164632

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. By room 130

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing striker by room 265

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. HSKP manager replaced. **Corrected On-Site**	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	---

Osceola County

License Number: 5912073

WOODSPRING SUITES ORLANDO KISSIMMEE #8108

License Type: Hotel

7727 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34747

Inspection Date: 06/24/2022

Inspection Number: 1164242

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6200643

WHITNEY HOTEL

License Type: Hotel

241 3RD STREET N., ST. PETERSBURG 33701

Inspection Date: 06/24/2022

Inspection Number: 1163915

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: MURPHY, JAMES

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher on second floor outside of room 232 is in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6203064

TRADEWINDS SANDPIPER BEACH RESORT

License Type: Motel

6000 GULF BLVD, ST. PETE BEACH 33706

Inspection Date: 06/21/2022

Inspection Number: 1221721

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6205531

DON CESAR HOTEL

License Type: Hotel

3400 GULF BLVD, ST.PETE BEACH 33706

Inspection Date: 06/23/2022

Inspection Number: 1160578

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAY-WALKER, LISA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 130629, 130614 3/9/2022 expired. Employee corrected boiler certificates during inspection 130629 3/9/2024 , 135618 3/09/24 **Corrected On-Site**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6209245

MELROSE ON THE BAY (M-O) OWNER LLC

License Type: Apartment

16321 BOLESTA RD, CLEARWATER 33760

Inspection Date: 06/23/2022

Inspection Number: 1520230

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LOZANO, KELVIN

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
By units 5141-84, 5056-144

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6209445

ELMCROFT OF PINECREST

License Type: Apartment

1150 8 AVE SW, LARGO 33770

Pinellas County

Inspection Date: 06/22/2022

Inspection Number: 1514886

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GUTTERMAN, KENNETH

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215317

STRATFORD COURT OF PALM HARBOR

License Type: Apartment

45 KATHERINE BLVD, PALM HARBOR 34684

Inspection Date: 06/22/2022

Inspection Number: 1530635

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BENEDICT, TRACY

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Expired 06/27/2021

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215666

SAVANNAH COVE APARTMENTS

License Type: Apartment

1124 LAUREN LN, TARPON SPRINGS 34689

Inspection Date: 06/23/2022

Inspection Number: 1535182

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: AIELLO, ROCCI

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Operator states repairs are being made. And they have their fire inspection scheduled for next month. On July 18th

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804029

WARM MINERAL SPRING MOTEL

License Type: Motel

12597 TAMIAMI TRL S, NORTH PORT 34287

Inspection Date: 06/23/2022

Inspection Number: 1217974

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: KNORR, DAVID

Violation CodeObservationViolation Citation

02-07-4

Flammables stored near a source of ignition. Observed fold away mattress and linens stored right next to the gas water heater. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903988

J HOMES N COURTS LLC

License Type: Motel

2564 PARK DR, SANFORD 32773

Inspection Date: 06/20/2022

Inspection Number: 1221169

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. At the office car port, at Apts 8&9,

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501628

HILTON HOTEL

License Type: Hotel

32 AVENIDA MENENDEZ, SAINT AUGUSTINE 32084

Inspection Date: 04/25/2022

Inspection Number: 1162479

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HARTMANN, MICHELLE

Violation CodeObservationViolation Citation

05-02-5

Reporting --Observed: Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
Hearing impaired detector in room 127 is not blinking. **Warning*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400503

BAYMONT INN & SUITES

License Type: Motel

2725 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 06/21/2022

Inspection Number: 1222791

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fir alarm control panel. For reporting purposes only. - From follow-up inspection 2022-05-18: Maintenance states fire alarm company has been called
Manager states are under a fire watch. Stated someone cut wires . - From follow-up inspection 2022-06-21: Per manager tech is still repairing

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400525

PLAZA RESORT & SPA

License Type: Hotel

600 N ATLANTIC AVE, DAYTONA BEACH 32118

Volusia County

Inspection Date: 06/21/2022

Inspection Number: 1163430

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. -laundry room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
06-01-4	Path to door marked as an exit is blocked. For reporting purposes only. -marked door next to 211	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

08-01-4 Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

-6/17/2022

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400829

PARADISE 770

License Type: Motel

2401 N ATLANTIC AVE, DAYTONA BEACH 32118

Volusia County

Inspection Date: 06/20/2022

Inspection Number: 1219812

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

02-04-4

Gas tanks stored inside the building. For reporting purposes only
Corrected On-Site

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

02-07-4

Flammable/combustible chemicals stored near a source of ignition. For reporting purposes only.

Gasoline can, gasoline powered equipment stored next to water heater in boiler room.

Manager removed from room during inspection **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

08-08-4	Vent stack for gas water heater in disrepair. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

License Number: 7406446	BLACK DOLPHIN INN
License Type: Bed and Breakfast	916 S RIVERSIDE DR, NEW SMYRNA BEACH 32168

Inspection Date: 06/20/2022	Inspection Number: 1094765	Inspection Type: Routine - Lodging	Inspection Disposition: Warning Issued
Inspector Name: PICHARDO, RENEE			

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.