

Alachua County

License Number: 1103006

THE 400 APARTMENTS

License Type: Apartment

400 NW 1 AVE, GAINESVILLE 32601

Inspection Date: 06/29/2022

Inspection Number: 1526341

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Observed no boiler certificate. - From follow-up inspection 2022-06-29: Scheduled for July 7, 2002. **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1304557

LAQUINTA INN AND SUITES

License Type: Hotel

1030 E 23 ST, PANAMA CITY 32405

Inspection Date: 07/01/2022

Inspection Number: 1164679

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expired 6-18-22.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505677

LA QUINTA INN & SUITES OCEANFRONT

License Type: Hotel

1 HENDRY AVE, COCOA BEACH 32931

Inspection Date: 07/01/2022

Inspection Number: 1164655

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: VAUGHAN, COURTNEY

Violation Code

Observation

Violation Citation

04-01-4 - From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-07-01: operator has someone coming 7/6 to fix. **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4 Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305910

WESTLAND 49 APARTMENTS

License Type: Apartment

1337 W 49 PLACE, HIALEAH 33012

Inspection Date: 06/27/2022

Inspection Number: 1529218

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed fire extinguisher next to elevators on first floor of building 1333 missing breakage device.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed in building 1337

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2311803

CONSORT APARTMENT

License Type: Apartment

909 NW 45 AVE, MIAMI 331262495

Inspection Date: 06/27/2022

Inspection Number: 1513356

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at fire extinguisher located ext to laundry room across from apartment # 101 and also across from apartment # 106.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329660

BVG

License Type: Apartment

5601 NW 1 AVE, MIAMI 33127

Inspection Date: 06/27/2022

Inspection Number: 1535812

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: SAENZ, HILDA

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. observed at apartment #39, # 9, next to laundry room. Next to apt # 1. Building 55. Apartment #15. apartment # 1. Next to laundry room by garbage area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2300289

ORANGE HOUSE

License Type: Apartment

335 NW 12 AVE, MIAMI 33128

Inspection Date: 06/27/2022

Inspection Number: 1519141

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SUAREZ, LEOPOLDO

Violation Code

Observation

Violation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2314753

HILTON MIAMI DOWNTOWN

License Type: Hotel

1601 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 06/29/2022

Inspection Number: 1161662

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Observed boiler certificate expired on 6-29-2022. As per Chief Engineer, inspection was completed on 6-23-2022 and have not received the boiler certificates.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329803

SHORECREST CLUB

License Type: Apartment

7950 NE BAYSHORE CT, MIAMI 33138

Inspection Date: 06/27/2022

Inspection Number: 1527145

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613256

THE FINLEY

License Type: Apartment

9541 103 ST, JACKSONVILLE 32210

Inspection Date: 06/29/2022

Inspection Number: 1526740

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BADDING, MELANIE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In unit 314. On first floor of building 10.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2600646

ZEN LIVING SUITES

License Type: Motel

5649 CAGLE RD, JACKSONVILLE 32216

Inspection Date: 06/29/2022

Inspection Number: 1222871

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: VILBRUN, JOSUE

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher discharged next to room 215

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Fire extinguisher missing from area next to room 213 & 260

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2609107

DAYS INN JACKSONVILLE AIRPORT

License Type: Hotel

1170 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 06/27/2022

Inspection Number: 1164555

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

04-02-4

- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only.
No alarm in room 109. ****Warning**** - From follow-up inspector
2022-06-27: Room occupied ****Time Extended****

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705808

ALABASTER GARDENS APTS

License Type: Apartment

929 MASSACHUSETTS AVE, PENSACOLA 32505

Inspection Date: 06/28/2022

Inspection Number: 1516649

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ALBRITTON, GREGORY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to apartment 4104.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705438

LONNIE WILLIAMSON

License Type: Apartment

1009 N 69TH AVE, PENSACOLA 32506

Inspection Date: 06/28/2022

Inspection Number: 1532080

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BARNARD, JOHN

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only. Low cable back side of apartment B.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705768

ROSE HOLLOW APARTMENTS

License Type: Apartment

10836 W HWY 98, PENSACOLA 32506

Inspection Date: 06/28/2022

Inspection Number: 1519625

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BARNARD, JOHN

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only. Low hanging electrical wire between units 10838-10842. Broken cable boxes outside apartments 10856 and between 10836 and 10838.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705559

BARRANCAS VILLAS

License Type: Apartment

3386 BARRANCAS AVE, PENSACOLA 32507

Inspection Date: 06/29/2022

Inspection Number: 1519848

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between apartment 10 and 11.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705388

FOUR SEASONS TOWNHOMES

License Type: Apartment

618 S 72 AVE, PENSACOLA 32534

Inspection Date: 06/10/2022

Inspection Number: 1513705

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BARNARD, JOHN

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
Building 628 apartment 2, two cable box covers on ground.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800155

OCEAN SHORE VILLA

License Type: Motel

6287 N OCEAN SHORE BLVD, PALM COAST 321372412

Inspection Date: 06/27/2022

Inspection Number: 1222664

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PERKINS, MARC

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only. Under the stairwell closest to the entrance to the property by the main road, propane gas tank stored under the stairwell.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hernando County

License Number: 3700963

FAIRFIELD BY MARRIOTT INN & SUITES SUNCOAST PARKWAY

License Type: Hotel

14082 CORTEZ BLVD., BROOKSVILLE 34609

Inspection Date: 06/30/2022

Inspection Number: 1164057

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: DAHL, MICHELE

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Hard wired smoke alarm in ADA room 207, 307, 123, not working. Notice on test button on door says to hold for 5 seconds, button was held for 10 seconds, still did not work.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3905879

WESTIN HARBOUR ISLAND

License Type: Hotel

725 S HARBOUR ISLAND BLVD, TAMPA 33602

Inspection Date: 06/28/2022

Inspection Number: 1163713

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: EHLERS, MICHAEL

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3912228

TAMPA MARRIOTT WATERSTREET

License Type: Hotel

700 S FLORIDA AVE, TAMPA 33602

Inspection Date: 06/28/2022

Inspection Number: 1164062

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. 1 missing/not posted in downstairs boiler room.
Repeat Violation

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913675

JW MARRIOTT TAMPA WATER STREET

License Type: Hotel

510 WATER ST, TAMPA 33602

Inspection Date: 06/28/2022

Inspection Number: 1164472

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913682

ROOST TAMPA

License Type: Hotel

1050 WATER ST, TAMPA 33602

Inspection Date: 07/01/2022

Inspection Number: 1164499

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: EHLERS, MICHAEL

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
Tanks with temperature of 210 and heat input of 500,000 BTU. 7t floor. There are also 2 boilers on the roof.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913605

OAKS AT RIVERVIEW

License Type: Apartment

202 E BROAD ST, TAMPA 33604

Inspection Date: 06/30/2022

Inspection Number: 1535455

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: VALENCIA, ASHLEY

Violation Code

Observation

Violation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By unit 102A 103 - From follow-up inspection 2022-06-30: Missing from location 102A 103

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-02-4

- From initial inspection : Frayed electrical wire(s). For reporting purposes only. Internet provider box building 110 - From follow-up inspection 2022-06-30: Internet provider box building 11
Time Extended

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3903555

RIVERSIDE PALMS APARTMENTS

License Type: Apartment

5008 SIERRA PL, TAMPA 33617

Inspection Date: 06/29/2022

Inspection Number: 1535730

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: REGAS, ANTHONY

Violation Code

Observation

Violation Citation

12-04-4

- From initial inspection : High Priority - 12-04-4 Observed:
Balcony/starway/platform collapsed.

61C-1.004(5) FAC High Priority: All building structural
components, attachments and fixtures shall be kept in
good repair.

Observed the stairwell and platform for building 8413 units
506,606, and 607. Is collapsed. The area is closed and being
blocked by caution tape for the upstairs units. The residents have
been moved to a new apartments. The downstairs unit 506 is safe
per The City of Tampa and the Fire Marshal for tenant to move
back into. City of Tampa and the Fire Marshal have been out and
have cited the Establishment for issues regarding stairway.
Operator states that they are pulling permits and getting bids for
the work to be done.

Establishment on warning from previous inspection callback due
on 7/16/2022. ****Repeat Violation**** ****Warning**** - From follow-up
inspection 2022-06-22: Still pending permits and bids for repairs
****Time Extended**** - From follow-up inspection 2022-06-29: Still
pending permits and bids for repairs. ****Time Extended****

Lake County

License Number: 4500304

OAKWOOD MOTEL

License Type: Motel

2110 CITRUS BLVD, LEESBURG 34748

Inspection Date: 06/29/2022

Inspection Number: 1222109

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only.

-operator states line is dead, in front of managers unit

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-08-4

Vent stack for gas water heater disconnected/in disrepair. For reporting purposes only.

-behind unit 1-5

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

Lee County

License Number: 4604205

THE MERIDIAN AT 2825

License Type: Apartment

2825 CENTRAL AVE, FORT MYERS 33901

Lee County

Inspection Date: 06/28/2022

Inspection Number: 1535967

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WALTER, KAYLA

Violation CodeObservationViolation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher in 3rd floor laundry room as in recharg zone. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguisher in second floor laundry room as missing. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

01-03-4

- From initial inspection : Observed: Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguisher as missing in 2nd floor Laundry room.
Priority: Reporting - From follow-up inspection 2022-06-28: Observed fire extinguisher as missing in second floor laundry room. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4703231

VILLAGE TRACE APARTMENTS

License Type: Apartment

3291-3299 MISSION RD, TALLAHASSEE 32303

Inspection Date: 06/30/2022

Inspection Number: 1536028

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TRUESDALE, CHRIS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher at building 3299 pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105024

WATERLINE MARINA RESORT AND BEACH CLUB

License Type: Hotel

5325 MARINA DR, HOLMES BEACH 34217

Inspection Date: 06/29/2022

Inspection Number: 1164316

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PIPIC, DINKA

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
No boiler certificate provided.

As a repeat violation the importance of following proper protocol with this violation was reinforced with the employee. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403243

142 OCEAN VIEW LLC

License Type: Apartment

142 OCEAN BAY DR, KEY LARGO 33037

Inspection Date: 06/28/2022

Inspection Number: 1522211

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Located near unit 1.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5402153

MARGARITAVILLE BEACH HOUSE KEY WEST

License Type: Hotel

2001 ROOSEVELT BLVD, KEY WEST 33040

Inspection Date: 06/28/2022

Inspection Number: 1161724

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SANCHEZ, JAVIER

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5403068

AUTHORS KEY WEST GUESTHOUSE

License Type: Motel

725 WHITE ST, KEY WEST 33040

Inspection Date: 06/28/2022

Inspection Number: 1218973

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only located by the office.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400320

EL PATIO MOTEL

License Type: Motel

800 WASHINGTON ST, KEY WEST 330404799

Inspection Date: 06/28/2022

Inspection Number: 1222726

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SUAREZ, LEOPOLDO

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603637

SOMERSET BEACHSIDE APARTMENTS WEST BUILDING

License Type: Apartment

480 SANTA ROSA BLVD, FORT WALTON BEACH 32548

Inspection Date: 06/27/2022

Inspection Number: 1529524

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near 211 & 210, near 103 & 104.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811133

ECONOLOGDE

License Type: Hotel

7102 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 07/01/2022

Inspection Number: 1165488

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5913628

VIVO LIVING KISSIMMEE

License Type: Apartment

4018 W VINE ST, KISSIMMEE 34741

Inspection Date: 06/29/2022

Inspection Number: 1535423

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: DAVIS, DIANNA

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Awaiting fire marshal to certify.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

Osceola County

Inspection Date: 06/27/2022

Inspection Number: 1164668

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. By room 643

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing striker by room 544

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5913567

THE GRAND AT WESTSIDE

License Type: Apartment

3250 DOUGLAS GRAND DR, KISSIMMEE 34747

Inspection Date: 06/29/2022

Inspection Number: 1536018

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6007059

ADVENIR AT LA COSTA

License Type: Apartment

4101 MAHOGANY DR, BOYNTON BEACH 33436

Inspection Date: 06/29/2022

Inspection Number: 1536062

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: AHLE, ROBERT

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Observe at apt 15205

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Observe at apt 15205 - From follow-up inspection 2022-06-30:
Time Extended

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6100019

CHAMPION INN

License Type: Motel

1131 US HWY 19, HOLIDAY 34691

Inspection Date: 06/27/2022

Inspection Number: 1222054

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: BEACHAM, MICHELLE

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Operator replaced smoke detector during inspection **Corrected On-Site**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6202843

801 GROVE STREET N

License Type: Apartment

801 GROVE ST N, ST PETERSBURG 33701

Inspection Date: 06/27/2022

Inspection Number: 1520320

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MURPHY, JAMES

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside of unit above laundry room in rear of property.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6203986

COLONY APARTMENTS

License Type: Apartment

301 4 AVE N, ST. PETERSBURG 33701

Inspection Date: 06/22/2022

Inspection Number: 1528234

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: RANVILLE, AMANDA

Violation Code

Observation

Violation Citation

07-02-4

Frayed electrical wire(s). For reporting purposes only. At front of building on west side.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6206004

RIO VISTA VILLAGE

License Type: Apartment

200 78 AVE N, ST. PETERSBURG 33702

Inspection Date: 06/29/2022

Inspection Number: 1528805

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LOZANO, KELVIN

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No mallet to break glass by unit 2-42, 17-241

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215866

VANTAGE POINT CONDOMINIUMS

License Type: Apartment

10200 GANDY BLVD, ST. PETERSBURG 33702

Inspection Date: 06/28/2022

Inspection Number: 1528268

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LOZANO, KELVIN

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
By 5-525

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6300431

PRESBYTERIAN APARTMENTS

License Type: Apartment

530 S FLORIDA AVE, LAKELAND 338015281

Inspection Date: 06/27/2022

Inspection Number: 1530138

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITE, CHERYL

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired.
Expired 3/3/22 For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Santa Rosa County

License Number: 6700064

BREEZE APARTMENTS

License Type: Apartment

75 NIGHTINGALE LN, GULF BREEZE 325614301

Inspection Date: 06/27/2022

Inspection Number: 1530937

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ALBRITTON, GREGORY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between apartments 215/216.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900385

ALTAMONTE SPRINGS HOTEL & SUITES

License Type: Motel

450 DOUGLAS RD, ALTAMONTE SPRINGS 32714

Inspection Date: 06/22/2022

Inspection Number: 1222879

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: VALERIO, GRACE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
- At top of stairs for third floor near room 284.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602518

HILTON GARDEN INN AT PGA VILLAGE

License Type: Hotel

8540 COMMERCE CENTRE DR, PORT ST LUCIE 34986

Inspection Date: 06/30/2022

Inspection Number: 1164646

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406510

VILLAGES AT HALIFAX

License Type: Apartment

121 NORMA DR, DAYTONA BEACH 32114

Inspection Date: 06/29/2022

Inspection Number: 1516186

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
-main panel in office Alarm and silence lights on

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401047

1915 BEACH CLUB

License Type: Motel

1915 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 06/27/2022

Inspection Number: 1220960

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

02-04-4

Helium tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only.

-stored inside small storage room across from unit 6 **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400715

GRAND PRIX MOTEL

License Type: Motel

2015 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Volusia County

Inspection Date: 06/27/2022

Inspection Number: 1220165

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

02-04-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. -unit 46	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

08-06-4	Combustibles stored in boiler room. For reporting purposes only. -2 full size propane tanks stored a few feet from gas water heater with vent stack. Manager removed **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

License Number: 7400051	DAYS INN SPEEDWAY	
License Type: Motel	2904 W INTL SPEEDWAY BLVD, DAYTONA BEACH 32124	
Inspection Date: 06/28/2022	Inspection Number: 1222959	Inspection Type: Complaint Full
Inspector Name: COREY, DEREK		Inspection Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
01-05-4	Portable fire extinguisher obstructed/not accessible. For reporting purposes only. -cabinet hammer missing from fire extinguisher cabinet at top of stairway in front of room #223	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406069

MARCELLE APARTMENTS

License Type: Apartment

119 MARCELLE AVE, PORT ORANGE 32127

Inspection Date: 07/01/2022

Inspection Number: 1550871

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.

-near meter boxes, ac units on north end of blue building

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406631

INTEGRA 289 EXCHANGE

License Type: Apartment

115 INTEGRA RESERVE LN, DEBARY 32713

Inspection Date: 06/29/2022

Inspection Number: 1533402

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: OCASIO-LOPEZ, LISA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.
159 carriage home.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.