

Bay County

License Number: 1304835

HAMPTON INN PANAMA CITY BEACH

License Type: Motel

2909 THOMAS DR, PANAMA CITY BEACH 32408

Inspection Date: 07/07/2022

Inspection Number: 1224793

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Extinguisher on floor in laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1502331

LAKE POINTE APARTMENT HOMES

License Type: Apartment

2880 N WICKHAM RD, MELBOURNE 32935

Inspection Date: 07/05/2022

Inspection Number: 1537247

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: VAUGHAN, COURTNEY

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Expired on 10/26/2020 for both boilers.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621796

50 SE 12TH STREET, LLC

License Type: Apartment

50 SE 12TH ST, FORT LAUDERDALE 33316

Inspection Date: 07/07/2022

Inspection Number: 1512910

Inspection Type: Lodging-Licensing

Inspection Disposition: Call Back -

Inspector Name: BRANN, JUSTIN

Inspection

Complied

Violation Code

Observation

Violation Citation

07-01-4

- From initial inspection : Dangling electrical wire(s) from missing Exit sign by Apt 14. For reporting purposes only. - From follow-up inspection 2022-07-07: Dangling electrical wire(s) from missing Exit sign by Apt 14. For reporting purposes only. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329463

EL CORTIJO LLC

License Type: Apartment

935 NW 37 AVE, MIAMI 33125

Inspection Date: 07/07/2022

Inspection Number: 1552859

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: SAENZ, HILDA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. observed at the fire extinguisher next to the mailboxes.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309283

11 AVENUE APARTMENTS LLC

License Type: Apartment

301-311 SW 11 AVENUE, MIAMI 33130

Inspection Date: 07/07/2022

Inspection Number: 1550253

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only.
Observed at fire extinguisher in building 301 next to unit 5 missing breaking device.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329499

CITIZENM

License Type: Hotel

11 SE 10 ST, MIAMI 33131

Inspection Date: 07/08/2022

Inspection Number: 1166026

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
At the time of the inspection observed three boilers with an input rating of 700,000 btu. No boiler certificate provided. All located on the 19th floor.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2313981

COURTYARD BY MARRIOTT

License Type: Motel

200 SE 2 AVE, MIAMI 331312106

Inspection Date: 07/08/2022

Inspection Number: 1223248

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. Operator placed the boiler certificates in the boiler room during the inspection. ****Corrected On-Site****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328452

COURTYARD BY MARRIOTT

License Type: Hotel

1530 WASHINGTON AVE, MIAMI BEACH 33139

Inspection Date: 07/05/2022

Inspection Number: 1166034

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. Observed boiler jurisdiction number's 094477 & 094566; All expired on 5/28/2022. As per boiler safety search, Division of State Fire Marshall, boilers are in the process of being replaced. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329347

1355 DREXEL AVENUE LLC

License Type: Hotel

1355 57 DREXEL AVE, 440 14 ST, MIAMI BEACH 33139

Inspection Date: 07/01/2022

Inspection Number: 1164659

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2319933

EMBASSY SUITES HOTEL MIAMI AIRPORT

License Type: Hotel

3974 NW SOUTH RIVER DR, MIAMI 33142

Inspection Date: 07/07/2022

Inspection Number: 1164826

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302711

NEWPORT BEACHSIDE HOTEL & RESORT

License Type: Motel

16701 COLLINS AVE, SUNNY ISLES BEACH 33160

Inspection Date: 07/07/2022

Inspection Number: 1222986

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler 041086-Expired 6/24/22. As per Chief Engineer hotel has inspection scheduled.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2315878

DBA SUMMER GROVE

License Type: Apartment

10307 CORAL WAY, MIAMI 33165

Inspection Date: 07/07/2022

Inspection Number: 1539271

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Located near unit 202 at building 10323, near unit 203 at 10313 building and near unit 203 at 10303 building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device available near unit 203at 10319 building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329360

SPRINGHILL HOTEL

License Type: Hotel

3895 NW 107 AVE, DORAL 33178

Inspection Date: 07/07/2022

Inspection Number: 1166412

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

DeSoto County

License Number: 2400003

ECONOMY INN

License Type: Motel

324 S BREVARD AVE, ARCADIA 342664309

Inspection Date: 07/05/2022

Inspection Number: 1224354

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. : unit 112.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613488

THE SAGEFIELD APARTMENTS

License Type: Apartment

13283 N MAIN ST, JACKSONVILLE 32218

Inspection Date: 07/07/2022

Inspection Number: 1536076

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: PERRY, DENNIS

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
 Fire extinguisher by gym in lobby.
 Fire extinguisher by unit 2135.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.
 Elevator system states communication failure - Elevator 1 by unit 2139.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913970

WESTSHORE CROSSING

License Type: Apartment

4515 N ROME AVE, TAMPA 33603

Inspection Date: 07/05/2022

Inspection Number: 1535973

Inspection Type: Complaint Partial

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: VALENCIA, ASHLEY

Violation CodeObservationViolation Citation

07-03-4

- From initial inspection : Scorch marks around an electrical pane meter. For reporting purposes only. Building P outside electric meter panel - From follow-up inspection 2022-07-05: Electric meter was replaced for building P, but scorch marks are still present. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3906143

LA QUINTA INN AND SUITES

License Type: Motel

4811 US HWY 301 N, TAMPA 33610

Inspection Date: 07/05/2022

Inspection Number: 1222778

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: COLEMAN, TONYA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3903555

RIVERSIDE PALMS APARTMENTS

License Type: Apartment

5008 SIERRA PL, TAMPA 33617

Hillsborough County

Inspection Date: 07/06/2022

Inspection Number: 1535730

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: REGAS, ANTHONY

Violation Code

Observation

Violation Citation

Hillsborough County

12-04-4

- From initial inspection : High Priority - 12-04-4 Observed:
Balcony/starway/platform collapsed.

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Observed the stairwell and platform for building 8413 units 506,606, and 607. Is collapsed. The area is closed and being blocked by caution tape for the upstairs units. The residents have been moved to a new apartments. The downstairs unit 506 is safe per The City of Tampa and the Fire Marshal for tenant to move back into. City of Tampa and the Fire Marshal have been out and have cited the Establishment for issues regarding stairway. Operator states that they are pulling permits and getting bids for the work to be done.

Establishment on warning from previous inspection callback due on 7/16/2022. ****Repeat Violation**** ****Warning**** - From follow-up inspection 2022-06-22: Still pending permits and bids for repairs ****Time Extended**** - From follow-up inspection 2022-06-29: Still pending permits and bids for repairs. ****Time Extended**** - From follow-up inspection 2022-07-06: Observed the stairwell and platform for building 8413 units 506,606, and 607. Is collapsed. The area is closed and being blocked by caution tape for the upstairs units. The residents have been moved to a new apartments. The downstairs unit 506 is safe per The City of Tampa and the Fire Marshal for tenant to move back into. City of Tampa and the Fire Marshal have been out and have cited the

Hillsborough County

Establishment for issues regarding stairway. Operator states that they are pulling permits and getting bids for the work to be done. Establishment on warning from previous inspection callback due on 7/16/2022. ****Admin Complaint****

License Number: 3912329

HILTON GARDEN INN TAMPA NORTH

License Type: Hotel

13305 TAMPA OAKS BLVD, TEMPLE TERRACE 33637

Inspection Date: 07/05/2022

Inspection Number: 1163182

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back - Complied

Inspector Name: REGAS, ANTHONY

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed the boiler certificate expired 3-17-22, Jurisdiction 12451
 - From follow-up inspection 2022-06-01: Observed the boiler certificate not renewed. ****Time Extended**** - From follow-up inspection 2022-07-05: Boiler certificate still expired. ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301448

HAMPTON INN & SUITES STUART

License Type: Hotel

1150 NW FEDERAL HWY, STUART 34994

Inspection Date: 07/08/2022

Inspection Number: 1166398

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only. Main lobby

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810970

TRAVEL LODGE

License Type: Motel

7200 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 07/08/2022

Inspection Number: 1224194

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: MANTI, KATHRYN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5805779

COURTYARD BY MARRIOTT

License Type: Hotel

8600 AUSTRIAN COURT, ORLANDO 328199343

Inspection Date: 07/08/2022

Inspection Number: 1166661

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: LUI, SUK HAN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
093796/expired 5/13/2022
130444/expired 5/13/2022

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801553

DAYS INN ORLANDO

License Type: Motel

2500 W 33 ST, ORLANDO 32839

Orange County

Inspection Date: 07/06/2022

Inspection Number: 1222732

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: PASIECKI, VICTORIA

Violation CodeObservationViolation Citation

01-02-4	<p>- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 4th floor near elevator, located in fire ho box</p> <p>- From follow-up inspection 2022-07-06: **Time Extended</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
08-01-4	<p>- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.</p> <p>053116- 2/4/22 - From follow-up inspection 2022-07-06: **Tim Extended**</p>	<p>61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.</p> <p>509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Osceola County

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 07/08/2022

Inspection Number: 1167011

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ Ground fault at main fire panel

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900724

ONE WAY MAINGATE HOTEL

License Type: Motel

2930 POLYNESIAN ISLE BLVD, KISSIMMEE 34746

Inspection Date: 07/08/2022

Inspection Number: 1219725

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-06-03: **Time Extended** - From follow-up inspection 2022-07-08: building under renovation at this time . **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911043

BEST WESTERN PLUS INN & SUITES

License Type: Hotel

3484 POLYNESIAN ISLE BLVD, KISSIMMEE 34746

Inspection Date: 07/05/2022

Inspection Number: 1162626

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: LORENZO, ANA

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-06-03: **Time Extended** - From follow-up inspection 2022-07-05: operator working on getting fire panel lights fixed . **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6003083

1200 & 1400 BROADWAY LLC

License Type: Apartment

1200 S BROADWAY, LANTANA 33462

Inspection Date: 07/06/2022

Inspection Number: 1546704

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PITRE, ASTRID

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge at unit 209. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6201541

EMPRESS MOTEL AND APARTMENTS

License Type: Motel

1501 9 ST N, ST. PETERSBURG 33704

Inspection Date: 07/06/2022

Inspection Number: 1222937

Inspection Type: Lodging-Licensing

Inspection Disposition: Warning

Inspector Name: LOZANO, KELVIN

Inspection

Issued

Violation CodeObservationViolation Citation

01-02-4

Observed: Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
 Outside of room 104
 Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6303266

IMPERIAL SWAN HOTEL & SUITES

License Type: Hotel

4141 S FLORIDA AVE, LAKE LAND 33813

Inspection Date: 07/05/2022

Inspection Number: 1164672

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: VELAZQUEZ, STEPHANIE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
4th floor corridor

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Putnam County

License Number: 6400067

ECONOMY INN

License Type: Motel

257 N HWY 17, PALATKA 32177

Inspection Date: 07/05/2022

Inspection Number: 1222992

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: BADDING, MELANIE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing hammer from locked fire extinguisher box by unit 16.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

Seminole County

License Number: 6903992

THE WESTIN LAKE MARY, ORLANDO NORTH

License Type: Hotel

2974 INTERNATIONAL PKWY, LAKE MARY 32746

Seminole County

Inspection Date: 07/05/2022

Inspection Number: 1162571

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

04-01-4	<p>- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Alarm is in trouble - From follow-up inspection 2022-07-05: Alarm in trouble 2 fault ball room #4 1 photo detector **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
08-01-4	<p>- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2022-07-05: Certificates are expired **Time Extended**</p>	<p>61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Seminole County

License Number: 6900006

SERENITY TOWERS ON THE ST JOHNS

License Type: Apartment

519 E 1 ST, SANFORD 32771

Inspection Date: 07/06/2022

Inspection Number: 1523483

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificates expired 01/09/2022. - From follow-up inspection 2022-07-06: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6904053

ALEXANDER AT SABAL POINT

License Type: Apartment

2700 SABAL ALEXANDER CIR, LONGWOOD 32779

Inspection Date: 07/06/2022

Inspection Number: 1524430

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fir
alarm control panel. For reporting purposes only.
System is in trouble - From follow-up inspection 2022-07-06:
System in trouble **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501018

QUALITY INN & SUITES

License Type: Motel

901 A1A BEACH BLVD, SAINT AUGUSTINE 32080

Inspection Date: 07/06/2022

Inspection Number: 1222972

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GROTZ, CINDY

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Inspector observed smoke detectors removed from ceiling in rooms 213, and 219.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Taylor County

License Number: 7200002

REGENCY INN

License Type: Motel

2277 S BYRON BUTLER PKWY, PERRY 32348

Inspection Date: 07/08/2022

Inspection Number: 1225423

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WARD, JOWANNA

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only. Missing in room 103 & 108.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400012

BEACHSIDE APARTMENTS

License Type: Apartment

416 N. GRANDVIEW AVE., DAYTONA BEACH 32118

Inspection Date: 07/05/2022

Inspection Number: 1544296

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

-breakable box missing device to access, next to unit 14 on wall

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400060

SANDALS INN

License Type: Motel

133 S OCEAN AVE, DAYTONA BEACH 32118

Inspection Date: 07/01/2022

Inspection Number: 1225215

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

-next to unit 103

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7402722

OCEAN VIEW APARTMENTS

License Type: Apartment

1825 N. ATLANTIC AVE., DAYTONA BEACH 32118

Inspection Date: 07/08/2022

Inspection Number: 1537776

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

-box on wall next to 307-308

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400715

GRAND PRIX MOTEL

License Type: Motel

2015 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 07/08/2022

Inspection Number: 1220165

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

04-02-4

- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only.

-unit 46 - From follow-up inspection 2022-07-08: **Time Extended**

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401000

BEST WESTERN AKU TIKI INN

License Type: Motel

2225 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Volusia County

Inspection Date: 07/06/2022

Inspection Number: 1222987

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GUTTERMAN, KENNETH

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
From follow-up inspection 2022-07-06: ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401437

SAN MARINA MOTEL

License Type: Motel

1001 N ATLANTIC AVE, DAYTONA BCH 321183626

Inspection Date: 07/07/2022

Inspection Number: 1225299

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location
(sign present indicating designated location). For reporting
purposes only.

-next to 214

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400051

DAYS INN SPEEDWAY

License Type: Motel

2904 W INTL SPEEDWAY BLVD, DAYTONA BEACH 32124

Inspection Date: 07/05/2022

Inspection Number: 1222959

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: COREY, DEREK

Violation Code

Observation

Violation Citation

01-05-4	- From initial inspection : Portable fire extinguisher obstructed/no accessible. For reporting purposes only. -cabinet hammer missing from fire extinguisher cabinet at top of stairway in front of room #223 - From follow-up inspection 2022-07-05: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-05-4	- From initial inspection : Portable fire extinguisher obstructed/no accessible. For reporting purposes only. -cabinet hammer missing from fire extinguisher cabinet at top of stairway in front of room #223 - From follow-up inspection 2022-07-05: **Time Extended** - From follow-up inspection 2022-07-08: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.