

**Bay County**

License Number: 1305255

HYATT PLACE PANAMA CITY BEACH

License Type: Hotel

15727 FRONT BEACH RD, PANAMA CITY BEACH 32413

Inspection Date: 07/15/2022

Inspection Number: 1164559

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: LYNN, NICKOLAS

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1620895

RESIDENCE INN POMPANO BEACH

License Type: Hotel

2880 CENTER PORT CIR, POMPANO BEACH 33064

Inspection Date: 07/12/2022

Inspection Number: 1165328

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: DEJONG, STEVEN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1621644

SOCIETY LAS OLAS

License Type: Apartment

301 SW 1ST AVE, FORT LAUDERDALE 33301

Inspection Date: 07/14/2022

Inspection Number: 1555538

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: BRANN, JUSTIN

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
Next to Apt 1307.  
Ground level outside door next to Stair B.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1621655

SONDER

License Type: Apartment

301 SW 1ST AVE, FORT LAUDERDALE 33301

Inspection Date: 07/14/2022

Inspection Number: 1548878

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: BRANN, JUSTIN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.  
Inspector will email inspection report to Fire Marshall for review.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1615097

BOCA SUITES DEERFIELD BEACH

License Type: Hotel

1040 E NEWPORT CENTER DR, DEERFIELD BEACH 33442

Inspection Date: 07/12/2022

Inspection Number: 1167048

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: DEJONG, STEVEN

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only., second floor room #207.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2102710

SREIT TUSCAN ISLE

License Type: Apartment

8650 WEIR DR, NAPLES 34104

Inspection Date: 07/15/2022

Inspection Number: 1529334

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: GRAVES, PETER

Violation Code

Observation

Violation Citation

01-03-4	- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. The fire extinguisher is missing next to apartment 203 in building 8635 and next to apartment 303 in building 8600. - From follow-up inspection 2022-07-15: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. There is no means of access to the fire extinguisher next to apartment 303 and 307 in building 8635, apartment 101, 203, 207 and 303 in building 8625. There is also no access to the fire extinguisher next to apartment 105 and 113 in building 8615. - From follow-up inspection 2022-07-15: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330856

MARTHA BALBUENA

License Type: Apartment

974 NE 5 AVE, HOMESTEAD 33030

Inspection Date: 07/14/2022

Inspection Number: 1535664

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: LEIDECKER, EDILMA

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located between unit 4 and 5.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329328

HOMEWOOD SUITES MIAMI DOWNTOWN BRICKELL

License Type: Hotel

1750 SW 1 AVE, MIAMI 33129

Inspection Date: 07/11/2022

Inspection Number: 1166686

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2329489

AC & ELEMENT HOTEL BRICKELL MIAMI

License Type: Hotel

115 SW 8 ST, MIAMI 33130

Inspection Date: 07/08/2022

Inspection Number: 1164626

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: CABANAS, NATALIE

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  
At the time of the inspection observed three boilers with a input rating of 700,000 btu and two boilers with a minimum input rating of 900,000. No boiler certificate provided.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2310762

License Type: Apartment

219 SW 5 AVE, MIAMI 331301384

Inspection Date: 07/11/2022

Inspection Number: 1539961

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed at fire extinguisher near unit 7 and unit 1A.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Observed inside meter room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2317880

COMFORT INN AND SUITES DOWNTOWN/BRICKELL

License Type: Hotel

100 SE 4TH ST, MIAMI 33131

Inspection Date: 07/11/2022

Inspection Number: 1165966

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329454

COURTYARD BY MARRIOTT MIAMI COCONUT GROVE

License Type: Hotel

2649 S BAYSHORE DR, MIAMI 33133

Inspection Date: 07/14/2022

Inspection Number: 1165145

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MASKASEM, SUPPACHAI

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 2 boiler's certificate 093160, 097013 expired on 11/14/18.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329207

SPRINGHILL SUITES BY MARRIOTT

License Type: Hotel

1311 NW 10TH AVE, MIAMI 33136

Inspection Date: 07/13/2022

Inspection Number: 1165658

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2301957

BEACH PARK HOTEL

License Type: Hotel

600 OCEAN DR, MIAMI BEACH 331396219

Inspection Date: 07/15/2022

Inspection Number: 1167101

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Located at laundry area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329399

DESIGN SUITES MIAMI BEACH

License Type: Hotel

5445 COLLINS AVE STE CU14, MIAMI BEACH 33140

Inspection Date: 07/14/2022

Inspection Number: 1167093

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: UNZAGA, MILADYS

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate expired since 2/19/2022. Inspection was conducted and certificates payment was submitted. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2330858

SEXTANT STAYS (THE CURRENT)

License Type: Apartment

7939 E DR, MIAMI 33141

Inspection Date: 07/15/2022

Inspection Number: 1555547

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: BROWN, JARON

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





**Dade County**

License Number: 2313482

ARCIA 2028 APARTMENT

License Type: Apartment

2028 NW 30 ST, MIAMI 331425951

Inspection Date: 07/12/2022

Inspection Number: 1541817

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.  
Observed fire extinguisher missing breakage device between unit 7 and 8

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored under a stairwell. For reporting purposes only.  
Observed 20 lb propane tank under stairway across from unit 4

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2329309

FOUR POINT BY SHERATON

License Type: Hotel

3861 BIRD RD, MIAMI 33146

Inspection Date: 07/13/2022

Inspection Number: 1166669

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MASKASEM, SUPPACHAI

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo  
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2313969

WESTWOOD APARTMENTS

License Type: Apartment

3801 SW 112 AVE, MIAMI 331654473

Inspection Date: 07/14/2022

Inspection Number: 1543708

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device provided near unit 52.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2321979

HOLIDAY INN EXPRESS MIAMI AIRPORT DORAL

License Type: Hotel

8436 NW 36 ST, MIAMI 33166

Inspection Date: 07/12/2022

Inspection Number: 1165683

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2301455

DAYS INN MIAMI AIRPORT NORTH

License Type: Motel

4767 NW 36 ST, MIAMI SPRINGS 33166

Inspection Date: 07/12/2022

Inspection Number: 1225464

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguisher with no braking device located between rooms 230 and 231 on Main building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2328943

BEST WESTERN PLUS MIAMI DORAL

License Type: Motel

3875 NW 107 AVE, MIAMI 33178

Inspection Date: 07/12/2022

Inspection Number: 1224107

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2600619

GOLDEN SHORES JACKSONVILLE (JASPER)

License Type: Apartment

7703 HARE AVE, JACKSONVILLE 32211

Inspection Date: 07/12/2022

Inspection Number: 1542852

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

Fire extinguisher missing from fire box outside unit 176

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Duval County**

License Number: 2613196

QUALITY INN OF ORANGE PARK

License Type: Motel

6135 YOUNGERMAN CIR, JACKSONVILLE 32244

Inspection Date: 07/13/2022

Inspection Number: 1225466

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
By room 161

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3900037

TAMPA INN

License Type: Motel

2901 E BUSCH BLVD, TAMPA 33612

Inspection Date: 07/12/2022

Inspection Number: 1225425

Inspection Type: Complaint Partial

Inspection Disposition: Warning  
Issued

Inspector Name: CESAR, RACHEL

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Fire extinguishers outside of room 231 and 158.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3913653

HOME 2 SUITES TAMPA USF NEAR BUSCH GARDENS

License Type: Hotel

11606 MCKINLEY DR, TAMPA 33612

Inspection Date: 07/15/2022

Inspection Number: 1163935

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: CESAR, RACHEL

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  
\*\*Warning\*\* - From follow-up inspection 2022-07-15: No boiler certificate present. \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3913629

FAIRFIELD INN & SUITES

License Type: Hotel

6720 LAKEVIEW CENTER DR, TAMPA 33619

Inspection Date: 07/11/2022

Inspection Number: 1164279

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: AUDETTE, DAKOTA

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fir  
alarm control panel. For reporting purposes only. - From  
follow-up inspection 2022-07-11: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Indian River County**

**Indian River County**

---

License Number: 4100985

ECONOLOGDE

License Type: Motel

950 US 1, VERO BCH 32960

**Indian River County**

Inspection Date: 07/11/2022

Inspection Number: 1223821

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SCHUCK, GREGORY

Violation CodeObservationViolation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only. Manager stated that they are doing a walk through of property every hour. Log is being kept. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Leon County**

License Number: 4703234

MAGNOLIA TERRACE

License Type: Apartment

509 E MAGNOLIA DR, TALLAHASSEE 32301

Inspection Date: 06/10/2022

Inspection Number: 1555498

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: TRUESDALE, CHRIS

Violation Code

Observation

Violation Citation

06-03-4

OBSERVED: MARKED EXIT IS INACCESSIBLE. FOR REPORTING PURPOSES ONLY. OBSERVED PATHWAY BLOCKED A CHAIR AND A BBQ PIT NEXT TO BACK DOOR TO UNIT 128.  
PRIORITY: REPORTING

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Leon County**

License Number: 4701621

MOTEL 6 TALLAHASSEE

License Type: Motel

2738 N. MONROE, TALLAHASSEE 32303

Inspection Date: 07/12/2022

Inspection Number: 1225458

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: TRUESDALE, CHRIS

Violation CodeObservationViolation Citation

04-02-4

Unattached smoke detector provided in guest room/unit 421. For reporting purposes only.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5400617

KINGSAIL RESORT MOTEL

License Type: Motel

7050 OVERSEAS HWY, MARATHON 330503140

Inspection Date: 07/14/2022

Inspection Number: 1225196

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: WHITEHURST, SCOTT

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear  
to be inoperable. For reporting purposes only. Unit 122

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603610

TOWNEPLACE SUITES BY MARRIOTT

License Type: Hotel

843 EGLIN PKWY, FORT WALTON BEACH 32547

Inspection Date: 07/13/2022

Inspection Number: 1165209

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **\*\*Repeat Violation\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603616

HILTON GARDEN INN

License Type: Hotel

1297 MIRACLE STRIP PKWY, FORT WALTON BEACH 32548

Inspection Date: 07/14/2022

Inspection Number: 1164676

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Expiration 12/16/21.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5801498

AVANTI PALMS RESORT AND CONFERENCE CENTER

License Type: Hotel

6515 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 07/13/2022

Inspection Number: 1165178

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Establishment currently on fire watch with city Orlando fire. They send a daily report to their fire inspector Jim Powell

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5809236

HOMEWOOD SUITES BY HILTON ORLANDO INTERNATIONAL DRIVE

License Type: Hotel

8745 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 07/13/2022

Inspection Number: 1165316

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LUI, SUK HAN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only./all 5 boilers with code violations and certificate of operation is suspended per Division of State Fire Marshal.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

---

License Number: 5801553

DAYS INN ORLANDO

License Type: Motel

2500 W 33 ST, ORLANDO 32839

**Orange County**

Inspection Date: 07/11/2022

Inspection Number: 1222732

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: PASIECKI, VICTORIA

Violation CodeObservationViolation Citation

01-02-4	<p>- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 4th floor near elevator, located in fire ho box</p> <p>- From follow-up inspection 2022-07-06: **Time Extended</p> <p>- From follow-up inspection 2022-07-11: **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
08-01-4	<p>- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.</p> <p>053116- 2/4/22 - From follow-up inspection 2022-07-06: **Tim Extended**</p> <p>- From follow-up inspection 2022-07-11: **Time Extended**</p>	<p>61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.</p> <p>509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>



**Osceola County**

License Number: 5900266

THE LISBON

License Type: Motel

4311 W VINE ST, KISSIMMEE 34746

Inspection Date: 07/13/2022

Inspection Number: 1222820

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: DAVIS, DIANNA

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. Panel reads service required.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

License Number: 5912068

MM LAKE HOTEL LLC

License Type: Hotel

4944 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 07/11/2022

Inspection Number: 1163168

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance  
inspector's boiler report available. For reporting purposes only.  
Boiler FL 138722. - From follow-up inspection 2022-06-06:  
\*\*Time Extended\*\* - From follow-up inspection 2022-07-11:  
\*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report  
is required annually for power boilers and high  
pressure/high temperature boilers and biannually for  
low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the  
local firesafety authority or the State Fire Marshal of  
any readily observable violation of a rule adopted under  
chapter 633 which relates to public lodging  
establishments or public food establishments, and the  
identification of such violation does not require any  
firesafety inspection certification. For reporting  
purposes only.

**Osceola County**

---

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

**Osceola County**

Inspection Date: 07/13/2022

Inspection Number: 1167012

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. By room 130	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only. <b>**Repeat Violation**</b>	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Osceola County**

04-02-4	No smoke detector provided in guest room/unit. For reporting purposes only. Room 269. Manager replaced. <b>**Corrected On-Site**</b>	509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. <b>**Repeat Violation**</b>	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

**Palm Beach County**

---

License Number: 6007059

ADVENIR AT LA COSTA

License Type: Apartment

4101 MAHOGANY DR, BOYNTON BEACH 33436

**Palm Beach County**

Inspection Date: 07/14/2022

Inspection Number: 1555510

Inspection Type: Complaint Full

Inspection Disposition: Call Back -

Inspector Name: AHLE, ROBERT

Admin. complaint recommended

Violation CodeObservationViolation Citation

01-01-4	- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observe at building 14 apt14208. - From follow-up inspection 2022-07-14: Same	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-01-4	Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observe at building 14 apt14208.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Palm Beach County**

01-02-4	<p>- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only, building 16 next to apt. 16109. Building 15 apt15103.</p> <p>- From follow-up inspection 2022-07-14: Same</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
01-02-4	<p>Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only, building 16 next to apt. 16109. Building 15 apt15103.</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
01-03-4	<p>- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observe at building 15 at apt 15205 **Repeat Violation** - Fror follow-up inspection 2022-07-14: Same</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

**Palm Beach County**

01-03-4	<p>Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observe at building 15 at apt 15205 **Repeat Violation**</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
07-04-4	<p>- From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observe at building 14 on third floor light hanging off wall and building 1 at first floor 1105 - From follow-up inspection 2022-07-14: Same</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
07-04-4	<p>Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Observe at building 14 on third floor light hanging off wall and building 1 at first floor 1105</p>	<p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

**Palm Beach County**

License Number: 6008599

LAQUINTA INN

License Type: Motel

34 FISHERMANS WHARF, JUPITER 33477

Inspection Date: 07/13/2022

Inspection Number: 1225414

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: MCCARTHY, RAMONA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6212009

LEMANS APARTMENTS

License Type: Apartment

6565 S 5 AVE, ST PETERSBURG 337072203

Inspection Date: 07/14/2022

Inspection Number: 1545688

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HOBBS, ANDREW

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Near ur 204

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6207237

HOWARD JOHNSON BY WYNDHAM

License Type: Motel

27988 US HWY 19 N, CLEARWATER 33761

Inspection Date: 07/14/2022

Inspection Number: 1225398

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: PEARCE, LAURA

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Missing tool for break panel of fire extinguisher holder near room 238

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7405788

EXTENDED STAY AMERICA #1564

License Type: Hotel

255 BILL FRANCE BLVD, DAYTONA BEACH 32114

Inspection Date: 07/13/2022

Inspection Number: 1166127

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

02-04-4

2 mattresses, wood frame box and refrigerators stored in water heater room. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7401104

LA QUINTA INN & SUITES

License Type: Motel

816 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 07/13/2022

Inspection Number: 1225300

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo  
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

---

License Number: 7401632

HOLIDAY INN RESORT DAYTONA BEACH OCEAN FRONT

License Type: Motel

1615 S ATLANTIC AVE, DAYTONA BEACH 32118



**Volusia County**

Inspection Date: 07/11/2022

Inspection Number: 1223653

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

04-02-4 No smoke detector provided in laundry room. For reporting purposes only.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-04-4 Fire alarm control panel has no power. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Volusia County**

License Number: 7401000

BEST WESTERN AKU TIKI INN

License Type: Motel

2225 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 07/14/2022

Inspection Number: 1221778

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

08-03-4

- From initial inspection : No boiler certificate or insurance  
inspector's boiler report available. For reporting purposes only.  
From follow-up inspection 2022-07-06: **\*\*Time Extended\*\*** -  
From follow-up inspection 2022-07-14:

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report  
is required annually for power boilers and high  
pressure/high temperature boilers and biannually for  
low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the  
local firesafety authority or the State Fire Marshal of  
any readily observable violation of a rule adopted under  
chapter 633 which relates to public lodging  
establishments or public food establishments, and the  
identification of such violation does not require any  
firesafety inspection certification. For reporting  
purposes only.

**Volusia County**

License Number: 7401466

SHORELINE ALL SUITES INN & CABANA COLONY COTTAGES

License Type: Motel

2435 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Inspection Date: 07/15/2022

Inspection Number: 1225169

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative complaint recommended

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

07-02-4

Frayed electrical wire(s). For reporting purposes only.  
  
-inside office on wall running along ceiling to network/server area.  
Small red/white electrical wires uncapped, at corner of wall.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7400778

SURFSIDE EXECUTIVE APTS

License Type: Apartment

421 AUBURN DR, DAYTONA BCH 321183254

Inspection Date: 07/14/2022

Inspection Number: 1554137

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

07-02-4

Frayed electrical wire(s). For reporting purposes only.

East end of building 425 near air conditioning units, running up  
wall to 2nd floor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7400673

BEST WESTERN DAYTONA INN SEABREEZE

License Type: Motel

730 N ATLANTIC AVE, DAYTONA BCH 321183805

Inspection Date: 07/14/2022

Inspection Number: 1225179

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo  
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7401413

TROPICAL RESORT AND MARINA

License Type: Motel

1485 LAKEVIEW DR, DELAND 32720

Inspection Date: 07/15/2022

Inspection Number: 1221244

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: OCASIO-LOPEZ, LISA

Violation Code

Observation

Violation Citation

04-02-4

- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Room 202, - From follow-up inspection 2022-07-15: \*\*Time Extended\*\*

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.