

Brevard County

License Number: 1505821

ADDISON POINTE

License Type: Apartment

3515 DELANEY DR, MELBOURNE 32934

Inspection Date: 07/29/2022

Inspection Number: 1543075

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VAUGHAN, COURTNEY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.
 Trouble in building 4 operator has part on order to correct the trouble light. ****Corrective Action Taken****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1601604

DANIA BEACH SUITES

License Type: Motel

135 E DANIA BEACH BLVD, DANIA BEACH 33004

Inspection Date: 07/29/2022

Inspection Number: 1225067

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BARTON, GEOFFREY

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher in office in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1618774

STUDIO 6 CORAL SPRINGS

License Type: Motel

5645 N UNIVERSITY DR, CORAL SPRINGS 33067

Broward County

Inspection Date: 07/28/2022

Inspection Number: 1225500

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Warning
Issued

Inspector Name: BRADY, OSSIAN

Violation CodeObservationViolation Citation

05-02-5	Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certifications 055345 03/13/2021, 055346 03/13/2021.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1612092

CLPF SERRAMAR LAKES

License Type: Apartment

6701 W OAKLAND PARK BLVD, FORT LAUDERDALE 33313

Inspection Date: 07/29/2022

Inspection Number: 1555760

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LOPEZ, BREONNTE

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Observed multiple;
Fire extinguisher next to apt 104D building 8
Fire extinguisher next to apt 106D building 8
Fire extinguisher next to apt 102D building 7
Fire extinguisher next to apt 106D building 5

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621426

BP AVENUE LLC

License Type: Apartment

6220 REESE RD, DAVIE 33314

Inspection Date: 07/26/2022

Inspection Number: 1519786

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: GANPAT, INDAR

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Extinguisher located by door to unit 101 in building 2 shows as undercharged. - From follow-up inspection 2022-07-26:
Observed same **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620857

FERRARA HOLDINGS LLC

License Type: Motel

4288 DAVIE RD, FORT LAUDERDALE 33314

Inspection Date: 07/29/2022

Inspection Number: 1223860

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GANPAT, INDAR

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Behind unit #1

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1600213

COMFORT INN OCEANSIDE

License Type: Hotel

50 SE 20 AVE, DEERFIELD BEACH 33441

Inspection Date: 07/26/2022

Inspection Number: 1167197

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: BRANN, JUSTIN

Violation Code

Observation

Violation Citation

02-04-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs. stored inside the building. For reporting purposes only. Maintenance room. Operator removed. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329127

ALSI ENTERPRISES

License Type: Apartment

2305 W 74 ST, HIALEAH 33016

Inspection Date: 07/26/2022

Inspection Number: 1540260

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed on units# 207, 103, 202 and 101.no glass breaking device.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309901

M AND M VENTURE ENTERPRISES INC

License Type: Apartment

336-344 NW 2 AVE, HOMESTEAD 33030

Inspection Date: 07/27/2022

Inspection Number: 1541565

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher building 336 NW. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2312668

ODETTE APARTMENTS LLC

License Type: Apartment

2155 NW 19 TER, MIAMI 33125

Inspection Date: 07/27/2022

Inspection Number: 1542507

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartments # 4 & # 5 second floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326653

ASHTON OAKS

License Type: Apartment

2137 NW 18 TER, MIAMI 33125

Inspection Date: 07/27/2022

Inspection Number: 1547718

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SAENZ, HILDA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed between apartments #5 & #6. Also observed between apartments #21 & #22.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327673

ARRAZCAETA APTS

License Type: Apartment

2141 NW 19 ST, MIAMI 33125

Inspection Date: 07/27/2022

Inspection Number: 1538879

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAENZ, HILDA

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed in front of apartments # 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2325791

COURTYARD MIAMI AIRPORT

License Type: Hotel

1201 NW 42 AVE, MIAMI 33126

Inspection Date: 07/27/2022

Inspection Number: 1164788

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329205

RESIDENCE INN BY MARRIOTT MIAMI AIRPORT SOUTH

License Type: Hotel

1201 NW LEJEUNE RD, MIAMI 33126

Inspection Date: 07/26/2022

Inspection Number: 1164726

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2307611

MIAMI AIRPORT MARRIOTT- FULL SERVICE

License Type: Hotel

1201 NW 42 AVE, MIAMI 331262656

Inspection Date: 07/26/2022

Inspection Number: 1167194

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ORDONEZ, CATALINA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329470

HOTEL INDIGO MIAMI BRICKELL / ATWELL SUITES MIAMI BRICKELL

License Type: Hotel

145 SW 11 ST, MIAMI 33130

Inspection Date: 07/28/2022

Inspection Number: 1166174

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

At the time of the inspection observed two boilers with 700,000 btu. No boiler certificate provided, establishment is still in process to get boilers certified.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328942

FOUR SEASONS HOTEL MIAMI

License Type: Hotel

1435 BRICKELL AVE, MIAMI 33131

Inspection Date: 07/26/2022

Inspection Number: 1164925

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329005

HOTEL AKA BRICKELL

License Type: Hotel

1395 BRICKELL AVE, MIAMI 33131

Inspection Date: 07/28/2022

Inspection Number: 1165462

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329329

EAST MIAMI

License Type: Hotel

788 BRICKELL PLAZA, MIAMI 33131

Inspection Date: 07/22/2022

Inspection Number: 1166268

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330168

1556 SW 6 STREET I LLC

License Type: Apartment

1556 SW 6 ST, MIAMI 33135

Inspection Date: 07/27/2022

Inspection Number: 1552677

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330314

MODERA EDGEWATER

License Type: Apartment

455 NE 24 ST, MIAMI 33137

Inspection Date: 07/26/2022

Inspection Number: 1536004

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SEYBA, JAMES

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2305153

SIAR 1 LLC

License Type: Apartment

7124 BAY DR, MIAMI BEACH 33141

Inspection Date: 07/29/2022

Inspection Number: 1541679

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device on extinguishers located by unit 2 and 5. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303874

GRAND ISLAND PORTFOLIO LLC

License Type: Apartment

1495 NE 167 ST, NORTH MIAMI BEACH 33162

Dade County

Inspection Date: 07/28/2022

Inspection Number: 1535404

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: VILCHEZ, NABEL

Violation CodeObservationViolation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. At building 300 located on first and second floor. - From follow-up inspection 2022-05-26: At the time of callback inspection Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. At building 300 located on first and second floor. **Time Extended** - From follow-up inspection 2022-06-06: At the time of callback inspection Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. At building 300 located on first and second floor. **Time Extended** - From follow-up inspection 2022-07-28: Observed Portable fire extinguisher missing from it's designated location (sign present indicating designated location). At building 300 located on first and second floor. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

- 01-05-4 - From initial inspection : Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Next to apt #104. - From follow-up inspection 2022-05-26: At the time of callback inspection Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Next to apt #104. ****Time Extended**** - From follow-up inspection 2022-06-06: Observed Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Next to apt #104. ****Time Extended**** - From follow-up inspection 2022-07-28: At the time of callback inspection observe fire extinguisher obstructed/not accessible,next apt #104. ****Time Extended****
- 04-05-4 - From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Apartment #306 - From follow-up inspection 2022-05-26: At the time of callback inspection no smoke detector provided in guest room/unit. For reporting purposes only. Apartment #306. ****Time Extended**** - From follow-up inspection 2022-06-06: Unable to enter in unit #306. ****Time Extended**** - From follow-up inspection 2022-07-28: At the time of callback inspection we are unable to enter in unit #306 ****Time Extended****
- 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
- 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309567

CORAL HAVEN APARTMENTS

License Type: Apartment

10255 CORAL WAY, MIAMI 33165

Inspection Date: 07/25/2022

Inspection Number: 1554209

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Located near unit 153 at building C.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device provided near unit 150 at building C

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329338

HILTON GARDEN INN MIAMI DOLPHIN MALL

License Type: Hotel

1695 NW 111 AVE, SWEETWATER 33172

Inspection Date: 07/27/2022

Inspection Number: 1165604

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326143

LA QUINTA INN AND SUITES MIAMI CUTLER BAY

License Type: Hotel

10821 CARIBBEAN BLVD, MIAMI 33189

Inspection Date: 07/28/2022

Inspection Number: 1166288

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CURRAS, YANLEE

Violation Code

Observation

Violation Citation

01-05-4

Portable fire extinguisher obstructed/not accessible. For reporting purposes only. Observed fire extinguisher with no braking device the fourth floor by room 411 and 421.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2603121

APM INN & SUITES JACKSONVILLE

License Type: Motel

510 LN AVE S, JACKSONVILLE 32254

Inspection Date: 07/27/2022

Inspection Number: 1225537

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: MERCER, THOMAS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Extinguishers by room 347 and 302 have needed in recharge zone. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2702778

HOTEL DEL SOL

License Type: Motel

6900 PENSACOLA BLVD, PENSACOLA 32505

Inspection Date: 07/25/2022

Inspection Number: 1225580

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BARNARD, JOHN

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing building 300 next to exterior door. Corrected and replaced by operator. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Between rooms 505-503. Operator repaired onsite ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2703078

THE RELAX INN MOTEL

License Type: Motel

3725 MOBILE HWY, PENSACOLA 32505

Inspection Date: 07/29/2022

Inspection Number: 1225606

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: BARNARD, JOHN

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near room 4.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705417

EXTENDED STAY PENSACOLA

License Type: Hotel

6950 PENSACOLA BLVD, PENSACOLA 32505

Inspection Date: 07/29/2022

Inspection Number: 1167258

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HATLER, MATTHEW

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
No smoke detector in room 225

509.215(1) and (2) and 509.032(2)(d) FS Reporting:
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

Hillsborough County

License Number: 3913615

STAYBRIDGE SUITES TAMPA EAST/BRANDON

License Type: Hotel

3624 N FALKENBURG RD, TAMPA 33619

Hillsborough County

Inspection Date: 07/25/2022

Inspection Number: 1164404

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: AUDETTE, DAKOTA

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
121762 - From follow-up inspection 2022-07-25: Inspection scheduled in October 2022 per management **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

08-03-4

- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.
135178 - From follow-up inspection 2022-07-25: Inspection scheduled in October 2022 per management. **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

Indian River County

License Number: 4100985

ECONOLOGDE

License Type: Motel

950 US 1, VERO BCH 32960

Indian River County

Inspection Date: 07/25/2022

Inspection Number: 1223821

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: SCHUCK, GREGORY

Violation CodeObservationViolation Citation

04-04-4	<p>- From initial inspection : Fire alarm control panel has no power. For reporting purposes only. Manager stated that they are doing a walk through of property every hour. Log is being kept. **Repeat Violation** - From follow-up inspection 2022-07-25: **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
08-01-4	<p>- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2022-07-25: **Time Extended**</p>	<p>61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Levy County

License Number: 4800404

DOCKSIDE MOTEL

License Type: Motel

491 DOCK ST, CEDAR KEY 32625

Inspection Date: 07/29/2022

Inspection Number: 1224517

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Room 3 missing smoke detector.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

Manatee County

License Number: 5100514

RAMADA WATERFRONT HOTEL

License Type: Motel

7150 N TAMIAMI TRAIL, SARASOTA 34243

Manatee County

Inspection Date: 07/29/2022

Inspection Number: 1223874

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: EASLER, VERONICA

Violation CodeObservationViolation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher in between rooms 313 and 315 in the recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-01-4	Boiler certificate or insurance inspector's boiler report expired on 06/22/2022. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200849

ON THE LAKE PARK

License Type: Apartment

11701 SE HWY C-25, OKLAWAHA 321795009

Inspection Date: 07/28/2022

Inspection Number: 1553742

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Fire extinguisher located between unit 2 and 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5201916

SERENITY GARDENS AT BELLEVIEW

License Type: Apartment

5836 SE DREW RD, BELLEVIEW 34420

Inspection Date: 07/29/2022

Inspection Number: 1555317

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between units A4 and A5 **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200242

MERCY INN & RV PARK

License Type: Motel

3601 W SILVER SPRINGS BLVD., OCALA 34475

Inspection Date: 07/27/2022

Inspection Number: 1225566

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: DRIGGERS, MANDY

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested and no other hearing-impaired smoke detectors available. For reporting purposes only.
Provided kiddie alarm, but unable to test. **Warning**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5803834

SHERATON ORLANDO NORTH HOTEL

License Type: Hotel

600 NORTH LAKE DESTINY DRIVE, MAITLAND 32751

Inspection Date: 07/29/2022

Inspection Number: 1165896

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONTGOMERY, DOREEN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Certificate 134960 expires 12/17/21 & Certificate 134898 expires 12/17/21 ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810170

GRAND BOHEMIAN HOTEL ORLANDO

License Type: Hotel

325 S ORANGE AVE, ORLANDO 32801

Inspection Date: 07/28/2022

Inspection Number: 1166826

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PLEICONES, KIM

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Boiler 133273 expired on 7/17/22, boiler turned off and not operating at this time

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809156

HAMPTON INN ORLANDO CONVENTION CENTER

License Type: Hotel

8900 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 07/28/2022

Inspection Number: 1165058

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LUI, SUK HAN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only/All boiler certificates expired due to new regulation from the department. Installation already in process per Manager.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810905

HILTON GARDEN INN ORLANDO I-DRIVE NORTH

License Type: Hotel

5877 AMERICAN WAY, ORLANDO 32819

Inspection Date: 07/29/2022

Inspection Number: 1165713

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KOSTELNY, ROGER

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo
reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014533

WESECONDCHANCE LLC

License Type: Apartment

806 N SAPODILLA AVE, WEST PALM BEACH 33414

Inspection Date: 07/27/2022

Inspection Number: 1555758

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: AHLE, ROBERT

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Observe at apt E.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6200643

WHITNEY HOTEL

License Type: Hotel

241 3RD STREET N., ST. PETERSBURG 33701

Inspection Date: 07/25/2022

Inspection Number: 1163915

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: MURPHY, JAMES

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher on second floor outside of room 232 is in the recharge zone. - From follow-up inspection 2022-07-25: **Tim Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215317

STRATFORD COURT OF PALM HARBOR

License Type: Apartment

45 KATHERINE BLVD, PALM HARBOR 34684

Inspection Date: 07/28/2022

Inspection Number: 1530635

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: BEACHAM, MICHELLE

Violation CodeObservationViolation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance
inspector's boiler report expired. For reporting purposes only.
Expired 06/27/2021 - From follow-up inspection 2022-07-28:
Inspection complete. Waiting for report. **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report
is required annually for power boilers and high
pressure/high temperature boilers and biannually for
low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the
local firesafety authority or the State Fire Marshal of
any readily observable violation of a rule adopted under
chapter 633 which relates to public lodging
establishments or public food establishments, and the
identification of such violation does not require any
firesafety inspection certification. For reporting
purposes only.

Seminole County

License Number: 6904041

BELL LAKE FOREST

License Type: Apartment

101 INTEGRA VILLAGE TRL, SANFORD 32771

Inspection Date: 07/29/2022

Inspection Number: 1554235

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Fo reporting purposes only.
Notified Sanford Fire Inspector, Dan Taylor. 407-562-2788. Left Voice Message.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400247

ETTCO AND COMPANY LLC

License Type: Apartment

420 N OLEANDER AVE, DAYTONA BEACH 32118

Inspection Date: 07/28/2022

Inspection Number: 1546685

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

02-07-4

Flammable/combustible chemicals stored near a source of ignition. For reporting purposes only.

-aerosol/chemicals and various household supplies stored on surface of water heater next to vent stack near the stairwell

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406499

HAMPTON INN DAYTONA BEACH BEACHFRONT

License Type: Hotel

1024 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 07/29/2022

Inspection Number: 1164864

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406503

RESIDENCE INN DAYTONA OCEANFRONT

License Type: Hotel

3209 S ATLANTIC AVE, DAYTONA BEACH SHORES 32118

Volusia County

Inspection Date: 07/26/2022

Inspection Number: 1165018

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

04-01-4	- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-07-26: **Time Extended**	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

07-04-4	Electrical outlet damaged to indicate a malfunction. For reporting purposes only. -north east corner of building exterior	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
07-04-4	- From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only. -north east corner of building exterior - From follow-up inspection 2022-07-26: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406229

ANCHOR INN

License Type: Bed and Breakfast

312 WASHINGTON ST, NEW SMYRNA BEACH 32168

Inspection Date: 07/25/2022

Inspection Number: 1094723

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: PICHARDO, RENEE

Violation Code

Observation

Violation Citation

12-04-4

- From initial inspection : High Priority - Staircase spindles loose/
nails rusted at bottom. West side **Warning** - From follow-up
inspection 2022-07-25: **Time Extended**

61C-1.004(5) FAC High Priority: All building structural
components, attachments and fixtures shall be kept in
good repair.