

**Alachua County**

License Number: 1100754

STAYABLE SUITES GAINESVILLE

License Type: Hotel

2900 SW 13 ST, GAINESVILLE 32608

Inspection Date: 08/26/2022

Inspection Number: 1167416

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: TORRES, WILLIAM

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate in boiler room expired, however Person In Charge was able to provide a current boiler certificate at the office and made copy to place in boiler room. **\*\*Corrected On-Site\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1300977

TURTLE LAKE APARTMENTS

License Type: Apartment

4324 W 20TH STREET, PANAMA CITY 32405

Inspection Date: 08/26/2022

Inspection Number: 1555954

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Out side D122

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside S169

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1302362

SUMMER BREEZE INN

License Type: Motel

9227 W FRONT BEACH RD, PANAMA CITY BEACH 32407

Inspection Date: 08/26/2022

Inspection Number: 1225925

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: HAASE, TINA

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Observed smoke detector taken off wall in room 104. Manager has asked maintenance to put back on wall. **\*\*Corrective Action Taken\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1304833

BEACH TOWER BY THE SEA

License Type: Motel

11831 FRONT BEACH RD, PANAMA CITY BEACH 32407

Inspection Date: 08/24/2022

Inspection Number: 1225898

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: HAASE, TINA

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Fire extinguisher missing on bottom floor back of building near coke machine.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Smoke alarm on 1st floor outside of housekeeping room on east side of building damaged.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1303586

TRAVELODGE

License Type: Motel

203 SHALIMAR ST, PANAMA CITY BEACH 32417

Inspection Date: 08/26/2022

Inspection Number: 1223951

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HAASE, TINA

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed fire extinguisher missing from building 6 between rooms 603 and 604.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1607162

BEST WESTERN HALLANDALE INN

License Type: Motel

101 ANSIN BLVD, HALLANDALE 33009-3992

Inspection Date: 08/24/2022

Inspection Number: 1167610

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: PIERRE, ENOSE

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher between room 507-509

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1605598

OCEAN MILE HOTEL

License Type: Motel

4101 N OCEAN BLVD, FORT LAUDERDALE 33308

Inspection Date: 08/23/2022

Inspection Number: 1225868

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: DEJONG, STEVEN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1620863

HOMEWOOD SUITES FORT LAUDERDALE AIRPORT & CRUISE PORT

License Type: Hotel

2061 GRIFFIN RD, DANIA BEACH 33312

Inspection Date: 08/25/2022

Inspection Number: 1166343

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation Code

Observation

Violation Citation

03-04-4

Fire sprinkler head obstructed/covered with dust behind dryers in laundry room. Operator cleaned during inspection. For reporting purposes only. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Charlotte County**

License Number: 1801527

FOUR POINTS BY SHERATON PUNTA GORDA HARBORSIDE

License Type: Hotel

33 TAMIAMI TR, PUNTA GORDA 33950

Inspection Date: 08/24/2022

Inspection Number: 1165243

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2328181

1225 NE 1 TERR APTS

License Type: Apartment

1225 NE 1 TERR, HOMESTEAD 33030

Inspection Date: 08/26/2022

Inspection Number: 1539485

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located next to laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2320327

FAIRWAY INN

License Type: Motel

100 U S 1, FLORIDA CITY 33034

Inspection Date: 08/26/2022

Inspection Number: 1224078

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329657

MODERA SKYLAR

License Type: Apartment

1444 / 1445 NW 14 AVE, MIAMI 33125

Inspection Date: 08/24/2022

Inspection Number: 1537301

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SAENZ, HILDA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed at the 5th floor next to resident lounge.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2318723

MAYFAIR HOUSE HOTEL & GARDEN

License Type: Hotel

3000 FLORIDA AVE, MIAMI 33133

Inspection Date: 08/22/2022

Inspection Number: 1167406

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: MASKASEM, SUPPACHAI

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed 1 boiler certificate expired, 016684 expired on 10/03/20. - From follow-up inspection 2022-08-22: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329454

COURTYARD BY MARRIOTT MIAMI COCONUT GROVE

License Type: Hotel

2649 BAYSHORE DR, MIAMI 33133

Inspection Date: 08/22/2022

Inspection Number: 1167186

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MASKASEM, SUPPACHAI

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. 093160, 097013 exp 11/14/18

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2300927

JEFFERSON 745-761

License Type: Apartment

745 JEFFERSON AVE, MIAMI BEACH 33139

Inspection Date: 08/22/2022

Inspection Number: 1555891

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: UNZAGA, MILADYS

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed no breaking device on fire extinguisher.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2304427

JEFFERSON 745-761

License Type: Apartment

755 JEFFERSON AVE, MIAMI BEACH 33139

Inspection Date: 08/22/2022

Inspection Number: 1555892

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: UNZAGA, MILADYS

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed missing breaking device on extinguisher located next to unit 6.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2305236

COLONY HOTEL

License Type: Hotel

736 OCEAN DRIVE, MIAMI BEACH 33139

Inspection Date: 08/24/2022

Inspection Number: 1167593

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel located behind front desk. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329201

METROPOLE HOTEL

License Type: Hotel

635 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 08/22/2022

Inspection Number: 1165787

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel.  
Management is aware, in the process of fixing,issue. For reporting  
purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329306

HYATT CENTRIC SOUTH BEACH

License Type: Hotel

1600 COLLINS AVENUE, MIAMI BEACH 33139

Inspection Date: 08/25/2022

Inspection Number: 1165290

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired.  
Observed boiler jurisdiction number's 132830, 132829 & 132828  
expired on 1/27/2022. For reporting purposes only. \*\*Repeat  
Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report  
is required annually for power boilers and high  
pressure/high temperature boilers and biannually for  
low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the  
local firesafety authority or the State Fire Marshal of  
any readily observable violation of a rule adopted under  
chapter 633 which relates to public lodging  
establishments or public food establishments, and the  
identification of such violation does not require any  
firesafety inspection certification. For reporting  
purposes only.

**Dade County**

License Number: 2329373

HAMPTON INN MIAMI AIRPORT EAST

License Type: Hotel

3449 NW 42 AVE, MIAMI 33142

Inspection Date: 08/26/2022

Inspection Number: 1165333

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-08-26: At time of callback inspection Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

---

License Number: 2329252

ALOFT DORAL

License Type: Hotel

3265 NW 107 AVE, DORAL 33172

**Dade County**

Inspection Date: 08/24/2022

Inspection Number: 1166363

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ALVAREZ, MARGARET

Violation CodeObservationViolation Citation

08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2612235

RED ROOF INN #10251

License Type: Motel

6969 LENOIR AVE E, JACKSONVILLE 32216

Inspection Date: 08/23/2022

Inspection Number: 1223430

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation CodeObservationViolation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only.  
Back door in housekeeping area

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

## Highlands County

License Number: 3800994

GROVES AT VICTORIA PARK

License Type: Apartment

2010 VILLAGE GROVE BLVD, SEBRING 33870

Inspection Date: 08/23/2022

Inspection Number: 1541357

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

12-04-4

High Priority - Balcony/stairway/platform collapsed. Observed balcony at second floor in back with water damage to platform platform underside is sagging down. Platform surface is still solid.

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

**Hillsborough County**

License Number: 3911768

COURTYARD BY MARRIOTT

License Type: Hotel

102 E CASS ST, TAMPA 33602

Inspection Date: 08/26/2022

Inspection Number: 1166517

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. No striker to access extinguisher.  
Outside room 504.  
**\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3914062

ASHER

License Type: Apartment

1050 WATER ST, TAMPA 33602

Inspection Date: 08/26/2022

Inspection Number: 1555417

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: EHLERS, MICHAEL

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. Tanks with temperature of 210 and heat input of 500,000 BTU. 7th floor. There are also 2 boilers on the roof.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3913634

QUALITY INN AND SUITES TAMPA FAIRGROUND

License Type: Hotel

4955 E 18 AVE, TAMPA 33605

Inspection Date: 08/23/2022

Inspection Number: 1161052

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: AUDETTE, DAKOTA

Violation Code

Observation

Violation Citation

04-02-4

- From initial inspection : No smoke detector provided in guest room/unit. For reporting purposes only. Room 210 - From follow-up inspection 2022-08-23: Occupied at time of callback. \*\*Tim Extended\*\*

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

---

License Number: 3902852

THE GODFREY HOTEL AND CABANAS

License Type: Hotel

7700 W COURTNEY CAMPBELL CAUSEWAY, TAMPA 33607

**Hillsborough County**

Inspection Date: 08/23/2022

Inspection Number: 1164385

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: CANNELLA, MARK

Violation CodeObservationViolation Citation

04-01-4	<p>- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-07-22: **Time Extended** - From follow-up inspection 2022-08-23: **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
08-03-4	<p>- From initial inspection : No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. - From follow-up inspection 2022-07-22: **Time Extended** - From follow-up inspection 2022-08-23: **Time Extended**</p>	<p>61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

**Hillsborough County**

License Number: 3906517

RODEWAY INN

License Type: Motel

6510 N US HWY 301, TAMPA 33610

Inspection Date: 08/26/2022

Inspection Number: 1225899

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: COLEMAN, TONYA

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting  
purposes only. Rooms 234 338

509.215(1) and (2) and 509.032(2)(d) FS Reporting:  
 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Indian River County**

License Number: 4100080

VEROTOWN LLC

License Type: Motel

3901 26 ST, VERO BEACH 32960

Inspection Date: 08/26/2022

Inspection Number: 1223420

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4600376

PARK MOTEL

License Type: Motel

2020 N TAMiami TRL, N FORT MYERS 33903-7800

Inspection Date: 08/22/2022

Inspection Number: 1224258

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: FREED, JOSEPH

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Observed smoke alarm Room #8 was damaged.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4601260

LA VILLA RESORT

License Type: Motel

2700 ESTERO BLVD, FORT MYERS BEACH 33931

Inspection Date: 08/25/2022

Inspection Number: 1224862

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GONDERMANN, FRANK

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In Bal Harbor Suite #207

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Leon County**

License Number: 4701589

LIVE OAKS AT KILLEARN

License Type: Apartment

1555 DELANEY DR, TALLAHASSEE 32309

Inspection Date: 08/24/2022

Inspection Number: 1555999

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SMITH, PAUL

Violation Code

Observation

Violation Citation

07-04-4

Electrical outlet damaged to indicate a malfunction. For reporting purposes only. Open wiring boxes buildings 19,16,11, & 3.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5803730

BEST WESTERN ORLANDO GATEWAY HOTEL

License Type: Motel

7299 UNIVERSAL BLVD, ORLANDO 32819

Inspection Date: 08/22/2022

Inspection Number: 1223382

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: LUI, SUK HAN

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. - From follow-up inspection 2022-08-22: **\*\*Time Extended\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

**Palm Beach County**

License Number: 6014407

733 APARTMENTS

License Type: Apartment

733 DR MLK JR BLVD, BELLE GLADE 33430

Inspection Date: 05/12/2022

Inspection Number: 1556123

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: SEVILLA, FREDDY

Violation CodeObservationViolation Citation

01-04-4

First floor units 3 and 28.  
 Second floor unit 8  
 Third floor units 18 and 13.  
 Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

Inspection Date: 07/28/2022

Inspection Number: 1556123

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: SEVILLA, FREDDY

Violation CodeObservationViolation Citation

01-04-4

Observed: No portable fire extinguisher present on the premises. For reporting purposes only. First floor units 3 and 28.  
Second floor unit 8  
Third floor units 18 and 13.  
Priority: Reporting  
Same.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014057

COURTYARD BY MARRIOTT JUPITER ABACO

License Type: Hotel

4800 MAIN ST, JUPITER 33458

Inspection Date: 08/22/2022

Inspection Number: 1166939

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: MCCARTHY, RAMONA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014059

HOLIDAY INN EXPRESS & SUITES

License Type: Hotel

1251 HYPOLUXO RD, LANTANA 33462

Inspection Date: 08/23/2022

Inspection Number: 1166940

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: PITRE, ASTRID

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning guest covered  
strobe light, hard wired in room 105.  
Operator uncovered.  
For reporting purposes only. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6300330

SONNYS MOTEL

License Type: Motel

35 US HWY 17-92, HAINES CITY 33844

Inspection Date: 08/26/2022

Inspection Number: 1224855

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.  
Removed room 10.

509.215(1) and (2) and 509.032(2)(d) FS Reporting:  
509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6903990

WOODSPRING SUITES ORLANDO SANFORD

License Type: Hotel

2727 S ORLANDO DR, SANFORD 32773

Inspection Date: 08/23/2022

Inspection Number: 1167579

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GUTTERMAN, KENNETH

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Lucie County**

License Number: 6602050

REDFINN INN

License Type: Motel

612 S 4 US 1, FT PIERCE 349508304

Inspection Date: 08/22/2022

Inspection Number: 1225871

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HARROD, JESSICA

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Near 118  
**\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7401131

BELLAIR PALMS

License Type: Apartment

2417 N. OLEANDER DRIVE, DAYTONA BEACH 32118

Inspection Date: 08/22/2022

Inspection Number: 1541146

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.

-damaged orange wire coming from ground near north stairway in front of building 2418, closest to unit 13

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406518

COMFORT INN AND SUITES

License Type: Hotel

103 S OCEAN AVE, DAYTONA BEACH 32118

Inspection Date: 08/23/2022

Inspection Number: 1166233

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406551

SCHULTE AVE RENTALS LLC

License Type: Apartment

2031 SCHULTE AVE, DAYTONA BEACH 32118

Inspection Date: 08/22/2022

Inspection Number: 1538780

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.

-under stairway by unit 2 on side

-south side of property at electrical boxes/meters

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7406446

BLACK DOLPHIN INN

License Type: Bed and Breakfast

916 S RIVERSIDE DR, NEW SMYRNA BEACH 32168

Inspection Date: 08/23/2022

Inspection Number: 1094765

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: PICHARDO, RENEE

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-08-23: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7405872

COMFORT INN &amp; SUITES

License Type: Motel

400 E INTERNATIONAL SPEEDWAY BLVD, DELAND 32724

Inspection Date: 08/23/2022

Inspection Number: 1223214

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: OCASIO-LOPEZ, LISA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.