

Bay County

License Number: 1305251

RAMADA

License Type: Hotel

4306 W HWY 98, PANAMA CITY 32401

Inspection Date: 09/01/2022

Inspection Number: 1166819

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside elevator on 4th floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1302846

SUNSET LAGOON

License Type: Apartment

6908 N LAGOON DR, PANAMA CITY BEACH 32408

Inspection Date: 09/02/2022

Inspection Number: 1537036

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside unit 1

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505699

EXTENDED STAY AMERICA #9511

License Type: Hotel

4450 HOLLYWOOD BLVD, MELBOURNE 32904

Inspection Date: 08/29/2022

Inspection Number: 1166501

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BRAYBOY, LYNN

Violation Code

Observation

Violation Citation

08-06-4

Combustibles stored in boiler room. For reporting purposes only. A gallon of paint. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

Broward County

License Number: 1618774

STUDIO 6 CORAL SPRINGS

License Type: Motel

5645 N UNIVERSITY DR, CORAL SPRINGS 33067

Broward County

Inspection Date: 08/29/2022

Inspection Number: 1225500

Inspection Type: Lodging-Licensing
InspectionInspection Disposition: Call Back -
Extension given, pending

Inspector Name: BRADY, OSSIAN

Violation CodeObservationViolation Citation

| | | |
|---------|--|---|
| 05-02-5 | - From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. - From follow-up inspection 2022-08-29: No hearing Impaired Smoke Detectors provided. **Time Extended** | 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 08-01-4 | - From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certifications 055345 03/13/2021, 055346 03/13/2021. - From follow-up inspection 2022-08-29: Certification process still ongoing. **Time Extended** | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Broward County

License Number: 1620249

HAMPTON INN FORT LAUDERDALE DOWNTOWN LAS OLAS AREA

License Type: Hotel

250 N ANDREWS AVE, FORT LAUDERDALE 33301

Inspection Date: 09/02/2022

Inspection Number: 1166674

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Between Rooms 503 and 504.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-03-4

Scorch marks around an electrical outlet. For reporting purposes only. Ice machine room across from Room 515.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620905

THE DALMAR FORT LAUDERDALE

License Type: Hotel

299 N. FEDERAL HIGHWAY, FORT LAUDERDALE 33301

Inspection Date: 09/02/2022

Inspection Number: 1165624

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. This inspection report will be emailed to Fire Marshal for review. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620906

ELEMENT FORT LAUDERDALE

License Type: Hotel

299 N FEDERAL HWY, FORT LAUDERDALE 33301

Inspection Date: 09/02/2022

Inspection Number: 1165859

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. This inspection report will be emailed to Fire Marshal for review. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621811

MOTIF APARTMENTS LLC

License Type: Apartment

500 N ANDREWS AVE, FORT LAUDERDALE 33301

Inspection Date: 09/01/2022

Inspection Number: 1536077

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: BRANN, JUSTIN

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel.
Inspection report will be emailed to Fire Marshall for review. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620888

THE LINK HOTEL

License Type: Hotel

1055 N FEDERAL HWY, FORT LAUDERDALE 33304

Inspection Date: 09/02/2022

Inspection Number: 1167738

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. Inspection report will be emailed to Fire Marshall for review. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1618388

HYATT PLACE

License Type: Hotel

8530 W BROWARD BLVD, PLANTATION 33324

Inspection Date: 09/01/2022

Inspection Number: 1166882

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WATSON, TRICIA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation**** ****Admin Complaint****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327711

MIAMI LAKES TOWNEPLACE SUITES

License Type: Hotel

8079 NW 154 ST, MIAMI LAKES 33016

Inspection Date: 09/02/2022

Inspection Number: 1165293

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2310019

9TH STREET HOMESTEAD LLC

License Type: Apartment

183 NW 9 ST UNIT 1-6, HOMESTEAD 33030

Inspection Date: 08/29/2022

Inspection Number: 1550344

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. One located between meter room and unit 3 and one between unit 4 and unit 5.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2308769

HOLIDAY MOTEL

License Type: Motel

1405 N KROME AVE, FLORIDA CITY 33034-2431

Inspection Date: 08/29/2022

Inspection Number: 1224431

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Observed between unit 103 and 104, and between unit 107 and 108
****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329257

ALOFT MARY BRICKELL

License Type: Hotel

1001 SW 2 AVE, MIAMI 33130

Inspection Date: 08/29/2022

Inspection Number: 1166644

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CABANAS, NATALIE

Violation Code

Observation

Violation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2324227

GONZALEZ FAMILY HOLDINGS INC

License Type: Apartment

1629 NW 35 STREET, MIAMI 33142

Inspection Date: 08/30/2022

Inspection Number: 1547715

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher next to unit B1 pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2319006

HOTEL BLOOM AT MIA

License Type: Motel

5125 NW 36 ST, MIAMI SPRINGS 33166

Inspection Date: 09/02/2022

Inspection Number: 1224600

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguishers with no braking devices located by rooms 220 and 222 on second floor. Employee provided braking devices. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2327881

STAYBRIDGE SUITES MIAMI/DORAL

License Type: Hotel

3265 NW 87 AVE, MIAMI 33172

Dade County

Inspection Date: 08/29/2022

Inspection Number: 1166488

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection

Inspector Name: ALVAREZ, MARGARET

Completed - No Further Action

Violation CodeObservationViolation Citation

| | | |
|---------|---|---|
| 08-01-4 | Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 08-04-4 | Boiler certificate not posted in the boiler room. For reporting purposes only. | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Duval County

License Number: 2609107

DAYS INN JACKSONVILLE AIRPORT

License Type: Hotel

1170 AIRPORT RD, JACKSONVILLE 32218

Inspection Date: 08/29/2022

Inspection Number: 1166872

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Missing in room 203.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2612319

DOUBLETREE BY HILTON JACKSONVILLE AIRPORT

License Type: Hotel

2101 DIXIE CLIPPER RD, JACKSONVILLE 32218

Inspection Date: 08/29/2022

Inspection Number: 1164750

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Both boiler certifications expired 12/20/2021. Boilers have been inspected and reports have been mailed to State Fire Marshal.

****Corrective Action Taken****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2608575

RAMADA BAYMEADOWS HOTEL

License Type: Hotel

9150 BAYMEADOWS RD, JACKSONVILLE 32256

Inspection Date: 08/30/2022

Inspection Number: 1166275

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JEFFERS, MARY-BETH

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Portable fire extinguisher missing from designated cabinet on first floor near elevators. Operator located extinguisher at front desk and placed back in designated cabinet. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2700285

THE ASCEND AT PENSACOLA BAY

License Type: Apartment

800 SCENIC HWY, PENSACOLA 32503

Inspection Date: 09/02/2022

Inspection Number: 1541338

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Next to apartment 27.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2705355

MELEI RENTALS

License Type: Apartment

3543 MOBILE HWY, PENSACOLA 32505

Inspection Date: 09/01/2022

Inspection Number: 1551690

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

06-03-4

Marked exit is inaccessible. For reporting purposes only.
Windows boarded on multiple apartments. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913872

LANTOWER ASTURIA

License Type: Apartment

15175 INTEGRA JUNCTION, ODESSA 33556

Inspection Date: 09/02/2022

Inspection Number: 1522352

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: SILVERWOOD, JANNETTA

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

-ground level next to G7-F @ building 2140 - From follow-up inspection 2022-09-02: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913970

WESTSHORE CROSSING

License Type: Apartment

4515 N ROME AVE, TAMPA 33603

Inspection Date: 08/29/2022

Inspection Number: 1535973

Inspection Type: Complaint Partial

Inspection Disposition: Call Back -
Complied

Inspector Name: COLEMAN, TONYA

Violation CodeObservationViolation Citation

07-03-4

- From initial inspection : Scorch marks around an electrical panel meter. For reporting purposes only. Building P outside electric meter panel - From follow-up inspection 2022-07-05: Electric meter was replaced for building P, but scorch marks are still present. **Time Extended**
 - From follow-up inspection 2022-08-08: **Time Extended**
 - From follow-up inspection 2022-08-29: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3906542

HOLIDAY INN TAMPA AIRPORT WESTSHORE

License Type: Hotel

700 N WESTSHORE BLVD, TAMPA 33609

Inspection Date: 08/31/2022

Inspection Number: 1166758

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation Code

Observation

Violation Citation

08-04-4

Boiler certificate not posted in the boiler room. For reporting purposes only. ****Corrected On-Site****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3907679

KARMA NEST TAMPA

License Type: Hotel

3001 UNIVERSITY CENTER DR, TAMPA 33612

Hillsborough County

Inspection Date: 09/01/2022

Inspection Number: 1167322

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CESAR, RACHEL

Violation CodeObservationViolation Citation

| | | |
|---------|--|---|
| 05-02-5 | Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. The two hearing impaired detectors present are missing sound. | 509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 08-01-4 | Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. | 61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Lee County

License Number: 4602027

BRECHIN APARTMENTS

License Type: Apartment

1915 MARAVILLA AVE, FORT MYERS 339017181

Inspection Date: 08/25/2022

Inspection Number: 1540135

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WALTER, KAYLA

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher in recharge zone near unit 10.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4702785

HAMPTON INN TALLAHASSEE CENTRAL

License Type: Hotel

2979 APALACHEE PKWY, TALLAHASSEE 32301

Inspection Date: 09/02/2022

Inspection Number: 1166906

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WARD, JOWANNA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed expired boiler certificate expired 9/16/21.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105013

FAIRFIELD INN & SUITES-LWR

License Type: Hotel

6105 EXCHANGE WAY, BRADENTON 34202

Inspection Date: 08/31/2022

Inspection Number: 1165505

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: EASLER, VERONICA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105145

PARISH OAKS APARTMENTS

License Type: Apartment

5185 115TH CIRCLE EAST, PARRISH 34219

Inspection Date: 09/02/2022

Inspection Number: 1511504

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: MCKEON, MICHAEL

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
 Trouble light on BLD 5115, 5135 and 5175.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5200242

MERCY INN & RV PARK

License Type: Motel

3601 W SILVER SPRINGS BLVD., OCALA 34475

Inspection Date: 08/29/2022

Inspection Number: 1225566

Inspection Type: Complaint Full

Inspection Disposition: Call Back -

Inspector Name: DRIGGERS, MANDY

Admin. complaint recommended

Violation Code

Observation

Violation Citation

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning when tested and no other hearing-impaired smoke detectors available. For reporting purposes only. Provided kiddie alarm, but unable to test. ****Warning**** - From follow-up inspection 2022-08-29: Unable to test hearing impaired smoke detector. BRK LED Strobe Light, AC power. Unable to test detector due to needing to be hardwired. ****Admin Complaint****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301451

HUTCHINSON SHORES RESORT & SPA

License Type: Hotel

3793 NE OCEAN BLVD, JENSEN BEACH 34957

Inspection Date: 08/29/2022

Inspection Number: 1166716

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Main lobby.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301450

MACKNIGHT RENTAL

License Type: Apartment

524 SW CAMDEN AVE, STUART 34994

Inspection Date: 09/01/2022

Inspection Number: 1548291

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5401577

BAKER'S CAY RESORT KEY LARGO

License Type: Hotel

97000 S OVERSEAS HGWY, KEY LARGO 33037

Inspection Date: 09/02/2022

Inspection Number: 1165187

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603266

ISLAND RESERVE APARTMENTS

License Type: Apartment

352 BILLFISH AVE, FORT WALTON BEACH 32548

Inspection Date: 09/02/2022

Inspection Number: 1548701

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
Upon inspection observed cable boxes in disrepair of apartment 17.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5601895

VIKING APARTMENTS

License Type: Apartment

401 ROGERS ST, FT WALTON BCH 325484564

Inspection Date: 08/30/2022

Inspection Number: 1549427

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: ADAMSON, ROBERT

Violation CodeObservationViolation Citation

12-04-4

- From initial inspection : High Priority - Balcony/stairway/platform collapsed.
Upon inspection observed concrete platform on second level outside apartment F sinking.
Warning - From follow-up inspection 2022-08-30: Upon callback inspection observed maintenance/construction crew repairing platform. **Time Extended**

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

Orange County

License Number: 5809417

EXTENDED STAY AMERICA #1639

License Type: Hotel

6443 WESTWOOD BLVD, ORLANDO 32821

Inspection Date: 08/31/2022

Inspection Number: 1167704

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: LEVINS, NICHOLAS

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811191

TRU BY HILTON ORLANDO CONVENTION CENTER

License Type: Hotel

6461 WESTWOOD BOULEVARD, ORLANDO 32821

Inspection Date: 08/30/2022

Inspection Number: 1165482

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEVINS, NICHOLAS

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available.
For reporting purposes only. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5808434

DISNEY'S BEACH CLUB RESORT

License Type: Hotel

1800 EPCOT RESORTS BLVD, LAKE BUENA VISTA 328301000

Inspection Date: 09/02/2022

Inspection Number: 1165580

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.FI 109444 6/23/22.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 08/29/2022

Inspection Number: 1167011

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ Ground fault at main fire panel - From follow-up inspection 2022-08-29: **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6005720

INN AT BOYNTON BEACH

License Type: Hotel

480 W BOYNTON BEACH BLVD, BOYNTON BEACH 33435

Inspection Date: 08/30/2022

Inspection Number: 1167682

Inspection Type: Complaint Full

Inspection Disposition: Administrative
complaint recommended

Inspector Name: AHLE, ROBERT

Violation Code

Observation

Violation Citation

04-07-4

Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215866

VANTAGE POINT CONDOMINIUMS

License Type: Apartment

10200 GANDY BLVD, ST. PETERSBURG 33702

Inspection Date: 09/01/2022

Inspection Number: 1528268

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: LOZANO, KELVIN

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
By 5-525 - From follow-up inspection 2022-09-01:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Santa Rosa County

License Number: 6701306

SPRINGHILL SUITES BY MARRIOTT NAVARRE BEACH

License Type: Hotel

8375 GULF BLVD, NAVARRE BEACH 32566

Inspection Date: 08/29/2022

Inspection Number: 1166263

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804620

HILTON GARDEN INN SARASOTA BRADENTON AIRPORT

License Type: Hotel

8270 N TAMIAMI TRAIL, SARASOTA 34243

Inspection Date: 09/01/2022

Inspection Number: 1165193

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: EASLER, VERONICA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

Volusia County

License Number: 7400525

PLAZA RESORT & SPA

License Type: Hotel

600 N ATLANTIC AVE, DAYTONA BEACH 32118

Volusia County

Inspection Date: 08/30/2022

Inspection Number: 1163430

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

| | | |
|---------|---|--|
| 01-02-4 | <p>- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.</p> <p>-laundry room - From follow-up inspection 2022-08-30: **Time Extended**</p> | <p>509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p> |
| 08-01-4 | <p>- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.</p> <p>-6/17/2022 - From follow-up inspection 2022-08-30: **Time Extended**</p> | <p>61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p> |

Volusia County

License Number: 7401304

LA BELLA OCEANFRONT INN

License Type: Motel

1400 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 08/29/2022

Inspection Number: 1225395

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

07-02-4

- From initial inspection : Frayed electrical wire(s). For reporting purposes only.

-north east corner of building in backside with frayed wire visible on end near air conditioning unit, wiring running along entirety of wall.
-backside of unit 107 - From follow-up inspection 2022-08-19:
Time Extended - From follow-up inspection 2022-08-29: **Tin Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406686

EUROPEAN VENTURES

License Type: Apartment

827 N OLEANDER AVE, DAYTONA BEACH 32118

Inspection Date: 08/31/2022

Inspection Number: 1556200

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: WOOD, JUSTIN

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

-laundry room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400954

ATLANTIC BUDGET INN

License Type: Motel

1233 N ATLANTIC AVE, DAYTONA BCH 321183630

Inspection Date: 08/30/2022

Inspection Number: 1224786

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406520

EXTENDED STAY AMERICA #9512

License Type: Hotel

275 INTERCHANGE BLVD, ORMOND BEACH 32174

Inspection Date: 08/29/2022

Inspection Number: 1165743

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.