

**Alachua County**

License Number: 1100004

SENATE HOUSE (THE)

License Type: Apartment

202 SE 7 ST, GAINESVILLE 326016832

Inspection Date: 09/06/2022

Inspection Number: 844

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

04-03-4

- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only  
Observed at 614, in the upper hallway, the base for a smoke alarm is there, no smoke alarm. - From follow-up inspection 2022-09-06  
This was cited at the 614 address, but is actually at the 202 address  
No change. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1305101

RADISSON PANAMA CITY BEACH

License Type: Motel

15325 FRONT BEACH RD, PANAMA CITY BCH 32413

Inspection Date: 09/09/2022

Inspection Number: 1224104

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HAASE, TINA

Violation CodeObservationViolation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available.  
For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Bay County**

License Number: 1300437

FLAMINGO HOTEL AND TOWER

License Type: Motel

15525 W FRONT BEACH RD, PANAMA CITY BEACH 32413

Inspection Date: 09/06/2022

Inspection Number: 1225288

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: HAASE, TINA

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only. Observed no battery in smoke alarm for room 133.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1505682

HOMEWOOD SUITES CAPE CANAVERAL

License Type: Hotel

9000 ASTRONAUT BLVD, CAPE CANAVERAL 32920

Inspection Date: 09/07/2022

Inspection Number: 1166122

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1505793

BEACHWOOD APARTMENTS

License Type: Apartment

637 S ORLANDO AVE, COCOA BEACH 32931

Inspection Date: 09/07/2022

Inspection Number: 1521995

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

01-02-4

- From initial inspection : Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Across from washer and dryer. - From follow-up inspection 2022-07-18: \*\*Time Extended\*\* - From follow-up inspection 2022-09-07: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1502331

LAKE POINTE APARTMENT HOMES

License Type: Apartment

2880 N WICKHAM RD, MELBOURNE 32935

Inspection Date: 09/06/2022

Inspection Number: 1537247

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: VAUGHAN, COURTNEY

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
Expired on 10/26/2020 for both boilers. - From follow-up inspection 2022-09-06: \*\*Time Extended\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1620364

HILTON GARDEN INN FORT LAUDERDALE SW/MIRAMAR

License Type: Hotel

14501 HOTEL RD, MIRAMAR 33027

Inspection Date: 08/31/2022

Inspection Number: 1167707

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LONDONO, GLORIA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2305825

CORAL ROC MOTEL

License Type: Motel

1100 N KROME AVENUE, FLORIDA CITY 33034-2426

Inspection Date: 09/08/2022

Inspection Number: 1224962

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: LEIDECKER, EDILMA

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.  
For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Dade County**

License Number: 2329502

BRICKELL GATE INC

License Type: Apartment

1128 NW 4 ST, MIAMI 33128

Inspection Date: 09/09/2022

Inspection Number: 1536836

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: CUDEMOS, VIRNA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Located near apartments #2.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2329367

AC HOTEL MIAMI AVENTURA

License Type: Hotel

20805 BISCAYNE BLVD, AVENTURA 33180

Inspection Date: 08/30/2022

Inspection Number: 1165190

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. As of 6/30/22.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613497

CADENCE AT NOCATEE

License Type: Apartment

380 BURBANK AVE, PONTE VEDRA 32081

Inspection Date: 09/07/2022

Inspection Number: 1535346

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: PERKINS, MARC

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
On the first floor hallway of building 8 by room 108, fire extinguisher in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613210

DOWNTOWN EAST APTS.

License Type: Apartment

888 FRANKLIN ST, JACKSONVILLE 32206

Inspection Date: 09/07/2022

Inspection Number: 1540745

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

04-05-4

No smoke detector provided in guest room/unit. For reporting purposes only.  
In unit 109.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613354

CAROLINE OAKS

License Type: Apartment

5175 N MAIN ST, JACKSONVILLE 32208

Inspection Date: 09/07/2022

Inspection Number: 1537020

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.  
Fire extinguisher by unit 329.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2612657

JACKSONVILLE SPRINGHILL SUITES

License Type: Hotel

4385 SOUTHSIDE BLVD, JACKSONVILLE 32216

Inspection Date: 09/07/2022

Inspection Number: 1165440

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
 Jurisdiction 135005 exp 06/06/2021 & Jurisdiction 135006 exp 06/06/2021 \*\*Repeat Violation\*\*

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2609173

STAYABLE SUITES JACKSONVILLE

License Type: Motel

812 DUNN AVE, JACKSONVILLE 32218

Inspection Date: 09/07/2022

Inspection Number: 1225997

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing by rooms 124 and 228.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2612062

COLONY AT DEERWOOD (THE)

License Type: Apartment

10010 SKINNER LAKE DR, JACKSONVILLE 32246

Inspection Date: 09/08/2022

Inspection Number: 1545618

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: CENTENO, ANGEL

Violation CodeObservationViolation Citation

12-04-4

- From initial inspection : High Priority - Balcony/stairway/platform collapsed.  
Observed handicap railing collapsed located at ramp next to dumpster area. **\*\*Warning\*\*** - From follow-up inspection 2022-09-08: Observed railing to be still the same at callback. Maintenance stated company has been called to fix. **\*\*Time Extended\*\***

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.

12-04-4

High Priority - Balcony/stairway/platform collapsed.  
Observed handicap railing collapsed located at ramp next to dumpster area. **\*\*Warning\*\***

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.



**Duval County**

License Number: 2612170

EXTENDED STAY AMERICA

License Type: Motel

10020 SKINNER LAKE DR, JACKSONVILLE 32246

Inspection Date: 09/07/2022

Inspection Number: 1225038

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CENTENO, ANGEL

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
Observed the boiler certifications to be expired 7-29-2022

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2612691

INTOWN SUITES

License Type: Motel

11451 BEACH BLVD, JACKSONVILLE 32246

Inspection Date: 09/07/2022

Inspection Number: 1224140

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CENTENO, ANGEL

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.  
Observed the property to not have boiler certificates.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hernando County**

License Number: 3700841

MOTEL 6

License Type: Motel

6172 COMMERCIAL WAY, SPRING HILL 34606

Inspection Date: 09/08/2022

Inspection Number: 1226083

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: DAHL, MICHELE

Violation CodeObservationViolation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.  
In public laundry room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3900493

MIRELA NORTH

License Type: Apartment

8412 RIO BRAVO CT, TAMPA 33617

Inspection Date: 09/07/2022

Inspection Number: 1556208

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: MARQUETTI, JESSICA

Violation Code

Observation

Violation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.

Building 33 units 7&8

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Leon County**

License Number: 4701482

HOWARD JOHNSON INN

License Type: Motel

2726 N MONROE ST, TALLAHASSEE 32303

Inspection Date: 09/07/2022

Inspection Number: 1226009

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: TRUESDALE, CHRIS

Violation CodeObservationViolation Citation

04-02-4

No smoke detector provided in guest room/unit. Observed smoke alarm not attached in room 125.  
Observed smoke alarm hanging by wire in room 124. For reporting purposes only.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Martin County**

License Number: 5301450

CARIBBEAN SHORES MOTEL AND COTTAGE

License Type: Motel

3670 NE INDIAN RIVER DR, JENSEN BEACH 34957

Inspection Date: 09/09/2022

Inspection Number: 1224558

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

04-04-4

Fire alarm control panel has no power. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Martin County**

License Number: 5301452

CARIBBEAN SHORES WATERFRONT RESORT

License Type: Hotel

2625 NE INDIAN RIVER DR, JENSEN BEACH 34957

Inspection Date: 09/06/2022

Inspection Number: 1164928

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Laundry room panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5809597

RESIDENCE INN BY MARRIOTT

License Type: Hotel

11651 UNIVERSITY BLVD, ORLANDO 32817

Inspection Date: 09/08/2022

Inspection Number: 1166855

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: VAZQUEZ, JULITZA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Orange County**

License Number: 5810970

TRAVEL LODGE

License Type: Motel

7200 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 09/07/2022

Inspection Number: 1224194

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -  
Complied

Inspector Name: BACHOO, SAVITRI

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-09-07: Construction is in progress \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5811203

TOWNEPLACE SUITES BY MARRIOTT

License Type: Hotel

5433 ALTAMIRA DR, ORLANDO 32819

Inspection Date: 09/07/2022

Inspection Number: 1166573

Inspection Type: Routine - Lodging

Inspection Disposition: Warning  
Issued

Inspector Name: BACHOO, SAVITRI

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available.  
For reporting purposes only.Boiler has 499,900 btu.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5803414

HILTON ORLANDO BUENA VISTA PALACE

License Type: Hotel

1900 BUENA VISTA DR, LAKE BUENA VISTA 32830

Inspection Date: 09/07/2022

Inspection Number: 1166134

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.  
Observed boiler certificate expired 8/13/2022

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6005456

MARRIOTT WEST PALM BEACH HOTEL

License Type: Hotel

1001 OKEECHOBEE BLVD, WEST PALM BEACH 33401

Inspection Date: 09/07/2022

Inspection Number: 1164919

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: AHLE, ROBERT

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:  
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.  
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6014058

WYNDHAM GRAND JUPITER AT HARBOURSIDE PLACE

License Type: Hotel

122 SOUNDINGS AVE, JUPITER 33477

Inspection Date: 09/09/2022

Inspection Number: 1165667

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GOLDMAN, BARRY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Floor one sounder alarm trouble light.  
\*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6215772

INTOWN SUITES

License Type: Hotel

2833 ROOSEVELT BLVD, CLEARWATER 33760

Inspection Date: 09/08/2022

Inspection Number: 1166053

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.  
 For reporting purposes only.  
 -smoke detector will make sounds but not flash

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6309271

LAKEVIEW TOWER APARTMENTS

License Type: Apartment

745 AVE A SW, WINTER HAVEN 33880

Inspection Date: 09/06/2022

Inspection Number: 1555968

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: FADEYI, SHANNON

Violation Code

Observation

Violation Citation

08-04-4

- From initial inspection : Boiler certificate not posted in the boiler room. For reporting purposes only. **\*\*Warning\*\*** - From follow-up inspection 2022-09-06: Unable to view. **\*\*Time Extended\*\***

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7401770

BEST WESTERN CASTILLO DEL SOL

License Type: Motel

205 S ATLANTIC AVE, ORMOND BEACH 32176

Inspection Date: 09/08/2022

Inspection Number: 1226082

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Volusia County**

License Number: 7406522

OM HOSPITALITY OF DELTONA LLC

License Type: Motel

481 DELTONA BLVD, DELTONA 32725

Inspection Date: 09/08/2022

Inspection Number: 1226063

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell. For reporting purposes only.  
Two tanks stored in maintenance shop.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.