

Brevard County

License Number: 1500324

MOTEL 6 - COCOA BEACH

License Type: Motel

3701 N ATLANTIC AVE, COCOA BEACH 32931

Inspection Date: 09/16/2022

Inspection Number: 1225498

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HICKS, GEORGE RANDY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Fire control panel in supervisory guide.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620895

RESIDENCE INN POMPANO BEACH

License Type: Hotel

2880 CENTER PORT CIR, POMPANO BEACH 33064

Inspection Date: 09/13/2022

Inspection Number: 1165328

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: DEJONG, STEVEN

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-09-13: **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1618774

STUDIO 6 CORAL SPRINGS

License Type: Motel

5645 N UNIVERSITY DR, CORAL SPRINGS 33067

Inspection Date: 09/14/2022

Inspection Number: 1225500

Inspection Type: Lodging-Licensing

Inspection Disposition: Call Back -

Inspector Name: BRADY, OSSIAN

Inspection

Complied

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

Observed boiler certifications 055345 03/13/2021, 055346 03/13/2021. - From follow-up inspection 2022-08-29: Certification process still ongoing. ****Time Extended**** - From follow-up inspection 2022-09-14: Boiler was inspected on 09/09/22, certification not yet available. ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2000920

STAY SUITES OF AMERICA

License Type: Hotel

1656 WELLS RD, ORANGE PARK 32073

Inspection Date: 09/12/2022

Inspection Number: 1167679

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JONES, CHAUNA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Certificate expired 3/27/22. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326353

VELASCO APARTMENTS

License Type: Apartment

1137 SW 4 ST # 3, MIAMI 33130

Inspection Date: 08/03/2022

Inspection Number: 1513669

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: SWIGERT, RICHARD

Violation CodeObservationViolation Citation

01-06-4

- From initial inspection : Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed next apartments 1 and 3. - From follow-up inspection 2022-08-03: Portable fire extinguisher locked in box with no means of access to the fire extinguisher. For reporting purposes only. Observed next apartments 1 and 3. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309756

SEVEN SEAS MOTEL

License Type: Motel

5940 BISCAYNE BLVD, MIAMI 33137

Inspection Date: 09/16/2022

Inspection Number: 1224836

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SEYBA, JAMES

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Between rooms 204 & 205.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329171

Z OCEAN

License Type: Hotel

1437 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 09/14/2022

Inspection Number: 1164718

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HODGE, KRISTEN

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. As per DIVISION OF STATE FIRE MARSHAL, BOILER SAFETY SECTION, hotel establishment has a active boiler under justification 122631: Certificate Expiration: 03/04/2022

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303039

JBR PROPERTIES 3330 LLC

License Type: Apartment

3330 NW 48 TERRACE, MIAMI 33142

Inspection Date: 09/12/2022

Inspection Number: 1546368

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only.
Observed fire extinguisher between units 209 and 210 is in the overcharged zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Observed fire extinguisher between units 102 and 103 missing a breakage device

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2318475

RED ROOF PLUS+ MIAMI AIRPORT

License Type: Hotel

3401 NW LEJEUNE RD, MIAMI 33142

Inspection Date: 09/15/2022

Inspection Number: 1164862

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed fire alarm panel showing trouble in second building

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326117

HOLIDAY INN EAST

License Type: Hotel

11520 SW 88 ST, MIAMI 33176

Inspection Date: 09/16/2022

Inspection Number: 1166012

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BENITEZ, YOANNA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Behind front desk.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329376

WOODSPRING SUITES MIAMI SOUTHWEST

License Type: Hotel

16055 SW 117 AVE, MIAMI 33177

Inspection Date: 09/09/2022

Inspection Number: 1166270

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed system trouble light illuminated. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328943

BEST WESTERN PLUS MIAMI DORAL

License Type: Motel

3875 NW 107 AVE, MIAMI 33178

Inspection Date: 09/12/2022

Inspection Number: 1224107

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: SWIGERT, RICHARD

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. - From follow-up inspection 2022-09-12: Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Time Extended****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329406

NORTH BAYSHORE CONDOMINIUM #1 LLC

License Type: Apartment

11630-11640 N BAYSHORE DR, NORTH MIAMI 33181

Inspection Date: 09/14/2022

Inspection Number: 1556278

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: SUAREZ, LEOPOLDO

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

04-06-4

Fire alarm control panel emitting an audible alarm. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329173

BEST WESTERN HOTEL & SUITES

License Type: Hotel

8560 SW 124 AVE, MIAMI 33183

Inspection Date: 09/15/2022

Inspection Number: 1166610

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329493

HAMPTON INN & SUITES

License Type: Hotel

14060 SW 138TH AVE, MIAMI 33186

Inspection Date: 09/12/2022

Inspection Number: 1165201

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Observed trouble light illuminated,main panel.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2609702

COUNTRY INN & SUITES BY RADISSON, JACKSONVILLE I-95 SOUTH, FL

License Type: Hotel

4690 SALISBURY RD, JACKSONVILLE 32256

Inspection Date: 09/15/2022

Inspection Number: 1167867

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: JEFFERS, MARY-BETH

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available.
 For reporting purposes only.
 Operator unable to provide boiler certificate during this inspection

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hernando County

License Number: 3700962

MICROTEL INN & SUITES

License Type: Hotel

4881 COMMERCIAL WAY, SPRING HILL 34606

Inspection Date: 09/16/2022

Inspection Number: 1167938

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In housekeeping room on 2nd floor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Highlands County

License Number: 3800987

LAKESIDE COTTAGES

License Type: Motel

740 S LAKEVIEW DR, LAKE PLACID 33852

Inspection Date: 09/12/2022

Inspection Number: 1223422

Inspection Type: Routine - Lodging

Inspection Disposition: Warning Issued

Inspector Name: JACKS, ALBERT

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only in unit six. Maintenance is going to hardware store to purchase one. Operator placed hearing impaired smoke alarm in un maintenance returns. ****Corrected On-Site****

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3901457

NEW RIVER APARTMENTS

License Type: Apartment

4009 N HOWARD AVE, TAMPA 33607

Inspection Date: 09/12/2022

Inspection Number: 1556272

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: RAHAL, LAUREN

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only. Electrical wiring on north west side of building with exposed outlet.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3904199

NEW RIVER APARTMENTS

License Type: Apartment

4009 N HOWARD AVE, TAMPA 33607

Inspection Date: 09/12/2022

Inspection Number: 1556273

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: RAHAL, LAUREN

Violation Code

Observation

Violation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only. Electrical wiring on north west side of building with exposed outlet.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3913627

WESTIN TAMPA BAY

License Type: Hotel

7627 COURTNEY CAMPBELL CAUSEWAY, TAMPA 33607

Inspection Date: 09/16/2022

Inspection Number: 1164882

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CANNELLA, MARK

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900493

MIRELA NORTH

License Type: Apartment

8412 RIO BRAVO CT, TAMPA 33617

Inspection Date: 09/12/2022

Inspection Number: 1556208

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: REGAS, ANTHONY

Violation Code

Observation

Violation Citation

04-06-4

- From initial inspection : Fire alarm control panel emitting an audibl
alarm. For reporting purposes only.

Building 33 units 7&8 - From follow-up inspection 2022-09-12:
Observed the fire alarm still emitting alarm. ****Time Extended****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4701676

TALLAHASSEE CAPITAL COURTYARD

License Type: Hotel

1018 APALACHEE PKWY, TALLAHASSEE 32301

Inspection Date: 09/15/2022

Inspection Number: 1166884

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WARD, JOWANNA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler certificate expired. Engineer states that State of FI and Marriott now require CO2 detectors. Starr Indemnity is set to come back out to test carbon monoxide detectors.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301451

THE BREEZY INN INC

License Type: Motel

3350 NE INDIAN RIVER DR, JENSEN BEACH 34957

Inspection Date: 09/15/2022

Inspection Number: 1226156

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: ROTONDI, VICTOR

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Lobby area.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400600

EDGEWATER LODGE

License Type: Motel

65651 OVERSEAS HWY, LONG KEY 33001

Inspection Date: 09/13/2022

Inspection Number: 1224710

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only.
Unit 14

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400347

FISHER INN RESORT

License Type: Motel

84951 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 09/15/2022

Inspection Number: 1223223

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

03-01-4

No fire sprinkler system installed in a transient lodging establishment three stories or more in height, or over 75 feet in height. For reporting purposes only.

509.215 and 509.032(2)(d) FS Reporting: 509.215 Any public lodging establishment, as defined in this chapter, which is of three stories or more, or over 75 feet in height shall be equipped with an automatic sprinkler system installed in compliance with the provisions prescribed in the National Fire Protection Association publication NFPA No. 13 "Standards for the Installation of Sprinkler Systems. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400617

KINGSAIL RESORT MOTEL

License Type: Motel

7050 OVERSEAS HWY, MARATHON 330503140

Inspection Date: 09/13/2022

Inspection Number: 1225196

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

04-03-4

- From initial inspection : Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only
Unit 122 - From follow-up inspection 2022-08-17:
Unable to view unit 122 **Time Extended** - From follow-up
inspection 2022-09-13: **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800476

CONTEMPORY RESORT HTL

License Type: Hotel

4600 N WORLD DR, BAY LAKE 32830

Inspection Date: 09/15/2022

Inspection Number: 1166780

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificates or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800432

POLYNESIAN VILLAGE HTL

License Type: Hotel

1600 SEVEN SEAS DR, LAKE BUENA VISTA 32830

Inspection Date: 09/15/2022

Inspection Number: 1165710

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

08-01-4

Boiler certificates or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5804911

DISNEY'S CARRIBBEAN BEACH REST

License Type: Motel

1114 CAYMAN WAY, LAKE BUENA VISTA 32830

Inspection Date: 09/15/2022

Inspection Number: 1223716

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
All boiler certificates are expired 12/13/2021 spoke to engineering w receive new copies of boilers after CO2 devices are installed.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

Osceola County

License Number: 5900233

MAINGATE LAKESIDE RESORT

License Type: Hotel

7769 W. IRLO BRONSON MEMORIAL HWY., KISSIMMEE 34747

Osceola County

Inspection Date: 09/16/2022

Inspection Number: 1167012

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: IRVEN, RYAN

Violation CodeObservationViolation Citation

04-01-4	<p>- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. **Repeat Violation</p> <p>- From follow-up inspection 2022-08-12: **Time Extended** - Fro</p> <p>follow-up inspection 2022-09-16: **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
08-01-4	<p>- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. **Repeat Violation**</p> <p>- From follow-up inspection 2022-08-12: **Time Extended**</p> <p>- From follow-up inspection 2022-09-16: **Time Extended**</p>	<p>61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.</p> <p>509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Palm Beach County

License Number: 6005720

INN AT BOYNTON BEACH

License Type: Hotel

480 W BOYNTON BEACH BLVD, BOYNTON BEACH 33435

Inspection Date: 09/13/2022

Inspection Number: 1167682

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: AHLE, ROBERT

Violation Code

Observation

Violation Citation

04-07-4

- From initial inspection : Trouble/alarm light illuminated on the smoke detector panel connected to the fire alarm system. For reporting purposes only. - From follow-up inspection 2022-09-13: **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6007059

ADVENIR AT LA COSTA

License Type: Apartment

4101 MAHOGANY DR, BOYNTON BEACH 33436

Inspection Date: 09/14/2022

Inspection Number: 1555510

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: AHLE, ROBERT

Violation Code

Observation

Violation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Observe at building 15 at apt 15205 ****Repeat Violation**** - From follow-up inspection 2022-07-14: Same - From follow-up inspection 2022-08-01: Same
- From follow-up inspection 2022-08-15: Same ****Time Extended***
- From follow-up inspection 2022-09-14: Same

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

07-04-4

- From initial inspection : Electrical outlet damaged to indicate a malfunction. For reporting purposes only.
Observe at building 14 on third floor light hanging off wall and building 1 at first floor 1105 - From follow-up inspection 2022-07-14: Same
- From follow-up inspection 2022-08-01: Building 14 repaired Building 1 same conditions - From follow-up inspection 2022-08-15: Building 1 same condition
Building 14: light fixed ****Time Extended**** - From follow-up inspection 2022-09-14: Observed light hanging

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

Pinellas County

License Number: 6200241

DAYS INN/SUPER 8

License Type: Motel

5005 34TH ST N, ST. PETERSBURG 33714

Pinellas County

Inspection Date: 09/12/2022

Inspection Number: 1226101

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CORRADO, NICHOLAS

Violation CodeObservationViolation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In front of room 258	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-03-4	Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing fire extinguisher in front of room 266, 104	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble light for zone 1 north building	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

License Number: 6207251

JEFFERSON APARTMENTS

License Type: Apartment

121 N JEFFERSON AVE, CLEARWATER 33755

Inspection Date: 09/15/2022

Inspection Number: 1550545

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection

Inspector Name: KLINGENSMITH, DESIREE

Completed - No Further Action

Violation Code Observation

Violation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. -Between apartments 28 and 29.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	---	---

Pinellas County

License Number: 6215803

OPAL SANDS RESORT

License Type: Hotel

430 S GULFVIEW BLVD, CLEARWATER 33767

Inspection Date: 09/15/2022

Inspection Number: 1165601

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. F1124543, F1124544, F1124545. Exp 7/22/22 - From follow-up inspection 2022-09-15: **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6900381

OPAL HOTEL & SUITES

License Type: Motel

230 W SR 436, ALTAMONTE SPRINGS 32714

Inspection Date: 09/15/2022

Inspection Number: 1225681

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: MARTIN, LESLIE

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
-063625, 098805, 098806 expired 4/15/21. ****Repeat Violation****
From follow-up inspection 2022-09-15: ****Time Extended****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903625

LA QUINTA INN & SUITES

License Type: Hotel

1060 GREENWOOD BLVD, LAKE MARY 32746

Inspection Date: 09/15/2022

Inspection Number: 1166547

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Operator has had the inspection and is waiting on the certificates will follow up at second yearly inspection

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903520

THE TRAVIS ON PARK

License Type: Apartment

606 PARK AVE, SANFORD 32771

Inspection Date: 09/13/2022

Inspection Number: 1551014

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANGEL, TERRY

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location. Fire extinguisher holder present and no fire extinguisher. For reporting purposes only.
North side of building.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501218

OCEAN SANDS BEACH INN

License Type: Motel

3465 COASTAL HWY, SAINT AUGUSTINE 32084

Inspection Date: 09/16/2022

Inspection Number: 1225336

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: MAKOWSKI, JARED

Violation Code

Observation

Violation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested.
For reporting purposes only.
1) hardwired in room 101 not connected. Discussed with person in charge. ****Warning****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400503

BAYMONT INN & SUITES

License Type: Motel

2725 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 09/15/2022

Inspection Number: 1226124

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

04-03-4

Smoke detector/alarm in guest room/unit damaged as to appear to be inoperable. For reporting purposes only.
-beepin in upper laundry storage

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
Whelen -did not flash

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406514

THE DAYTONA AUTOGRAPH COLLECTION

License Type: Hotel

1870 VICTORY CIR, DAYTONA BEACH 32114

Inspection Date: 09/16/2022

Inspection Number: 1164854

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
135766 ,5/19/22

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401632

HOLIDAY INN RESORT DAYTONA BEACH OCEAN FRONT

License Type: Motel

1615 S ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 09/12/2022

Inspection Number: 1223653

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

04-04-4

- From initial inspection : Fire alarm control panel has no power. For reporting purposes only.
- From follow-up inspection 2022-09-12:
Time Extended

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405077

ALOHA MOTEL APTS

License Type: Motel

6700 TURTLE MOUND RD, NEW SMYRNA BCH 321694919

Inspection Date: 09/12/2022

Inspection Number: 1222071

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

12-04-4

- From initial inspection : High Priority - Walkway on second floor exterior wood rotted. east side near sliding glass door. ****Warning****
 - From follow-up inspection 2022-06-06: Area cordoned off to prevent access. ****Time Extended**** - From follow-up inspection 2022-09-12: Stairs and upstairs deck blocked by caution tape to prevent access ****Time Extended****

61C-1.004(5) FAC High Priority: All building structural components, attachments and fixtures shall be kept in good repair.