

Brevard County

License Number: 1505704

DOUBLETREE BY HILTON COCOA BEACH OCEANFRONT

License Type: Hotel

2080 N ATLANTIC AVE, COCOA BEACH 32931

Inspection Date: 09/19/2022

Inspection Number: 1165735

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Trouble 5 on display.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2317880

COMFORT INN AND SUITES DOWNTOWN/BRICKELL

License Type: Hotel

100 SE 4TH ST, MIAMI 33131

Inspection Date: 09/23/2022

Inspection Number: 1167058

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GARCIA, B OSCAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2306762

MOTEL 77 NEW 7

License Type: Motel

3021 SW 8 ST, MIAMI 33135

Inspection Date: 09/21/2022

Inspection Number: 1224832

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Observed the hearing impaired with no battery and no plug. - From follow-up inspection 2022-09-21: Observed the hearing impaired with no batte and no plug. **Admin Complaint**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329715

MEMEC USA LLC

License Type: Apartment

1553 SW 2 ST, APTS 1,4,5,6,7,9,12,15,16,21, MIAMI 33135

Inspection Date: 09/21/2022

Inspection Number: 1514344

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: HENLEY, LATONYA

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Warning**** - From follow-up inspection 2022-09-21: Trouble/alarm light illuminate on the fire alarm control panel. For reporting purposes only. ****Time Extended****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329336

THE MERIDIAN HOTEL

License Type: Hotel

418 MERIDIAN AVE, MIAMI BEACH 33139

Inspection Date: 09/20/2022

Inspection Number: 1166280

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329400

HENROSA HOTEL

License Type: Hotel

1435 COLLINS AVE, MIAMI BEACH 33139

Inspection Date: 09/21/2022

Inspection Number: 1165903

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HODGE, KRISTEN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel locate behind front desk. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329464

DAKOTA PARK SOUTH INC

License Type: Apartment

1036 LENOX AVE, MIAMI BEACH 33139

Inspection Date: 09/20/2022

Inspection Number: 1536694

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation Code

Observation

Violation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
No glass breaking device available on the first and second floor fire extinguishers **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330885

726 MICHIGAN

License Type: Apartment

726 MICHIGAN AVE, MIAMI BEACH 33139

Inspection Date: 09/21/2022

Inspection Number: 1556314

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: HODGE, KRISTEN

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-04-4

No portable fire extinguisher present on the premises. For reporting purposes only. At the time of inspection observed no fire extinguisher on outside of apartment building's or sign stating that fire extinguishers are located in each unit. All units occupied at the time of inspection.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2303535

THE BROADMOOR MIAMI BEACH

License Type: Hotel

7450 OCEAN TER, MIAMI BEACH 33141

Inspection Date: 09/19/2022

Inspection Number: 1167957

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Missing breakin device on extinguisher located on 3rd and 7 floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2302132

MERLIN APTS LLC

License Type: Apartment

1245 NW 58 ST, MIAMI 33142

Inspection Date: 09/20/2022

Inspection Number: 1546592

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge at fire extinguisher between units 9 and 10 For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Observed fire extinguisher between units 9 and 10 missing breakage device

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2318819

J P VISTA LLC

License Type: Apartment

3226 3234 NW 22 AVE, MIAMI 33142

Dade County

Inspection Date: 09/23/2022

Inspection Number: 1553340

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BROWN, JARON

Violation CodeObservationViolation Citation

01-02-4	Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Observed fire extinguisher next to unit14 in need of a recharge	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
01-06-4	Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed fire extinguisher in meter room missing breakage device.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell. For reporting purposes only. Observed propane cylinder under stairway across from unit 8	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

License Number: 2302979	ROM APARTMENT	
License Type: Apartment	2970 NW 61 ST, MIAMI	331422263
Inspection Date: 09/20/2022	Inspection Number: 1538089	Inspection Type: Routine - Lodging
Inspector Name: BROWN, JARON		Inspection Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
02-08-4	Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell. For reporting purposes only. Observed propane tank under stairway next to unit 2972	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2328341

HAMPTON INN MIAMI DADELAND

License Type: Hotel

8200 SW 70 AVE, MIAMI 33143

Inspection Date: 09/19/2022

Inspection Number: 1166955

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PICO, JORGE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329090

MARENAS RESORT

License Type: Hotel

18683 COLLINS AVE, SUNNY ISLES BEACH 33160

Inspection Date: 09/21/2022

Inspection Number: 1165942

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. As of 10/28/21.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2330603

ELIORAH PROPERTIES

License Type: Apartment

1595 NE 125 ST, NORTH MIAMI 33161

Inspection Date: 09/21/2022

Inspection Number: 1541475

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SUAREZ, LEOPOLDO

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Between Apts 6 and 7.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2326954

PEPPER COVE APTS

License Type: Apartment

9300 SW 137 AVE, MIAMI 33186

Inspection Date: 09/16/2022

Inspection Number: 1545626

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. Observed at building 7.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613404

PEOPLES CHOICE APARTMENTS

License Type: Apartment

7154 - 7166 CONANT AVE, JACKSONVILLE 32210

Inspection Date: 09/21/2022

Inspection Number: 1556347

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: MERCER, THOMAS

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Missing from boxes by unit 2 & 12 of 7166 building

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2609386

SHAKIR ECONOMY MOTEL

License Type: Motel

7992 NEW KINGS RD, JACKSONVILLE 322193631

Inspection Date: 09/21/2022

Inspection Number: 1225376

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher next to unit 9

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613222

HOMEWOOD SUITES

License Type: Hotel

10434 MIDTOWN PKWY, JACKSONVILLE 32246

Inspection Date: 09/20/2022

Inspection Number: 1166859

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: CENTENO, ANGEL

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
Observed Boiler certificate Jurisdiction #132876 expired 12-12-2021
Observed Boiler certificate Jurisdiction #132877 expired 12-12-2021
****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2700190

WESTERN INN

License Type: Motel

4126 MOBILE HWY, PENSACOLA 32506-4204

Inspection Date: 09/23/2022

Inspection Number: 1224388

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only:
- expired 02/25/2022. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800590

FAIRFIELD INN & SUITES

License Type: Hotel

400 OLD KINGS RD, PALM COAST 32137

Inspection Date: 09/20/2022

Inspection Number: 1165082

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: HARTMANN, MICHELLE

Violation Code

Observation

Violation Citation

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only.
Hearing impaired detectors in room 125 has audio but no visual alarm, and in 103 flashes but no audio alarm. ****Admin Complaint****
- From follow-up inspection 2022-09-20: Time extended for 30 days.
****Time Extended****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3914065

SENTOSA RIVERVIEW

License Type: Apartment

10210 FALCON GATE LOOP, RIVERVIEW 33569

Inspection Date: 09/20/2022

Inspection Number: 1533908

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: EHLERS, MICHAEL

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Building 7 unit 101.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3900493

MIRELA NORTH

License Type: Apartment

8412 RIO BRAVO CT, TAMPA 33617

Hillsborough County

Inspection Date: 09/20/2022

Inspection Number: 1556208

Inspection Type: Complaint Full

Inspection Disposition: Call Back -

Inspector Name: VELAZQUEZ, STEPHANIE

Admin. complaint recommended

Violation Code

Observation

Violation Citation

04-06-4	<p>- From initial inspection : Fire alarm control panel emitting an audible alarm. For reporting purposes only.</p> <p>Building 33 units 7&8 - From follow-up inspection 2022-09-12: Observed the fire alarm still emitting alarm. **Time Extended** - From follow-up inspection 2022-09-20: **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
04-06-4	<p>- From initial inspection : Fire alarm control panel emitting an audible alarm. For reporting purposes only.</p> <p>Building 33 units 7&8 **Repeat Violation** - From follow-up inspection 2022-09-21: **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Hillsborough County

04-06-4	<p>- From initial inspection : Fire alarm control panel emitting an audible alarm. For reporting purposes only. Building 33 units 7&8 **Repeat Violation** inspection 2022-09-21: **Time Extended** inspection 2022-09-22: **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
04-06-4	<p>- From initial inspection : Fire alarm control panel emitting an audible alarm. For reporting purposes only. Building 33 units 7&8 **Repeat Violation** inspection 2022-09-21: **Time Extended** inspection 2022-09-22: **Time Extended** inspection 2022-09-23: **Time Extended**</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>
04-06-4	<p>Fire alarm control panel emitting an audible alarm. For reporting purposes only. Building 33 units 7&8 **Repeat Violation**</p>	<p>509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.</p>

Indian River County

License Number: 4100234

HIGHLAND APARTMENTS

License Type: Apartment

1655 HIGHLAND AVE, VERO BEACH 32960

Inspection Date: 09/19/2022

Inspection Number: 1551966

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: SCHUCK, GREGORY

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. In laundry room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4701795

BEST WESTERN PRIDE INN & SUITES

License Type: Motel

2016 APALACHEE PKWY, TALLAHASSEE 32301

Inspection Date: 09/23/2022

Inspection Number: 1223647

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WARD, JOWANNA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Observed boiler certificate expired on 6/11/22. ****Warning****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400007

POSTCARD INN THE COTTAGES

License Type: Motel

84001 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 09/20/2022

Inspection Number: 1223770

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WHITEHURST, SCOTT

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400075

POSTCARD INN MAIN TOWER

License Type: Motel

84001 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 09/20/2022

Inspection Number: 1223202

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400679

POSTCARD INN

License Type: Motel

84001 OVERSEAS HWY, ISLAMORADA 33036

Inspection Date: 09/20/2022

Inspection Number: 1224839

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WHITEHURST, SCOTT

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400103

THE SAINT HOTEL KEY WEST

License Type: Hotel

417 EATON ST, KEY WEST 33040

Inspection Date: 09/20/2022

Inspection Number: 1165569

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5400201

PIER HOUSE

License Type: Motel

1 DUVAL ST, KEY WEST 33040

Inspection Date: 09/20/2022

Inspection Number: 1223335

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ELDER, AUDREY

Violation CodeObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-04-4	Boiler certificate not posted in the boiler room. For reporting purposes only. Observed certificate posted expired on 3-9-2020. **Repeat Violation	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report shall be posted in the boiler room. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500972

HAMMAGE & SKEET LLC

License Type: Apartment

37093 TESTONE LN, HILLIARD 32046

Inspection Date: 09/23/2022

Inspection Number: 1536551

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROZIER, TORRANCE

Violation Code

Observation

Violation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored at front door . For reporting purposes only.
 Door number 3
 Door number 1

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5808506

COURTYARD BY MARRIOTT

License Type: Hotel

12000 COLLEGIATE WAY, ORLANDO 32817

Inspection Date: 09/21/2022

Inspection Number: 1166856

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VAZQUEZ, JULITZA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809083

MONUMENTAL HOTEL ORLANDO

License Type: Hotel

12120 INTERNATIONAL DR, ORLANDO 32821

Inspection Date: 09/22/2022

Inspection Number: 1166782

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LEVINS, NICHOLAS

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811198

ALOFT ORLANDO INTERNATIONAL DRIVE

License Type: Hotel

5730 CENTRAL FLORIDA PARKWAY, ORLANDO 32821

Orange County

Inspection Date: 09/23/2022

Inspection Number: 1165167

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LEVINS, NICHOLAS

Violation CodeObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800075

DIAMOND RESORTS INTERNATIONAL

License Type: Vacation Rental - Condo

8317 S LK BRYAN BEACH BLVD, ORLANDO 328216312

Inspection Date: 09/16/2022

Inspection Number: 1089486

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LEVINS, NICHOLAS

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5800160

KNIGHTS INN

License Type: Motel

5870 S ORANGE BLOSSOM TRL, ORLANDO 32839

Inspection Date: 09/23/2022

Inspection Number: 1223092

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PASIECKI, VICTORIA

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Second floor near guest laundry **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5907020

DISNEY'S ALL STAR MUSIC RESORT

License Type: Hotel

1801 W BUENA VISTA DR, BAY LAKE 328301000

Inspection Date: 09/23/2022

Inspection Number: 1166662

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation Code

Observation

Violation Citation

06-03-4

Marked exit light For reporting purposes only.
 Observed exit lights shield missing and loose from the stand
 exposed wires located on the second floor.
 Manager notify engineering staff. ****Corrective Action Taken****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5900225

SERALAGO HOTEL AND SUITES MAINGATE EAST

License Type: Hotel

5678 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 09/23/2022

Inspection Number: 1167011

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

04-01-4

- From initial inspection : Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only./ Ground fault at main fire panel - From follow-up inspection 2022-08-29: **Time Extended** - From follow-up inspection 2022-09-23: **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6001569

ROYAL INN

License Type: Motel

675 ROYAL PALM BEACH BLVD, ROYAL PALM BEACH 33411-7635

Inspection Date: 09/20/2022

Inspection Number: 1224139

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GOODWIN, NICHOLAS

Violation CodeObservationViolation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Observed at 639

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014059

HOLIDAY INN EXPRESS & SUITES

License Type: Hotel

1251 HYPOLUXO RD, LANTANA 33462

Inspection Date: 09/22/2022

Inspection Number: 1166940

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -

Inspector Name: AHLE, ROBERT

Admin. complaint recommended

Violation Code

Observation

Violation Citation

05-02-5

- From initial inspection : Hearing-impaired smoke detector is not functioning guest covered strobe light, hard wired in room 105. Operator uncovered.
 For reporting purposes only. ****Corrected On-Site**** - From follow-up inspection 2022-09-22: ****Time Extended****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6213380

TAHITIAN RESORT

License Type: Motel

11320 GULF BLVD, TREASURE ISLAND 33706

Inspection Date: 09/20/2022

Inspection Number: 1224022

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MURPHY, JAMES

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Outside room 123.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
In guest laundry room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6215785

COCONUT COVE ALL SUITE RESORT

License Type: Hotel

678 S GULFVIEW BLVD, CLEARWATER BEACH 33767

Inspection Date: 09/22/2022

Inspection Number: 1166569

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6205575

QUALITY INN & SUITES

License Type: Hotel

38724 US HWY 19 N, TARPON SPRINGS 34689

Inspection Date: 09/20/2022

Inspection Number: 1165117

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: AIELLO, ROCCI

Violation CodeObservationViolation Citation

05-02-5

Hearing-impaired smoke detector is not functioning when tested. For reporting purposes only. Detector was a hard wire, but was fitter with a plug in outlet, the sound functions properly, but the light does not work. Operator states he has more hard wired in the handicapped rooms, but none available at time of inspection.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6309189

WOODSPRING SUITES DAVENPORT

License Type: Hotel

702 CHAMPIONS DR, DAVENPORT 33897

Inspection Date: 09/22/2022

Inspection Number: 1164871

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: JACKSON, SHARON

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6801281

HYATT REGENCY SARASOTA

License Type: Hotel

1000 BLVD OF THE ARTS, SARASOTA 34236

Inspection Date: 09/19/2022

Inspection Number: 1166570

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804758

THE WESTIN SARASOTA

License Type: Hotel

1175 N GULFSTREAM AVE, SARASOTA 34236

Inspection Date: 09/20/2022

Inspection Number: 1165055

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6600043

SANDPIPER BAY RESORT

License Type: Hotel

3500 MORNINGSIDE BLVD, PORT ST LUCIE 34952

Inspection Date: 09/23/2022

Inspection Number: 1167916

Inspection Type: Lodging-Licensing
Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JUSTINIANO, SONIA

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

Panel reads Trouble dialed deliver fail. Manager states waiting on another phone line to be installed.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602406

SANCTUARY AT WINTERLAKES

License Type: Apartment

5410 NW RABBIT RUN WAY, PORT ST LUCIE 34986

Inspection Date: 09/22/2022

Inspection Number: 1556271

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HARROD, JESSICA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.
Fire panel reading trouble building 4. Manager states she will call.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405884

HOST INN

License Type: Motel

315 BELLEVUE AVE, DAYTONA BEACH 32114

Inspection Date: 09/20/2022

Inspection Number: 1223169

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: PICHARDO, RENEE

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.
Next to 211

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406483

DAYTONA BEACH RESIDENCE INN

License Type: Hotel

1725 RICHARD PETTY BLVD, DAYTONA BEACH 32114

Inspection Date: 09/23/2022

Inspection Number: 1166857

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

06-01-4

Path to door marked as an exit is blocked. For reporting purposes only.
 - path partial block at bottom of stairway with chairs and tables
 ,south side of building

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401092

QUALITY INN

License Type: Motel

700 N ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 09/20/2022

Inspection Number: 1224796

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7400778

SURFSIDE EXECUTIVE APTS

License Type: Apartment

421 AUBURN DR, DAYTONA BCH 321183254

Inspection Date: 09/19/2022

Inspection Number: 1554137

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

07-02-4

- From initial inspection : Frayed electrical wire(s). For reporting purposes only.

East end of building 425 near air conditioning units, running up wall to 2nd floor - From follow-up inspection 2022-09-19: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406714

AVENTINE AT DELAND

License Type: Apartment

400 E HOWRY AVE, DELAND 32724

Inspection Date: 09/19/2022

Inspection Number: 1556369

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: OCASIO-LOPEZ, LISA

Inspection

Completed - No Further Action

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7600597

HILTON SANDESTIN BEACH GULF RESORT AND SPA

License Type: Hotel

4000 SANDESTIN BLVD S, MIRAMAR BEACH 32550

Inspection Date: 09/13/2022

Inspection Number: 1166839

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SHANKLIN, CYNTHIA

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. ****Repeat Violation****

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.