

Alachua County

License Number: 1103004

GREYSTONE APARTMENTS

License Type: Apartment

909, 911,913,915 SW 6 AVE, GAINESVILLE 32601

Inspection Date: 09/26/2022

Inspection Number: 1549882

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: GRODEWALD, PAUL

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher outside of apartment 112.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1305251

RAMADA

License Type: Hotel

4306 W HWY 98, PANAMA CITY 32401

Inspection Date: 09/26/2022

Inspection Number: 1168017

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. Outside 410
****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1300481

VIEUX CARRE APARTMENTS

License Type: Apartment

2405 STANFORD RD, PANAMA CITY 32405

Inspection Date: 09/27/2022

Inspection Number: 1548689

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation CodeObservationViolation Citation

02-08-4

Propane (LP gas) tank having a water capacity greater than 2.7 lbs stored under a stairwell. For reporting purposes only. Stored under landing in front of 119.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bay County

License Number: 1305136

SIENA GARDENS APARTMENTS

License Type: Apartment

901 W 19TH ST, PANAMA CITY 32405

Inspection Date: 09/27/2022

Inspection Number: 1541459

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LYNN, NICKOLAS

Violation Code

Observation

Violation Citation

01-01-4

Portable fire extinguisher pressure gauge indicates the extinguisher is overcharged. For reporting purposes only. Outside 3313.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Bradford County

License Number: 1400002

MAGNOLIA PROPERTIES

License Type: Hotel

137 N WALNUT ST, STARKE 320913224

Inspection Date: 09/26/2022

Inspection Number: 1165792

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: BADDING, MELANIE

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only.
Fire extinguisher by unit 25 with no hammer or way to break glass.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1620857

FERRARA HOLDINGS LLC

License Type: Motel

4288 DAVIE RD, FORT LAUDERDALE 33314

Inspection Date: 09/29/2022

Inspection Number: 1223860

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: GANPAT, INDAR

Violation Code

Observation

Violation Citation

01-03-4

- From initial inspection : Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only. Behind unit #1 - From follow-up inspection 2022-09-29: Observed same **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

Dade County

License Number: 2307942

MIAMI INT'L AIRPORT HOTEL

License Type: Hotel

NW 20TH STREET & LE JEUNE ROAD, MIAMI 33122

Dade County

Inspection Date: 09/30/2022

Inspection Number: 1166513

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SANCHEZ, JAVIER

Violation CodeObservationViolation Citation

04-01-4	Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.	509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
08-03-4	No boiler certificate or insurance inspector's boiler report available. For reporting purposes only. 059146, 059147 no boiler certification provided **Repeat Violation**	61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2317719

BISCAYNE BAY MARRIOTT HOTEL

License Type: Hotel

1633 N BAYSHORE DR, MIAMI 331321261

Inspection Date: 09/30/2022

Inspection Number: 1166588

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CUDEMOS, VIRNA

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329323

RESIDENCE INN MIAMI SOUTH BEACH

License Type: Hotel

1231 17 ST, MIAMI BEACH 33139

Inspection Date: 09/26/2022

Inspection Number: 1166950

Inspection Type: Routine - Lodging

Inspection Disposition: Administrative
complaint recommended

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. Observed boiler jurisdiction number's 098797; 098796 expired on 9/22/2022. A boiler inspection was conducted on 9/07/22, hotel establishment is waiting on follow up inspection from boiler inspector in order to renew and obtain certificates. Reporting For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329488

AC HOTEL MIAMI DADELAND

License Type: Hotel

7695 N KENDALL DR, MIAMI 33156

Inspection Date: 09/27/2022

Inspection Number: 1166253

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PICO, JORGE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2320005

MIAMI MARRIOTT DADELAND

License Type: Hotel

9090 S DADELAND BLVD, MIAMI 331567825

Inspection Date: 09/30/2022

Inspection Number: 1166051

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PICO, JORGE

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2309692

THUNDERBIRD HOTEL

License Type: Motel

18401 COLLINS AVE, MIAMI BEACH 331602497

Inspection Date: 09/27/2022

Inspection Number: 1223247

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: TAYLOR, JOHN

Violation Code

Observation

Violation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. As of 8/20/22.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2319611

MIAMI SPRINGS INN

License Type: Motel

4585 NW 36 ST, MIAMI SPRINGS 33166

Inspection Date: 09/30/2022

Inspection Number: 1223321

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

01-06-4

Portable fire extinguisher locked in a box with no means of access to the fire extinguisher. For reporting purposes only. Observed extinguisher with no braking device located between rooms 204 and 205 on first floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613230

HAMPTON INN & SUITES

License Type: Hotel

13551 AIRPORT CT, JACKSONVILLE 32218

Inspection Date: 09/26/2022

Inspection Number: 1164985

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only.
Fire extinguisher under folding area in laundry area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hendry County

License Number: 3600016

WEST EXPRESS INN

License Type: Motel

433 W SUGARLAND HWY, CLEWISTON 33440

Inspection Date: 09/26/2022

Inspection Number: 1224138

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKS, ALBERT

Violation Code

Observation

Violation Citation

04-02-4

No smoke detector provided in guest room/unit. For reporting purposes only unit 103.

509.215(1) and (2) and 509.032(2)(d) FS Reporting: 509.215(1) Each guest room shall be equipped with an approved listed single-station smoke detector meeting the minimum requirements of NFPA-74 Standards for the Installation, Maintenance and Use of Household Fire Warning Equipment. (2) The building has smoke detectors in each guest room individually annunciating to a panel at a supervised location. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301091

SPRUCE RIDGE APARTMENTS

License Type: Apartment

983 SPRUCE RIDGE DR, STUART 34994

Inspection Date: 09/26/2022

Inspection Number: 1548003

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only. 1st floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5600164

CAPT QUARTERS APTS (THE)

License Type: Apartment

19 CHESTNUT AVE, FT WALTON BCH 325485621

Inspection Date: 09/28/2022

Inspection Number: 1540142

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ADAMSON, ROBERT

Violation CodeObservationViolation Citation

07-01-4

Damaged electrical wire(s). For reporting purposes only.
Upon inspection observed multiple cable boxes in disrepair.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6013984

INTOWN SUITES MILITARY TRAIL

License Type: Motel

5801 N MILITARY TRL, RIVIERA BEACH 33407

Inspection Date: 09/26/2022

Inspection Number: 1224131

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: KHATOON, BEGUM

Violation Code

Observation

Violation Citation

08-01-4

- From initial inspection : Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only. Boiler Jurisdiction No. 099391. Establishment have two boiler - From follow-up inspection 2022-09-26: Not observed **Time Extended**

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6014542

TROPICAL GARDENS REALTY

License Type: Apartment

521 S FEDERAL HWY, LAKE WORTH BEACH 33460

Inspection Date: 09/27/2022

Inspection Number: 1556309

Inspection Type: Lodging-Licensing

Inspection Disposition: Inspection

Inspector Name: FRANCO, BROOKE

Inspection

Completed - No Further Action

Violation Code

Observation

Violation Citation

01-02-4

Portable fire extinguisher pressure gauge indicates the extinguisher is in need of recharge. For reporting purposes only-outside unit 1

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6000929

BREAKERS HOTEL

License Type: Hotel

1 S COUNTY RD, PALM BEACH 33480

Inspection Date: 09/30/2022

Inspection Number: 1165814

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AHLE, ROBERT

Violation Code

Observation

Violation Citation

08-03-4

No boiler certificate or insurance inspector's boiler report available. For reporting purposes only.

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting: 61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers. 509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6203834

THE POSTCARD INN

License Type: Motel

6300 GULF BLVD, ST.PETE BEACH 33706

Inspection Date: 09/26/2022

Inspection Number: 1223783

Inspection Type: Routine - Lodging

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WILMOT, TASHARA

Violation CodeObservationViolation Citation

08-01-4

Boiler certificate or insurance inspector's boiler report expired. For reporting purposes only.
-121747 and 8/18/22

61C-1.004(10) FAC and 509.032(2)(d) FS Reporting:
61C-1.004(10) The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers.
509.032(2)(d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7401632

HOLIDAY INN RESORT DAYTONA BEACH OCEAN FRONT

License Type: Motel

1615 S ATLANTIC AVE, DAYTONA BEACH 32118

Inspection Date: 09/26/2022

Inspection Number: 1223653

Inspection Type: Routine - Lodging

Inspection Disposition: Call Back -
Complied

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

04-04-4

- From initial inspection : Fire alarm control panel has no power. For reporting purposes only. - From follow-up inspection 2022-09-12: **Time Extended** - From follow-up inspection 2022-09-26: Contr Panel continues to show trouble light **Time Extended**

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406503

R & L AMBASSADOR RESORT

License Type: Motel

940 N ATLANTIC BLVD, DAYTONA BEACH 32118

Inspection Date: 09/26/2022

Inspection Number: 1224787

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation Code

Observation

Violation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only.

-manager stated someone is coming out to check system

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406506

WOODSPRING SUITES DAYTONA

License Type: Hotel

2910 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32124

Inspection Date: 09/26/2022

Inspection Number: 1166759

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: COREY, DEREK

Violation CodeObservationViolation Citation

04-01-4

Trouble/alarm light illuminated on the fire alarm control panel. For reporting purposes only. ****Repeat Violation****

509.032(2)(d) FS Reporting: The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Walton County

License Number: 7601179

SUPER 8 MOTEL

License Type: Motel

402 HUGH ADAMS RD, DEFUNIAK SPRINGS 32433

Inspection Date: 09/29/2022

Inspection Number: 1225292

Inspection Type: Routine - Lodging

Inspection Disposition: Warning
Issued

Inspector Name: HORTON, VERONICA

Violation Code

Observation

Violation Citation

01-03-4

Portable fire extinguisher missing from it's designated location (sign present indicating designated location). For reporting purposes only.

Portable Fire Extinguisher missing from following locations, between rooms: 216/217, 220/221, 117/118
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.