

**Alachua County**

License Number: 1102945

BIG LOU'S NY STYLE PIZZERIA

License Type: Permanent Food Service

5 SE 2 AVE, GAINESVILLE 32601

Inspection Date: 07/15/2019

Inspection Number: 2892827

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: WEATHERS, TIM

Violation CodeObservationViolation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only.  
Connection, junction box to right of outside ice machine opened with no cover. Capped wires visible. - From follow-up inspection 2019-07-15: Wiring covered with black tape. Wires not exposed, but not a traditional repair. Per Manager new cover plate has been ordered. \*\*Time Extended\*\* \*\*Corrective Action Taken\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1102556

NOLA'S CAJUN PO'BOY &amp; SEAFOOD

License Type: Permanent Food Service

3200 NW 98 ST, GAINESVILLE 32606

Inspection Date: 07/16/2019

Inspection Number: 2931378

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: WEATHERS, TIM

Violation CodeObservationViolation Citation

46-04-4

- From initial inspection : Unapproved lock. Slide lock on outside of walk-in cooler door has no safety mechanism to allow someone locked inside to release door.  
- From follow-up inspection 2019-07-10: Slide lock still present. \*\*Time Extended\*\*  
- From follow-up inspection 2019-07-16: Slide lock still present on walk-in cooler door. \*\*Time Extended\*\*

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only.  
Light switch to walk-in cooler has no cover. Capped wires in fan compartment of walk-in cooler component hanging from unit. - From follow-up inspection 2019-07-10: Capped wires still hanging from fan compartment in walk-in cooler. Cover to light switch still not present. \*\*Time Extended\*\* - From follow-up inspection 2019-07-16: Capped wires still hanging down. \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1505917		BEN AND JERRY'S MELBOURNE	
License Type: Permanent Food Service		1800 W HIBISCUS BLVD # 118, MELBOURNE 32901	
Inspection Date: 07/15/2019	Inspection Number: 2933010	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MAYNARD, DIANE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1506892		MELBOURNE SEAFOOD STATION INC.	
License Type: Permanent Food Service		2001 S HARBOR CITY BLVD, MELBOURNE 32901	
Inspection Date: 07/19/2019	Inspection Number: 2934396	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: MAYNARD, DIANE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Class k	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1505366		SPESSARD HOLLAND GOLF COURSE	
License Type: Permanent Food Service		2374 OAK ST, MELBOURNE BEACH 32951	
Inspection Date: 07/15/2019	Inspection Number: 2929059	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MAYNARD, DIANE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Broward County**

License Number: 1621692 LOS PINCHOS  
 License Type: Permanent Food Service 1940 HOLLYWOOD BLVD, HOLLYWOOD 33020

Inspection Date: 07/16/2019 Inspection Number: 2901722 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: CHAPDELAINE, MARIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Back gate door, Exit door locked. For reporting purposes only.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. No cover in men's room - From follow-up inspection 2019-07-17: No electric cover in men's room **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. No cover in men's room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1622425 OCEANO BISTRO & LOUNGE  
 License Type: Permanent Food Service 1350 N OCEAN BLVD, POMPANO BEACH 33062

Inspection Date: 07/16/2019 Inspection Number: 2907502 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BURGGRAVE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Both boiler certificates expired on 1/19/2019.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1611718 KFC #11  
 License Type: Permanent Food Service 990 W COMMERCIAL BLVD, FORT LAUDERDALE 33309

Inspection Date: 07/17/2019 Inspection Number: 2896397 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked with boxes. **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Broward County**

License Number: 1621554

MANHATTAN NY PIZZA

License Type: Permanent Food Service

1923 CORDOVA RD, FORT LAUDERDALE 33316

Inspection Date: 07/15/2019

Inspection Number: 2926403

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: PINEROS, MICHELE

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. tabletop fryer on table with hot holding units next to pizza oven.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2103332

PIZZA HUT DELIVERY/CARRY OUT #2269

License Type: Permanent Food Service

15215 COLLIER BLVD #305, NAPLES 34119

Inspection Date: 07/19/2019

Inspection Number: 2910875

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PFENNING, BRUNO

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Operator moved extinguisher to proper location.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2328460		MCDONALDS RESTAURANT	
License Type: Permanent Food Service		4185 W 16 AVE, HIALEAH 33012	
Inspection Date: 07/18/2019	Inspection Number: 2895992	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only. Located back door exit kitchen area. **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2334625		PANDOREE	
License Type: Permanent Food Service		195-197 NW 36 ST, MIAMI 33127	
Inspection Date: 07/17/2019	Inspection Number: 2927590	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Chef cooks eggs on a stove with no hood suppression. Observed fryer under extractor, no hood system. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2327879		POLLO TROPICAL #46	
License Type: Permanent Food Service		3499 BISCAYNE BLVD, MIAMI 331373820	
Inspection Date: 07/15/2019	Inspection Number: 2883647	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back door exit.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2334319		PEI WEI FRESH KITCHEN # 0248	
License Type: Permanent Food Service		12175 S DIXIE HWY, PINECREST 33156	
Inspection Date: 07/17/2019	Inspection Number: 2909372	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TAYLOR, JOHN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed boxes and garbage container blocking back exit.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

**Dade County**

License Number: 2331952

CHERY'S RESTAURANT

License Type: Permanent Food Service

12781 W DIXIE HWY, MIAMI 33161

Inspection Date: 07/18/2019

Inspection Number: 2897049

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: UNZAGA, MILADYS

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed establishment is using a gas propane tank connected to a portable stove to cook rice inside the kitchen area.  
Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335201

RINCONCITO CUBANO #4

License Type: Permanent Food Service

70 NW 107 AVE, MIAMI 33172

Inspection Date: 07/17/2019

Inspection Number: 2926582

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: CRUZ, EDGAR

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2019-07-18:

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2651662

ISLAND DREAM ITALIAN ICE

License Type: Mobile Food Dispensing Vehicle

7841 LEM TURNER RD, JACKSONVILLE 32208

Inspection Date: 07/16/2019

Inspection Number: 1204560

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: YOUNG, JENNIFER

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  
Use table top fryer to cook funnel cake - From follow-up inspection 2019-04-30: No change \*\*Time Extended\*\* - From follow-up inspection 2019-07-16: No change \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Hernando County**

License Number: 3750305

TAQUERIA EL GUACHE #2

License Type: Mobile Food Dispensing Vehicle

1555 E JEFFERSON ST, BROOKSVILLE 34601

Inspection Date: 07/17/2019

Inspection Number: 1209130

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: MEAKINS, ALLISON

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2019-06-05: \*\*Time Extended\*\* - From follow-up inspection 2019-07-17: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3900108	FUSION BOWL CAPHE, LLC	
License Type: Permanent Food Service	504 E KENNEDY BLVD, TAMPA 33602	
Inspection Date: 07/15/2019	Inspection Number: 2910499	
Inspector Name: COLEMAN, TONYA	Inspection Type: Routine - Food	
	Inspection Disposition: Warning Issued	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Inspector Notified Fire AHJ. For reporting purposes only. Hood system broken.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3917506	DAILY DOSE COFFEE HOUSE AND EATERY	
License Type: Permanent Food Service	302 KNIGHTS RUN # 130, TAMPA 33602	
Inspection Date: 07/17/2019	Inspection Number: 2926156	
Inspector Name: COLEMAN, TONYA	Inspection Type: Routine - Food	
	Inspection Disposition: Warning Issued	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. 3 propane gas burners	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3910109	PULGARCITO 503	
License Type: Permanent Food Service	8614 N SUWANEE AVE, TAMPA 33604	
Inspection Date: 07/18/2019	Inspection Number: 2873506	
Inspector Name: DAVIS, CAROL S	Inspection Type: Food-Licensing Inspection	
	Inspection Disposition: Call Back - Extension given, pending	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-01-4	- From initial inspection : Licensed for 10 seats, increased to 20. For reporting purposes only. **Repeat Violation** - From follow-up inspection 2019-07-09: **Time Extended** - From follow-up inspection 2019-07-18: **Time Extended**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 3916067	CHIPOTLE MEXICAN GRILL #813	
License Type: Permanent Food Service	12827 N DALE MABRY HWY, CARROLLWOOD 33618	
Inspection Date: 07/17/2019	Inspection Number: 2933919	
Inspector Name: AIELLO, ROCCI	Inspection Type: Complaint Full	
	Inspection Disposition: Warning Issued	
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Operator moved the 2 full trash cans, that where blocking the rear exit.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Lee County**

License Number: 4605126

MOJOE'S COFFEE BAR

License Type: Permanent Food Service

1740 ESTERO BLVD, FORT MYERS BEACH 33931

Inspection Date: 07/15/2019

Inspection Number: 2871169

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2019-05-15: - From follow-up inspection 2019-07-15: Items marked 'other' are fore reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Martin County**

License Number: 5301685

THE ORIGINAL PANCAKE HOUSE

License Type: Permanent Food Service

4110 NW FEDERAL HWY, JENSEN BEACH 34957

Inspection Date: 07/18/2019

Inspection Number: 2923406

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only. By front door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5401465

HUNGRY TARPON

License Type: Permanent Food Service

77522 OVERSEAS HWY, ISLAMORADA 330363813

Inspection Date: 07/18/2019

Inspection Number: 2884358

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. In the Salad desert area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5602995

THAI PEPPER RESTAURANT & LOUNGE OF FORT WALTON

License Type: Permanent Food Service

301 RACETRACK ROAD NW, FORT WALTON BEACH 32547

Inspection Date: 07/17/2019

Inspection Number: 2906097

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: STEINMAN, MARC

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Kitchen \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5807175

THE MEDITERRANEAN SPOT

License Type: Permanent Food Service

9430 E COLONIAL DR, ORLANDO 32817

Inspection Date: 07/16/2019

Inspection Number: 2914590

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Back door area

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

47-03-4 Observed electrical wiring in disrepair. For reporting purposes only. Breaker panel is open with exposed contacts at the back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5812522

DEL TACO

License Type: Permanent Food Service

12025 COLLEGIATE WAY, ORLANDO 32817

Inspection Date: 07/15/2019

Inspection Number: 2933316

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

47-01-4 Observed frayed/spliced electrical wires. For reporting purposes only. . Fry heater has a damaged cord

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814549

AVENTURA HOTEL, LOBBY BAR + NOODLE RESTAURANT

License Type: Permanent Food Service

6725 ADVENTURE WAY, ORLANDO 32819

Inspection Date: 07/15/2019

Inspection Number: 2930668

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: NIEVES, RAFAEL

Violation CodeObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

No boiler certificates available for 4 boilers with 1,060,000 BTU located on roof top over parking garage and for 2 boilers with 825,000 located in pool room.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Orange County**

License Number: 5814551		AVENTURA HOTEL, BURGER VENUE	
License Type: Permanent Food Service		6725 ADVENTURE WAY, ORLANDO 32819	
Inspection Date: 07/15/2019	Inspection Number: 2922707	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: NIEVES, RAFAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  No boiler certificates available for 4 boilers with 1,060,000 BTU located on roof top over parking garage and for 2 boilers with 825,000 located in pool room.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 5814554		AVENTURA HOTEL, MAIN KITCHEN	
License Type: Permanent Food Service		6725 ADVENTURE WAY, ORLANDO 32819	
Inspection Date: 07/15/2019	Inspection Number: 2930227	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: NIEVES, RAFAEL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  No boiler certificates available for 4 boilers with 1,060,000 BTU located on roof top over parking garage and for 2 boilers with 825,000 located in pool room.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 5814649		SIMPLY GYROS	
License Type: Permanent Food Service		7728 WEST SANDLAKE RD, ORLANDO 32819	
Inspection Date: 07/15/2019	Inspection Number: 2926058	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BACHOO, SAVITRI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2019-07-18: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	



**Orange County**

License Number: 5812065

COFFEE FACTORY & CAFE

License Type: Permanent Food Service

12789 WATERFORD LAKES PKWY #1, ORLANDO 32828-7103

Inspection Date: 07/15/2019

Inspection Number: 2933021

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: WILSON, LANETTE

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door - From follow-up inspection 2019-07-15:  
\*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6003976		DENNY'S #7636	
License Type: Permanent Food Service		2705 OKEECHOBEE BLVD, WEST PALM BEACH 33409	
Inspection Date: 07/18/2019	Inspection Number: 2926535	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MATTIELLO-ATASSI, MARIA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only at dry storage.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6019691		BOMBAY CAFÉ	
License Type: Permanent Food Service		1200 YAMATO ROAD STE A-5, BOCA RATON 33431	
Inspection Date: 07/10/2019	Inspection Number: 2912936	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.  - rear egress path partially blocked with storage and storage shelves.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 6019714		EINSTEIN BROS BAGELS STORE 3347	
License Type: Permanent Food Service		690 YAMATO RD BAY 1, BOCA RATON 33431	
Inspection Date: 07/17/2019	Inspection Number: 2892414	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.  - blocked with empty boxes and full garbage can.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 6020310		PUCCINI'S PIZZERIA	
License Type: Permanent Food Service		9874 YAMATO RD, BOCA RATON 33434	
Inspection Date: 07/10/2019	Inspection Number: 2915693	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Palm Beach County**

License Number: 6021853

BASILIC VIETNAMESE GRILL

License Type: Permanent Food Service

6592 W ATLANTIC AVE, DELRAY BEACH 33446

Inspection Date: 07/11/2019

Inspection Number: 2925084

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: BANNIGAN, TIM

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.

- "Class K" portable extinguisher not mounted beneath "Class K" placard.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6012378

PALM BEACH DINER

License Type: Permanent Food Service

610 S DIXIE HWY, LANTANA 33462

Inspection Date: 07/17/2019

Inspection Number: 2934153

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Manager moved outside \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6217204	FARMTABLE KITCHEN		
License Type: Permanent Food Service	179 2ND AVE N., ST. PETERSBURG 33701		
Inspection Date: 07/17/2019	Inspection Number: 2914399	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: VALENCIA, ASHLEY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Cooking mushrooms with butter	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6214761	THE LITTLE LAMB GASTROPUB		
License Type: Permanent Food Service	2475 MCMULLEN BOOTH ROAD SUITE J, CLEARWATER 33759		
Inspection Date: 07/15/2019	Inspection Number: 2914577	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PEARCE, LAURA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Red extinguisher by back door **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Red extinguisher by back door **Repeat Violation** - From follow-up inspection 2019-07-18: Fire safety to deliver replacement this day per operator **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6210166	COUNTRYSIDE CAFE		
License Type: Permanent Food Service	28050 US 19 N STE 104, CLEARWATER 33761		
Inspection Date: 07/16/2019	Inspection Number: 2905153	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: PEARCE, LAURA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with hood suppression system with warning alarm in constant sound . Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2019-07-16: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Pinellas County**

License Number: 6216901

DECCAN SPICE TAMPA BAY

License Type: Permanent Food Service

2325 ULMERTON RD STE 28, CLEARWATER 33762

Inspection Date: 07/16/2019

Inspection Number: 2933894

Inspection Type: Complaint Full

Inspection Disposition: Emergency order recommended

Inspector Name: VALENCIA, ASHLEY

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Removed from building \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6805733

ART OVATION HOTEL

License Type: Permanent Food Service

1255 N PALM AVE, SARASOTA 34236

Inspection Date: 07/15/2019

Inspection Number: 2931313

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: MCKEON, MICHAEL

Violation Code

Observation

Violation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Multiple tanks located by back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6903683

PANERA BREAD #3310

License Type: Permanent Food Service

696 E ALTAMONTE DR, ALTAMONTE SPGS 32701

Inspection Date: 07/15/2019

Inspection Number: 2890032

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By the bread ovens

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6904868

COFFEE FACTORY &amp; CAFÉ

License Type: Permanent Food Service

5256 RED BUG LAKE RD, WINTER SPRINGS 32708

Inspection Date: 07/19/2019

Inspection Number: 2930876

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. At the back door area next to the cooler extinguisher missing from hook unable to locate

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Johns County**

License Number: 6501275

MCDONALDS #12869

License Type: Permanent Food Service

100 PONTE VEDRA POINTE BLVD, PONTE VEDRA BEACH 32082

Inspection Date: 07/19/2019

Inspection Number: 2919100

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
Rear exit blocked by equipment / garbage. Moved by manager. \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.



**St. Lucie County**

License Number: 6603035

SWEETIES DINER

License Type: Permanent Food Service

2625 S US 1, FORT PIERCE 34982

Inspection Date: 07/19/2019

Inspection Number: 2915455

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: MERCIER, WILLIAM

Violation Code

Observation

Violation Citation

48-04-4

More than 2 gallons of liquid gas on chemical shelflocated inside of the building.  
For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7403174

DOMINO'S PIZZA

License Type: Permanent Food Service

343 W GRANADA BLVD, ORMOND BCH 321746275

Inspection Date: 07/15/2019

Inspection Number: 2889690

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

49-01-4

Gas can stored by back door. For reporting purposes only.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

**Walton County**

License Number: 7650093

CRAB ISLAND SPORTS GRILL

License Type: Mobile Food Dispensing Vehicle

40 HIDDEN HARBOR LN, MIRAMAR BEACH 32550

Inspection Date: 07/16/2019

Inspection Number: 1219273

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STEINMAN, MARC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Wall mounted	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.