

**Alachua County**

License Number: 1102945

BIG LOU'S NY STYLE PIZZERIA

License Type: Permanent Food Service

5 SE 2 AVE, GAINESVILLE 32601

Inspection Date: 07/22/2019

Inspection Number: 2892827

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: WEATHERS, TIM

Violation Code

Observation

Violation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only.  
Connection, junction box to right of outside ice machine opened with no cover. Capped wires visible. - From follow-up inspection 2019-07-15: Wiring covered with black tape. Wires not exposed, but not a traditional repair. Per Manager new cover plate has been ordered. **\*\*Time Extended\*\*** **\*\*Corrective Action Taken\*\*** -  
From follow-up inspection 2019-07-22: No change to electrical box covered with tape. **\*\*Time Extended\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1506386 POLLO TROPICAL  
 License Type: Permanent Food Service 4335 W NORFOLK PKWY, WEST MELBOURNE 32904

Inspection Date: 07/23/2019 Inspection Number: 2934918 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: MAYNARD, DIANE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1502781 NORTHSIDE SPORTS GRILL  
 License Type: Permanent Food Service 4835 W EAU GALLIE BLVD, MELBOURNE 32935

Inspection Date: 07/26/2019 Inspection Number: 2919941 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended  
 Inspector Name: MAYNARD, DIANE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Broward County**

License Number: 1615158 AND FISH KITCHEN AND BAR  
 License Type: Permanent Food Service 1200-1208 N OCEAN BLVD, POMPAN0 BEACH 33062

Inspection Date: 07/23/2019 Inspection Number: 2928038 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BURGGRABE, BROCK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Both certificates expired.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1623643 BLAZE PIZZA  
 License Type: Permanent Food Service 6334 N ANDREWS AVE, FORT LAUDERDALE 33309

Inspection Date: 07/25/2019 Inspection Number: 2912321 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked by garbage container . For reporting purposes only. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 1614974 A THAI  
 License Type: Permanent Food Service 6419 STIRLING RD, DAVIE 33314-7126

Inspection Date: 07/25/2019 Inspection Number: 2883372 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LEWIS, LYNDEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1623711 POPEYES LOUISIANA KITCHEN  
 License Type: Permanent Food Service 1300 E COMMERCIAL BLVD, OAKLAND PARK 33334

Inspection Date: 07/26/2019 Inspection Number: 2906294 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Columbia County**

License Number: 2200678

SUBWAY 52619

License Type: Permanent Food Service

3586 W US HWY 90, LAKE CITY 32055

Inspection Date: 07/23/2019

Inspection Number: 2933044

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Fire extinguisher near back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2314060		PIZZA HUT #780097	
License Type: Permanent Food Service		4837 NW 183 ST, OPA LOCKA 330552955	
Inspection Date: 07/23/2019	Inspection Number: 2888642	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed cardboard boxes on cart blocking back door. Manager moved boxes to dumpster. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2328777		PANORAMA RESTAURANT AND SKY LOUNGE	
License Type: Permanent Food Service		2889 MCFARLANE RD, COCONUT GROVE 33133	
Inspection Date: 07/26/2019	Inspection Number: 2930575	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MASKASEM, SUPPACHAI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed one boiler certificate expired. 096415 exp 07/05/18	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2331718		HAMPTON INN COCONUT GROVE	
License Type: Permanent Food Service		2800 SW 28 TERR, MIAMI 33133	
Inspection Date: 07/25/2019	Inspection Number: 2894356	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MASKASEM, SUPPACHAI			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2333969		SUBWAY #52931	
License Type: Permanent Food Service		2962 SW 8 ST, MIAMI 33135	
Inspection Date: 07/24/2019	Inspection Number: 2904892	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ALEJANDRO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. By delivery boxes.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

**Dade County**

License Number: 2334969 THE BEST WINE SHOP LLC  
 License Type: Permanent Food Service 6421 SW 8 ST, MIAMI 33144

Inspection Date: 07/26/2019 Inspection Number: 2935876 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Located in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Stored on floor underneath prep table in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2313817 COSME CAFE  
 License Type: Permanent Food Service 8390 BIRD RD, MIAMI 33155

Inspection Date: 07/23/2019 Inspection Number: 2917110 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: ALVAREZ, MARGARET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Observed exposed wiring in bathroom	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330738 MAO COLOMBIAN FAST FOOD  
 License Type: Permanent Food Service 8438 SW 40TH ST, MIAMI 33155

Inspection Date: 07/24/2019 Inspection Number: 2929087 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed empty boxes blocking the way in front of back door emergency exit.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Dade County**

License Number: 2319438 AMNZ SUBWAY 1577 INC  
 License Type: Permanent Food Service 7 NW 183 ST, MIAMI 33169  
 Inspection Date: 07/23/2019 Inspection Number: 2932622 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: HENLEY, LATONYA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed 2 cases of spinach on floor blocking back door.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2324810 LOS VERDES  
 License Type: Permanent Food Service 2426 SW 137 AVE, MIAMI 33175  
 Inspection Date: 07/24/2019 Inspection Number: 2899902 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GONZALEZ, RICARDO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. By kitchen front door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2333492 BJ'S RESTAURANT AND BREWHOUSE #530  
 License Type: Permanent Food Service 8888 SW 136 ST STE 350, MIAMI 33176  
 Inspection Date: 07/22/2019 Inspection Number: 2934194 Inspection Type: Complaint Full Inspection Disposition: Warning Issued  
 Inspector Name: ALVAREZ, MARGARET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed blocked by trash bins. Manager had employee remove **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2332545 100 MONTADITOS  
 License Type: Permanent Food Service 13440 SW 120 ST #608, MIAMI 33186  
 Inspection Date: 07/24/2019 Inspection Number: 2916575 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LODENQUAI, BARRINGTON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2612182		GOLDEN CORRAL # 631	
License Type: Permanent Food Service		4250 SOUTHSIDE BLVD, JACKSONVILLE 32216	
Inspection Date: 07/24/2019	Inspection Number: 2935288	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: ARMSTRONG, RICO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 097645 6/21/19 expired	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2609086		JAX MARKET PLACE TAKE-OUT #1	
License Type: Permanent Food Service		614 PECAN PARK RD, JACKSONVILLE 32218	
Inspection Date: 07/25/2019	Inspection Number: 2877243	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: YOUNG, JENNIFER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 5 gallon propane tanks in kitchen near drink machine	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2614420		TROPICAL SMOOTHIE CAFE	
License Type: Permanent Food Service		5895 ROOSEVELT BOULEVARD, JACKSONVILLE 32244	
Inspection Date: 07/22/2019	Inspection Number: 2919424	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: PERRY, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door in mop sink area.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2615304		CHICKEN SALAD CHICK	
License Type: Permanent Food Service		4624 TOWN CROSSING DR, JACKSONVILLE 32246	
Inspection Date: 07/25/2019	Inspection Number: 2909551	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: GONZALEZ, MAYRA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Kitchen exit door block by empty cardboard boxes.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	



**Duval County**

License Number: 2614965

JVILLE CRAB SHACK NUMBER 3

License Type: Permanent Food Service

700 N EDGEWOOD AVE, JACKSONVILLE 32254

Inspection Date: 07/26/2019

Inspection Number: 2905770

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
 No access to emergency exit due to it being blocked by large aquarium display.  
 \*\*Repeat Violation\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Escambia County**

License Number: 2703054

PIZZA HUT #2068

License Type: Permanent Food Service

4522 SAUFLEY FIELD RD, PENSACOLA 325261718

Inspection Date: 07/22/2019

Inspection Number: 2934901

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: RUSSELL, SARAH

Violation CodeObservationViolation Citation

45-06-4

Portable fire extinguisher is inaccessible. For reporting purposes only. At back door. Trash bins blocking clear walkway to extinguisher. Fire Inspector contacted.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Fire Inspector contacted.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Flagler County**

License Number: 2800507

TACO BELL 26462

License Type: Permanent Food Service

1020 PALM COAST PKWY, PALM COAST 32137

Inspection Date: 07/24/2019

Inspection Number: 2935282

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: HARTMANN, MICHELLE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
Blocked by trash and boxes.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Hillsborough County**

License Number: 3918284

EL RICO FRAPPE LATINO

License Type: Permanent Food Service

122 PIERCE CHRISTIE DR, VALRICO 33594

Inspection Date: 07/22/2019

Inspection Number: 2875019

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: CANNELLA, MARK

Violation Code

Observation

Violation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. 3 Switch plates missing at front counter area from outlets .  
\*\*Repeat Violation\*\* - From follow-up inspection 2019-07-22: \*\*Admin Complaint\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3917682 BIG EASY BAR  
 License Type: Permanent Food Service 1704 E 7TH AVE, TAMPA 33605

Inspection Date: 07/23/2019 Inspection Number: 2712281 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending  
 Inspector Name: BOOKAL, SHANNA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-02-4	- From initial inspection : Increased seating to over 90 + seats without approval. For reporting purposes only - From follow-up inspection 2018-06-19: ****this violation is due by August 18**** **Time Extended** - From follow-up inspection 2018-06-20: **Time Extended** - From follow-up inspection 2018-08-20: Per Carol time extend 60days in light of new management. Inspector reiterated that even though Fire dept. is in the process of permitting for the remodel that is ongoing, plans and seating evaluation still need to be submitted to Tallahassee **Time Extended** - From follow-up inspection 2018-10-19: Per Carol time extend 30 days to give remodel time (e.g walk in cooler installation, flooring, etc.) and fire department to sign off on seating evaluation. Inspector was emailed current seating evaluation with waste management sign off updated. **Time Extended** - From follow-up inspection 2018-11-19: Per Carol time extend 60 days to give remodel time (e.g walk in cooler installation, flooring, etc.) and fire department to sign off on seating evaluation. Inspector was shown updated paperwork and informed of ongoing Walk in cooler construction **Time Extended** - From follow-up inspection 2019-01-24: Per Carol time extend 60 days to give remodel time (e.g walk in cooler installation, flooring, etc.) and fire department to sign off on seating evaluation. Inspector was shown updated paperwork and informed of ongoing Walk in cooler construction **Time Extended** - From follow-up inspection 2019-03-25: Per Jessica time extend 60 days to give remodel time/ fire department to sign off on seating evaluation. **Time Extended** - From follow-up inspection 2019-05-24: Per Lindsay time extend since fire department's recent visit earlier this week and they did not sign off on the paperwork **Time Extended** - From follow-up inspection 2019-07-23: **Time Extended**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
49-02-4	- From initial inspection : From prior inspection/callback :::Increased seats 90+ without approval. For reporting purposes only.  Per Carol time extend 60days in light of new management. Inspector reiterated that even though Fire dept. is in the process of permitting for the remodel that is ongoing, plans and seating evaluation still need to be submitted to Tallahassee - From follow-up inspection 2018-08-22: **Time Extended** - From follow-up inspection 2018-10-22: Per Carol time extend 30 days to give remodel time (e.g walk in cooler installation, flooring, etc.) and fire department to sign off on seating evaluation. Inspector was emailed current seating evaluation with waste management sign off updated. **Time Extended** - From follow-up inspection 2018-11-19: Per Carol time extend 60 days to give remodel time (e.g walk in cooler installation, flooring, etc.) and fire department to sign off on seating evaluation. Inspector was shown updated paperwork and informed of ongoing Walk in cooler construction **Time Extended** - From follow-up inspection 2019-01-24: Per Carol time extend 60 days to give remodel time (e.g walk in cooler installation, flooring, etc.) and fire department to sign off on seating evaluation. Inspector was shown updated paperwork and informed of ongoing Walk in cooler construction **Time Extended** - From follow-up inspection 2019-03-25: Per Jessica time extend 60 days to give remodel time/ fire department to sign off on seating evaluation. **Time Extended** - From follow-up inspection 2019-05-24: Per Lindsay time extend since fire department's recent visit earlier this week and they did not sign off on the paperwork **Time Extended** - From follow-up inspection 2019-07-23: **Time Extended**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
49-02-4	- From initial inspection : Increased seating over 90+ seats without approval - already on existing callback - From follow-up inspection 2019-07-24: **Time Extended**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
49-02-4	Increased seating over 90+ seats without approval - already on existing callback	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

**Manatee County**

License Number: 5105409

SUNSHINE CARIBBEAN RESTAURANT

License Type: Permanent Food Service

6320 15 ST E 2, SARASOTA 34243

Inspection Date: 07/25/2019

Inspection Number: 2907024

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: KNOX, KHALENA

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2019-07-12: **\*\*Time Extended\*\*** -  
From follow-up inspection 2019-07-25: **\*\*Time Extended\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Marion County**

License Number: 5203009

DUNKIN DONUTS

License Type: Permanent Food Service

5457 SE MARICAMP RD, OCALA 34480

Inspection Date: 07/26/2019

Inspection Number: 2918284

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. With two trash cans and cardboards, Manager moved all items. \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Martin County**

License Number: 5301854

METRO DINER #1405

License Type: Permanent Food Service

2660 SE FEDERAL HWY 1, STUART 34994

Inspection Date: 07/26/2019

Inspection Number: 2925791

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By office.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301598

CHILIS GRILL AND BAR

License Type: Permanent Food Service

4205 SE FEDERAL HWY, STUART 34997

Inspection Date: 07/25/2019

Inspection Number: 2893850

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.by back door/extinguisher stored on floor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301819

FAT BOYZ SUBS

License Type: Permanent Food Service

5062 SE FEDERAL HWY, STUART 34997

Inspection Date: 07/23/2019

Inspection Number: 2911949

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.backroom/by 3 compartment sink/2 small flattops.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Nassau County**

License Number: 5500810

BURGER KING

License Type: Permanent Food Service

542370 US HIGHWAY 1, CALLAHAN 32011

Inspection Date: 07/24/2019

Inspection Number: 2933890

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. In break room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5501146

CANTINA LOUIE

License Type: Permanent Food Service

960062 GATEWAY BLVD, FERNANDINA BEACH 32034

Inspection Date: 07/26/2019

Inspection Number: 2916259

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In storage room, employee removed it  
\*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5604035

AMERICAN HOUSE BLUEWATER BAY

License Type: Permanent Food Service

4595 HWY 20 E, NICEVILLE 32578

Inspection Date: 07/22/2019

Inspection Number: 2923438

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURROUGHS, RICHARD

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  
 - boilers have a sticker on each of them for when they were inspected but the establishment has not received their certificates.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation  
 - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Orange County**

License Number: 5807262	CHECKERS #6326		
License Type: Permanent Food Service	2750 W COLONIAL DR, ORLANDO	32804	
Inspection Date: 07/26/2019	Inspection Number: 2893442	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: QUINONES, ANTONIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed missing electrical cover. For reporting purposes only. Front of ice machine side wall.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5809292	FRATELLOS PIZZA		
License Type: Permanent Food Service	11660 E COLONIAL DR, ORLANDO	32817	
Inspection Date: 07/22/2019	Inspection Number: 2893122	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At the back door close to the office extinguisher is in the red	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5814025	MOE'S SOUTHWEST GRILL		
License Type: Permanent Food Service	6817 EAGLE WATCH DRIVE, ORLANDO	32822	
Inspection Date: 07/22/2019	Inspection Number: 2912104	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked, empty box by back door.. For reporting purposes only.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5804724	CHILI'S II		
License Type: Permanent Food Service	9333 JEFF FUQUA BLVD STE 5199, ORLANDO	32827	
Inspection Date: 07/26/2019	Inspection Number: 2887442	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

**Orange County**

License Number: 5811031 CHICK-FIL-A - TERMINAL FOOD COURT  
 License Type: Permanent Food Service 9333 AIRPORT BLVD, ORLANDO 32827

Inspection Date: 07/26/2019 Inspection Number: 2892673 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. inspected 4-23-19, they had an inspection, but no certificate. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5811050 SBARRO - CENTRAL FOOD COURT  
 License Type: Permanent Food Service 9333 AIRPORT BLVD, ORLANDO 32827

Inspection Date: 07/26/2019 Inspection Number: 2892698 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler, they only have the inspection report.. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5811285 MACARONI GRILL  
 License Type: Permanent Food Service 9333 AIRPORT BLVD., ORLANDO 32827

Inspection Date: 07/26/2019 Inspection Number: 2892846 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5803254 ROSE & CROWN PUB  
 License Type: Permanent Food Service 1510 N AVE OF THE STARS, LAKE BUENA VISTA 32830

Inspection Date: 07/25/2019 Inspection Number: 2887396 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: NIEVES, RAFAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.  For boiler ID FL057438, expired on 04/29/19 and for Boiler ID FL057439, expired on 04/29/19.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Orange County**

License Number: 5814308

WENDY'S #11721

License Type: Permanent Food Service

13549 W COLONIAL DR, WINTER GARDEN 34787

Inspection Date: 07/22/2019

Inspection Number: 2921492

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FREY, RANDY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Fire extinguisher next to ice machine.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6020820 TOSSED  
 License Type: Permanent Food Service 6000 GLADES RD STE 1177A, BOCA RATON 33431

Inspection Date: 07/26/2019 Inspection Number: 2925627 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BANNIGAN, TIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.  - "Class ABC" portable fire extinguisher on floor beneath convection oven	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6012447 STEVE'S WOOD FIRED PIZZA  
 License Type: Permanent Food Service 9180 GLADES RD, BOCA RATON 33434

Inspection Date: 07/24/2019 Inspection Number: 2889668 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BANNIGAN, TIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.  "CLASSK" portable extinguisher on floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pasco County**

License Number: 6100942

BOULEVARD FAMILY RESTAURANT

License Type: Permanent Food Service

7507 LITTLE RD, NEW PORT RICHEY 34654

Inspection Date: 07/26/2019

Inspection Number: 2905633

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HIRST, DAN

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Two small table top fryers on table in center of kitchen not under hood system. One fryer was off, one fryer was on and hot.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6113520

WAFFLE HOUSE #2294

License Type: Permanent Food Service

12201 US 19, HUDSON 34667

Inspection Date: 07/23/2019

Inspection Number: 2926860

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAHL, MICHELE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Blocked by bread rack \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6113435

TASTE OF CURRY

License Type: Permanent Food Service

10136 US HWY 19, PORT RICHEY 34668

Inspection Date: 07/26/2019

Inspection Number: 2910177

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: TORRACO, MARIANNE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Filters, rack, box, bus tubs

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.





**Pinellas County**

License Number: 6211703

GINO'S NEW YORK PIZZERIA

License Type: Permanent Food Service

3394 TAMPA RD, PALM HARBOR 34684

Inspection Date: 07/22/2019

Inspection Number: 2892387

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PIATT, PAUL

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to ladies restroom

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6308047

PIZZANOS PIZZA & GRINDERZ

License Type: Permanent Food Service

126 CALIFORNIA BLVD, DAVENPORT 33897

Inspection Date: 07/23/2019

Inspection Number: 2908839

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: JACKSON, SHARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a farberware single basket fryer being used to fry chicken tenders. - From follow-up inspection 2019-07-23: In use. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a farberware single basket fryer being used to fry chicken tenders.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

---

**Santa Rosa County**

---

License Number: 6700139

BURGER KING # 1618

License Type: Permanent Food Service

6682 CAROLINE ST HWY 90, MILTON 32570

Inspection Date: 07/23/2019

Inspection Number: 2935268

Inspection Type: Complaint Full

Inspection Disposition: Emergency  
order recommended

Inspector Name: HALL, DAVID

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.  
Plate cover pushed to side exposing wiring and caps in drive thru.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6805370

PANERA BREAD

License Type: Permanent Food Service

215 N CATTLEMEN RD UNIT 51, SARASOTA 34243

Inspection Date: 07/26/2019

Inspection Number: 2902608

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KNOX, KHALENA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6902915

DOMINO'S #3163

License Type: Permanent Food Service

5285 RED BUG LAKE RD #117, WINTER SPRINGS 32708

Inspection Date: 07/26/2019

Inspection Number: 2903589

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. At the stainless steel table at the order monitor. The table appears to be repurposed and while the cord is not plugged in it is still connected to a switch and bare wires. Operator is unsure if the box is disconnected

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6904586

PIZZA HUT

License Type: Permanent Food Service

1875 W CR 419, OVIEDO 32765

Inspection Date: 07/24/2019

Inspection Number: 2898341

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. At the freezer door the bracket is present without the fire extinguisher. Extinguisher found in another location and relocated \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7401998

PANTHEON PIZZA

License Type: Permanent Food Service

505 WHITE ST, DAYTONA BEACH 32114

Inspection Date: 07/22/2019

Inspection Number: 2893607

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

46-04-4

Exit door locked. For reporting purposes only.  
Rear exit in dining room has bar across door and height chairs partially blocking  
path \*\*Corrected On-Site\*\*61C-1.004(9) FAC: (9) Reporting: Means of access,  
including entrances, halls, and stairways, must permit  
unobstructed travel at all times and shall be clean,  
ventilated and well-lighted day and night. Hall and stair  
runners shall be kept in good condition. Railways, as  
defined in 61C-1.001(23), F.A.C., shall be installed on all  
stairways and around all porches and steps. For  
reporting purposes only.

License Number: 7406138

NEW YORK PIZZA &amp; SUB

License Type: Permanent Food Service

637 N GRANDVIEW AVE, DAYTONA BEACH 32118

Inspection Date: 07/25/2019

Inspection Number: 2877874

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to  
back door509.032(2)(d) FS Reporting: (d) The division, or its  
agent, shall notify the local firesafety authority or the  
State Fire Marshal of any readily observable violation of  
a rule adopted under chapter 633 which relates to public  
lodging establishments or public food establishments,  
and the identification of such violation does not require  
any firesafety inspection certification. For reporting  
purposes only.

License Number: 7407046

BRUNO'S PIZZA

License Type: Permanent Food Service

1254 OCEANSHORE BLVD, ORMOND BEACH 32176

Inspection Date: 07/24/2019

Inspection Number: 2917508

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood  
suppression system installed. Notified Fire AHJ. For reporting purposes only. Table  
top fryers in use. \*\*Repeat Violation\*\*509.032(2)(d) FS Reporting: (d) The division, or its  
agent, shall notify the local firesafety authority or the  
State Fire Marshal of any readily observable violation of  
a rule adopted under chapter 633 which relates to public  
lodging establishments or public food establishments,  
and the identification of such violation does not require  
any firesafety inspection certification. For reporting  
purposes only.