

**Alachua County**

License Number: 1103392

MOJO HOGTOWN BBQ

License Type: Permanent Food Service

12 SE 2 AVE, GAINESVILLE 32601

Inspection Date: 08/22/2019

Inspection Number: 2909188

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: WEATHERS, TIM

Violation CodeObservationViolation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two large LP tanks by restrooms in area by two doors labeled not a exit. - From follow-up inspection 2019-08-20: Tanks not moved. Moved outside during inspection. **\*\*Corrective Action Taken\*\*** - From follow-up inspection 2019-08-22: Tanks in heaters still inside, but others that were not in heaters moved outside. **\*\*Corrective Action Taken\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two large LP tanks by restrooms in area by two doors labeled not a exit. - From follow-up inspection 2019-08-20: Tanks not moved. Moved outside during inspection. **\*\*Corrective Action Taken\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103352

HARVEST THYME CAFE 2

License Type: Permanent Food Service

4780 NW 39 AVE STE 1, GAINESVILLE 32606

Inspection Date: 08/22/2019

Inspection Number: 2905164

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: WEATHERS, TIM

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Above entrance to dish room, outlet with open, but capped wiring.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1506870	DUNKIN DONUTS		
License Type: Permanent Food Service	3267 S BABCOCK ST, MELBOURNE 32901		
Inspection Date: 08/19/2019	Inspection Number: 2927046	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MAYNARD, DIANE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1500288	THE BREAKFAST SPOT		
License Type: Permanent Food Service	1300 N ATLANTIC AVE, COCOA BEACH 32931		
Inspection Date: 08/22/2019	Inspection Number: 2917171	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: HICKS, GEORGE RANDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Inside kitchen by swinging doors dish area side.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1505995	THE FREEDOM CAFE		
License Type: Permanent Food Service	1270 N WICKHAM RD STE 25, MELBOURNE 32935		
Inspection Date: 08/23/2019	Inspection Number: 2928427	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: WALCOTT, AMY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only by backroom kitchen exit blocked by baking rack	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

License Number: 1506150	SQUID LIPS WATERFRONT		
License Type: Permanent Food Service	1477 PINEAPPLE AVE, MELBOURNE 32935		
Inspection Date: 08/16/2019	Inspection Number: 2896824	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: WALCOTT, AMY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Bar patio attached to the building - From follow-up inspection 2019-07-08: - From follow-up inspection 2019-07-09: - From follow-up inspection 2019-08-16: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Brevard County**

License Number: 1505868

MOE'S SOUTHWEST GRILL #35

License Type: Permanent Food Service

2230 TOWN CENTER AVE SUITE 111, VIERA 32940

Inspection Date: 08/19/2019

Inspection Number: 2919332

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WALCOTT, AMY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only at front counter

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1621046 GREAT AMERICAN GRILL  
 License Type: Permanent Food Service 180 SW 18 AVE, DANIA 33004

Inspection Date: 08/19/2019 Inspection Number: 2890997 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1622427 CAMBRIA SUITES FORT LAUDERDALE AIRPORT  
 License Type: Permanent Food Service 141 NW 19 CT, DANIA 33004

Inspection Date: 08/21/2019 Inspection Number: 2897956 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. cooking outside of hood coverage with burners and oil in frying pan. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1623520 GO GAI  
 License Type: Permanent Food Service 2051A HOLLYWOOD BLVD, HOLLYWOOD 33020

Inspection Date: 07/25/2019 Inspection Number: 2926290 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: CHAPDELAINE, MARIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Pressure washer with gas stored inside storage room by back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1620490		CHEESECAKE FACTORY (THE)	
License Type: Permanent Food Service		600 E LAS OLAS BLVD, FORT LAUDERDALE 33301	
Inspection Date: 08/22/2019	Inspection Number: 2888282	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2019-08-22: No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Time Extended**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 1621169		THE ATLANTIC HOTEL & SPA	
License Type: Permanent Food Service		601 N FORT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304	
Inspection Date: 08/21/2019	Inspection Number: 2916982	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 133632, 133631, 058990 all expired 7-6-2019	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 1621170		THE ATLANTIC HOTEL & SPA	
License Type: Permanent Food Service		601 N FORT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304	
Inspection Date: 08/21/2019	Inspection Number: 2915301	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANN, JUSTIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 133632, 133631, 058990 all expired 7-6-2019	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 1616272		YUMMY BBQ INC	
License Type: Permanent Food Service		2350A N UNIVERSITY DR, SUNRISE 33322	
Inspection Date: 08/20/2019	Inspection Number: 2866251	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: GRAY, ANTHONY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	- From initial inspection : Portable fire extinguisher missing from its designated location. For reporting purposes only. - From follow-up inspection 2019-08-20: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Duval County**

License Number: 2612545

EL POTRO MEXICAN RESTAURANT # 28

License Type: Permanent Food Service

7200 NORMANDY BLVD, #12, JACKSONVILLE 32205

Inspection Date: 08/22/2019

Inspection Number: 2924994

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: ROZIER, TORRANCE

Violation Code

Observation

Violation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
Gas pressure cleaner with gas inside stored in employee restroom.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612337

WENDY'S #65

License Type: Permanent Food Service

4453 SOUTHSIDE BLVD, JACKSONVILLE 32216

Inspection Date: 08/22/2019

Inspection Number: 2940543

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, MAYRA

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.  
Kitchen exit door blocked with trash bags and empty boxes. Manager cleared area out. \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.



**Indian River County**

License Number: 4101144 SQUID LIPS  
 License Type: Permanent Food Service 1660 N. INDIAN RIVER DR., SEBASTIAN 32958

Inspection Date: 08/22/2019 Inspection Number: 2892835 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended  
 Inspector Name: MAYNARD, DIANE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Uncovered wired by ice bin	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-03-4	- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only. Uncovered wired by ice bin - From follow-up inspection 2019-08-23: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4101212 DOUGHBOYZ PIZZERIA  
 License Type: Permanent Food Service 920 US 1 STE C, SEBASTIAN 32958

Inspection Date: 08/20/2019 Inspection Number: 2918768 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: MAYNARD, DIANE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. 2 fryers **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Indian River County**

License Number: 4100626

CAPTAIN HIRAM'S

License Type: Permanent Food Service

1606 INDIAN RIVER DR, SEBASTIAN 329581610

Inspection Date: 08/22/2019

Inspection Number: 2886876

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: MAYNARD, DIANE

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-05-4

- From initial inspection : Portable fire extinguisher missing from its designated location. For reporting purposes only. - From follow-up inspection 2019-08-23:  
\*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4105301

CAFE 1901

License Type: Permanent Food Service

3400 43RD AVE STE 1 &amp; 2, VERO BEACH 32960

Inspection Date: 08/20/2019

Inspection Number: 2908009

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4604503

MCDONALDS

License Type: Permanent Food Service

18500 SUMMERLIN RD, FORT MYERS 33908

Inspection Date: 08/19/2019

Inspection Number: 2905690

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PAGAN, VIRMAR

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed the exit door with bread racks. **\*\*Corrected On-Site\*\***

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Leon County**

License Number: 4703304

GREAT PLATES

License Type: Permanent Food Service

1313 JACKSON BLUFF RD, TALLAHASSEE 32304

Inspection Date: 05/20/2019

Inspection Number: 2940577

Inspection Type: Routine - Food

Inspection Disposition: Allegation Not Observed

Inspector Name: CHARLES, BRENDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	OBSERVED USE OF COOKING EQUIPMENT PRODUCING GREASE LADEN VAPORS/SMOKE WITH NO HOOD SUPPRESSION SYSTEM INSTALLED. NOTIFIED FIRE AHJ. FOR REPORTING PURPOSES ONLY.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	OBSERVED PROPANE TANK (LARGER THAN 2.7 LB WATER CAPACITY/1 LB GAS CAPACITY) LOCATED INSIDE OF THE BUILDING. FOR REPORTING PURPOSES ONLY.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Martin County**

License Number: 5301823

CUBAN CAFE

License Type: Permanent Food Service

9407 SE FEDERAL HWY, HOBE SOUND 33455

Inspection Date: 08/20/2019

Inspection Number: 2915422

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.frontline/flat grill. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5428372

IL POSTINO RESTAURANT

License Type: Permanent Food Service

1 KNIGHTS KEY BLVD, MARATHON 33050

Inspection Date: 08/20/2019

Inspection Number: 2926572

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Near ice machine in kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5802822		PIZZA HUT	
License Type: Permanent Food Service		883 SEMORAN BLVD, APOPKA 32703	
Inspection Date: 08/19/2019	Inspection Number: 2939744	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MONTGOMERY, DOREEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked during hours of operation, side door in dining room on side of Sheeler Road. For reporting purposes only.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5811838		GRAFFITI JUNKTION 14	
License Type: Permanent Food Service		54 W CHURCH ST #141, ORLANDO 32801	
Inspection Date: 08/23/2019	Inspection Number: 2907414	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: QUINONES, ANTONIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Above 3 compartment sink	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5807815		JADE BISTRO	
License Type: Permanent Food Service		2425 EDGEWATER DR, ORLANDO 32804	
Inspection Date: 08/22/2019	Inspection Number: 2941536	Inspection Type: Complaint Partial	Inspection Disposition: Warning Issued
Inspector Name: PLEICONES, KIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Located in kitchen firing portable burner out from under hood system. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5803621		BRISTOL CAFE	
License Type: Permanent Food Service		5750 T G LEE BLVD, ORLANDO 32822	
Inspection Date: 08/22/2019	Inspection Number: 2916610	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. boiler certification expired 11-29-18. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

**Palm Beach County**

License Number: 6021864		WEST PALM BEACH BREWERY & WINE VAULT	
License Type: Permanent Food Service		332 EVERNIA ST, WEST PALM BEACH 33401	
Inspection Date: 08/22/2019	Inspection Number: 2928203	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ENDERS, PAMELA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

License Number: 6005759		BURGER KING #02993	
License Type: Permanent Food Service		9031 OLD DIXIE HWY, LAKE PARK 33403	
Inspection Date: 08/19/2019	Inspection Number: 2940032	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ROTONDI, VICTOR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only.electrical outlet/missing cover plate/by ice machine	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 6012406		DELI ON RYE	
License Type: Permanent Food Service		4311 N FEDERAL HWY, BOCA RATON 33431	
Inspection Date: 08/21/2019	Inspection Number: 2892697	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  - To the LEFT of the 6 Open Burner Gas Range, atop of a reach in cooler "outside of any exhaust hood or Fire Suppression System Protection" is a double deep fryer in-use.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Palm Beach County**

License Number: 6020489 BOCA BAGEL BAR  
 License Type: Permanent Food Service 4251 N FEDERAL HWY, BOCA RATON 33431

Inspection Date: 08/21/2019 Inspection Number: 2926389 Inspection Type: Routine - Food  
 Inspector Name: BANNIGAN, TIM

Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  - in kitchen to the left of the floor mixer in front of electrical panels are TWO in-use deep fryers with NO exhaust hood OR Fire Suppression System.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
46-04-4	Exit door locked. For reporting purposes only.  - rear exit door locked.  - rear exit door handle damaged and in disrepair.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6020611 SUSHI YAN  
 License Type: Permanent Food Service 1929 N FEDERAL HWY, BOCA RATON 33431

Inspection Date: 08/22/2019 Inspection Number: 2928201 Inspection Type: Routine - Food  
 Inspector Name: BANNIGAN, TIM

Inspection Disposition: Warning Issued

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  - using Deep Fryer without Exhaust Hood or Fire Suppression System.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6020799 PIEZANO'S PIZZA & PASTA  
 License Type: Permanent Food Service 4131 N FEDERAL HWY, BOCA RATON 33431

Inspection Date: 08/21/2019 Inspection Number: 2909203 Inspection Type: Routine - Food  
 Inspector Name: BANNIGAN, TIM

Inspection Disposition: Inspection Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only.  - rear exit door locked and door knob removed.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.



**Palm Beach County**

License Number: 6009899

OUTBACK STEAKHOUSE

License Type: Permanent Food Service

103A-1 S US HWY 1, JUPITER 33477

Inspection Date: 08/22/2019

Inspection Number: 2897537

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only.by  
mixer/prep area/kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6007073

STELLA'S PIZZERIA

License Type: Permanent Food Service

19585 SR 7 STE M, BOCA RATON 33498

Inspection Date: 08/22/2019

Inspection Number: 2896887

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BANNIGAN, TIM

Violation CodeObservationViolation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only.  
- deep fryer not separated from open flame gas burners by a 16" barrier

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pinellas County**

License Number: 6217798		GREEN LIGHT BAR	
License Type: Permanent Food Service		229 62 AVE N, ST. PETERSBURG 33702	
Inspection Date: 08/22/2019	Inspection Number: 2877112	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Admin. complaint recommended
Inspector Name: VALENCIA, ASHLEY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Table top fryer - From follow-up inspection 2019-06-28: Air fryer- unknown if UL listed ventless - From follow-up inspection 2019-08-22: Air fryer	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6212548		THE BROWN BOXER PUB & GRILLE	
License Type: Permanent Food Service		731 BAYWAY BLVD, CLEARWATER 33767	
Inspection Date: 08/20/2019	Inspection Number: 2907537	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-01-4	Flammables stored/debris present in Boxer side store room. 2 LP containers.For reporting purposes only.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.	
License Number: 6212910		GARDEN GRILLE CAFE	
License Type: Permanent Food Service		34018 -22 US HWY 19 N, PALM HARBOR 34684	
Inspection Date: 08/20/2019	Inspection Number: 2895488	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PIATT, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Two tables in front of the door. Moved the tables **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

**Seminole County**

License Number: 6904760 QDOBA MEXICAN GRILL  
 License Type: Permanent Food Service 380 S SR 434 SPACE A06, ALTAMONTE SPRINGS 32714

Inspection Date: 08/20/2019 Inspection Number: 2895854 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher by back exit door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6903674 PHO 4 U  
 License Type: Permanent Food Service 750 S HWY 17-92, LONGWOOD 32750

Inspection Date: 08/23/2019 Inspection Number: 2867452 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: MARTIN, LESLIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : ANSUL system gauge in red zone. For reporting purposes only. - From follow-up inspection 2019-08-23: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**St. Lucie County**

License Number: 6600733

COURTYARD BY MARRIOTT

License Type: Permanent Food Service

10978 S OCEAN DR, JENSEN BEACH 34957

Inspection Date: 08/19/2019

Inspection Number: 2919736

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.  
For reporting purposes only.61C-1.004(9) FAC Reporting: (9) Heating and ventilation  
- The heating and ventilation system shall be kept in  
good repair or be installed to maintain a minimum of 68  
degrees Fahrenheit throughout the building. The  
insurance inspector's boiler report is required annually  
for power boilers and high pressure/high temperature  
boilers and biannually for low pressure steam or vapor  
heating boilers and shall be posted in the boiler room.  
For reporting purposes only.

License Number: 6602296

COURTYARD BY MARRIOTT

License Type: Permanent Food Service

10978 S OCEAN DR, JENSEN BEACH 34957

Inspection Date: 08/19/2019

Inspection Number: 2923959

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.  
For reporting purposes only. Expired 2/19.61C-1.004(9) FAC Reporting: (9) Heating and ventilation  
- The heating and ventilation system shall be kept in  
good repair or be installed to maintain a minimum of 68  
degrees Fahrenheit throughout the building. The  
insurance inspector's boiler report is required annually  
for power boilers and high pressure/high temperature  
boilers and biannually for low pressure steam or vapor  
heating boilers and shall be posted in the boiler room.  
For reporting purposes only.

**Volusia County**

License Number: 7407263

BRUH BRUHS BARBECUE

License Type: Permanent Food Service

555 8 ST UNIT G &amp; H, HOLLY HILL 32117

Inspection Date: 08/19/2019

Inspection Number: 2929873

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7405220

HUNGRY HOWIE'S

License Type: Permanent Food Service

201 S RIDGEWOOD AVE #112, EDGEWATER 32132

Inspection Date: 08/22/2019

Inspection Number: 2940323

Inspection Type: Complaint Full

Inspection Disposition: Call Back -  
Complied

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

47-02-4

- From initial inspection : Observed scorch marks around electrical outlet. For reporting purposes only. Behind prep table - From follow-up inspection 2019-08-22: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only. Behind prep table

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.