

Broward County

License Number: 1622143

HYATT PLACE FT LAUDERDALE AIRPORT & CRUISE PORT

License Type: Permanent Food Service

91 SW 18 AVE, DANIA BEACH 33004

Inspection Date: 09/04/2019

Inspection Number: 2915778

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CONSIGLIO, CAMILLE

Violation CodeObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-02-5 Insurance inspector boiler report not posted in boiler room. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1610568

ANGELA'S ON THE BEACH AT THE QUADOMAINE

License Type: Permanent Food Service

2201 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 09/05/2019

Inspection Number: 2944063

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: CONSIGLIO, CAMILLE

Violation CodeObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-02-5 Insurance inspector boiler report not posted in boiler room. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1616008

CHECKERS DRIVE-IN

License Type: Permanent Food Service

590 E OAKLAND PARK BLVD, WILTON MANORS 33334

Inspection Date: 09/04/2019

Inspection Number: 2917674

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation CodeObservationViolation Citation

45-05-4 Portable fire extinguisher missing from its designated location. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

| | | | |
|--------------------------------------|--|---|--|
| License Number: 2321511 | | HOLIDAY INN EXPRESS | |
| License Type: Permanent Food Service | | 6650 W 20 AVE, HIALEAH 33016 | |
| Inspection Date: 09/03/2019 | Inspection Number: 2915726 | Inspection Type: Routine - Food | Inspection Disposition: Warning Issued |
| Inspector Name: CABANAS, NATALIE | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed boiler certificate expired. | 61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. | |
| License Number: 2334605 | | ADRIAN FISH MARKET & RESTAURANT CORP | |
| License Type: Permanent Food Service | | 13115 W OCKEECHOBEE RD UNITS 115-11, HIALEAH GARDENS 33018 | |
| Inspection Date: 09/05/2019 | Inspection Number: 2909213 | Inspection Type: Routine - Food | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: HERNANDEZ, NILYAM | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 2331613 | | MIAMI KAVA | |
| License Type: Permanent Food Service | | 4400 NW 2 AVE, MIAMI 33127 | |
| Inspection Date: 09/05/2019 | Inspection Number: 2930573 | Inspection Type: Routine - Food | Inspection Disposition: Warning Issued |
| Inspector Name: SANCHEZ, JAVIER | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 45-05-4 | Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed fire extinguisher stored in the floor in the Bar area | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| License Number: 2331808 | | PRIME ITALIAN | |
| License Type: Permanent Food Service | | 101 OCEAN DRIVE, MIAMI BEACH 33139 | |
| Inspection Date: 09/06/2019 | Inspection Number: 2894720 | Inspection Type: Routine - Food | Inspection Disposition: Warning Issued |
| Inspector Name: HERNANDEZ, NILYAM | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |

Dade County

License Number: 2325650

BOSTON MARKET # 0636

License Type: Permanent Food Service

8070 NW 36 ST, MIAMI 331666610

Inspection Date: 09/06/2019

Inspection Number: 2886257

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SEYBA, JAMES

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed fire extinguisher by dishwasher area.in the recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329242

CATERING SHOP INC

License Type: Catering

14233 S DIXIE HWY, MIAMI 33176

Inspection Date: 09/06/2019

Inspection Number: 1113416

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2329252

INEDIT GOURMET

License Type: Catering

12100 SW 132 CT #A-116, MIAMI 33186

Inspection Date: 09/05/2019

Inspection Number: 1113454

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LODENQUAI, BARRINGTON

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3906719

NEW YORK GIANTS PIZZA INC

License Type: Permanent Food Service

14609 LIVINGSTON AVE, LUTZ 33559

Inspection Date: 09/06/2019

Inspection Number: 2943841

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: HIRST, DAN

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Ladder and soda crates blocking back door.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Exposed wires on hood above fryer and two burner stove unit.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3912840

DANNY'S ALL AMERICAN CAFE

License Type: Permanent Food Service

4406 FALKENBURG RD, TAMPA 33610

Inspection Date: 09/06/2019

Inspection Number: 2892866

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: AIELLO, ROCCI

Violation CodeObservationViolation Citation

49-05-4

Operator increased seating from 10-34 seats. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3916362

GOLDEN BAKERY

License Type: Permanent Food Service

12822 N 56 ST, TEMPLE TERRACE 33617

Inspection Date: 09/06/2019

Inspection Number: 2894877

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MAIO, BRENNNA

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4101180

TIKI BAR & GRILL

License Type: Permanent Food Service

1130 INDIAN RIVER DRIVE, SEBASTIAN 32958

Inspection Date: 09/06/2019

Inspection Number: 2900921

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: MAYNARD, DIANE

Violation Code

Observation

Violation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. - From follow-up inspection 2019-09-06: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105226

JERSEY MIKE'S SUBS

License Type: Permanent Food Service

8210 TOURIST CENTER DR, BRADENTON 34201

Inspection Date: 08/31/2019

Inspection Number: 2911565

Inspection Type: Routine - Food

Inspection Disposition: Emergency
Order Callback Complied

Inspector Name: SAYED, MOHAMMED

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2019-08-30: **Time Extended** - From follow-up inspection 2019-08-31: Observed gauge in the red zone. **Time Exten

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301453

TWO BROTHERS PIZZA LLC

License Type: Permanent Food Service

8423 SE CHURCH ST, HOBE SOUND 33455

Inspection Date: 09/05/2019

Inspection Number: 2932993

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. small deep fryer/small flat top grill ./kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301846

POPEYES LOUISIANA KITCHEN

License Type: Permanent Food Service

6860 SOUTH KANNER HWY, STUART 34997

Inspection Date: 09/05/2019

Inspection Number: 2922955

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5806164

BURGER KING #6962

License Type: Permanent Food Service

12371 S ORANGE BLOSSOM TRL, ORLANDO 32837

Inspection Date: 09/06/2019

Inspection Number: 2904996

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GUTTERMAN, KENNETH

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only next to mgr office.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6019135

SMOKEY BONES BAR & FIRE GRILL #7539

License Type: Permanent Food Service

10260 FOREST HILL BLVD, WELLINGTON 33414

Inspection Date: 09/05/2019

Inspection Number: 2895191

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MENOR, MICHAEL

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Exposed electrical wiring on the line and through out the kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6051565

MIRO'S MOBILE CATERING

License Type: Mobile Food Dispensing Vehicle

5850 GRAND HARBOUR CIR, BOYNTON BEACH 33437

Inspection Date: 09/05/2019

Inspection Number: 1203459

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: HARVIE, HARUKO

Violation CodeObservationViolation Citation

45-06-4

- From initial inspection : Portable fire extinguisher is inaccessible. For reporting purposes only. - From follow-up inspection 2019-09-05: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

| | | | |
|--------------------------------------|---|---|--|
| License Number: 6217938 | | SOUL SICILIAN FUSION | |
| License Type: Permanent Food Service | | 516 CLEVELAND ST, CLEARWATER 33755 | |
| Inspection Date: 09/03/2019 | Inspection Number: 2943431 | Inspection Type: Food-Licensing Inspection | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: PIATT, PAUL | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only. A divider was blocking, moved **Corrected On-Site** | 61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only. | |

| | | | |
|--------------------------------------|--|---|--|
| License Number: 6217940 | | ALOHA TO GO HALE | |
| License Type: Permanent Food Service | | 5903 SEMINOLE BLVD, SEMINOLE 33772 | |
| Inspection Date: 09/05/2019 | Inspection Number: 2932843 | Inspection Type: Food-Licensing Inspection | Inspection Disposition: Warning Issued |
| Inspector Name: LANTIGUA, ROBERTO | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 45-02-4 | Portable fire extinguisher on the floor, gauge in red zone. For reporting purposes only. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |
| 45-02-4 | - From initial inspection : Portable fire extinguisher on the floor, gauge in red zone. For reporting purposes only. - From follow-up inspection 2019-09-06: | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |

| | | | |
|--------------------------------------|---|---|--|
| License Number: 6216000 | | MIKES PIZZA & PUB | |
| License Type: Permanent Food Service | | 14479 WALSINGHAM RD, LARGO 33774 | |
| Inspection Date: 09/03/2019 | Inspection Number: 2898402 | Inspection Type: Routine - Food | Inspection Disposition: Warning Issued |
| Inspector Name: KOUSTIS, TIMOTHY | | | |
| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> | |
| 47-03-4 | Observed electrical wiring in disrepair. For reporting purposes only. Electrical box next to kettle in back prep area has no cover. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. | |

Pinellas County

License Number: 6216757

SUBWAY

License Type: Permanent Food Service

1388 TAMPA RD, PALM HARBOR 34683

Inspection Date: 09/03/2019

Inspection Number: 2900758

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PIATT, PAUL

Violation Code

Observation

Violation Citation

46-04-4 Exit door locked. For reporting purposes only. Unbolted **Corrected On-Site**

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Polk County

License Number: 6304508

HUNGRY HOWIES

License Type: Permanent Food Service

5218 S FLORIDA AVE, LAKE LAND 338132516

Inspection Date: 09/06/2019

Inspection Number: 2888381

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BEAULIEU, STEPHANIE

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. By soda bibbs

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.