

Alachua County

License Number: 1103198	ZAXBY'S		
License Type: Permanent Food Service	1 NW 10TH AVE, GAINESVILLE	32601	
Inspection Date: 09/18/2019	Inspection Number: 2902787	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WEATHERS, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Trash bags blocking back exit door. Moved. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

License Number: 1101748	POPEYES FRIED CHICKEN #128		
License Type: Permanent Food Service	1412 N MAIN ST, GAINESVILLE	326014368	
Inspection Date: 09/18/2019	Inspection Number: 2942482	Inspection Type: Complaint Full	Inspection Disposition: Call Back - Complied
Inspector Name: WEATHERS, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Exit by mop sink blocked by 3 mop buckets and batter table for different store. Moved mop buckets to make walk way more accessible, but still partially blocked. **Corrective Action Taken** - From follow-up inspection 2019-09-10: Back door still blocked by breader table for different store. - From follow-up inspection 2019-09-18: Table not present. Some boxes blocking back door. Moved boxes. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

License Number: 1102844	SANDY'S PLACE		
License Type: Permanent Food Service	5001 NW 34 ST STE G, GAINESVILLE	32605	
Inspection Date: 09/17/2019	Inspection Number: 2884211	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CASEY, KEITH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-01-4	Flammables stored/debris present in meter room. For reporting purposes only. Observed wood stored up against an open circuit breaker box. Wood was discarded. **Corrected On-Site**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.	

License Number: 1102451	MCDONALDS		
License Type: Permanent Food Service	5110 NW 43 ST, GAINESVILLE	326064455	
Inspection Date: 09/19/2019	Inspection Number: 2885406	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WEATHERS, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Trash cart blocking back exit door. Moved cart. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

Brevard County

License Number: 1506118		MCDONALDS RESTAURANTS NAT 33138	
License Type: Permanent Food Service		235 PALM BAY RD, WEST MELBOURNE 32904	
Inspection Date: 09/18/2019	Inspection Number: 2895995	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FRANZ, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.- by bun racks **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 1506690		DUNKIN DONUTS	
License Type: Permanent Food Service		3490 SE BAYSIDE LAKES BLVD, PALM BAY 32909	
Inspection Date: 09/17/2019	Inspection Number: 2913023	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MAYNARD, DIANE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1505717		PANERA BREAD #4151	
License Type: Permanent Food Service		299 E. EAU GALLIE BLVD, INDIAN HARBOUR BEACH 32937	
Inspection Date: 09/20/2019	Inspection Number: 2892787	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HICKS, GEORGE RANDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Emergency light in prep area hanging by wire.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1653134

GIMME GRILLIN

License Type: Mobile Food Dispensing Vehicle

5817 SW 21 STREET, WEST PARK 33023

Inspection Date: 09/18/2019

Inspection Number: 1220080

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation CodeObservationViolation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1611641

MCDONALD'S'S

License Type: Permanent Food Service

2300 W SUNRISE BLVD, FORT LAUDERDALE 33311-5756

Inspection Date: 09/16/2019

Inspection Number: 2885616

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MATTIELLO-ATASSI, MARIA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by ice machine.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2353395		ELSA MARINA FLORES	
License Type: Mobile Food Dispensing Vehicle		2882 W 71 PL, HIALEAH 33002	
Inspection Date: 09/16/2019	Inspection Number: 1213888	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330246		LA QUINTA INN & SUITES #7709	
License Type: Permanent Food Service		7925 NW 154 ST, MIAMI 33016	
Inspection Date: 09/16/2019	Inspection Number: 2924818	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CRUZ, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed certificate last dated 12/07/2016	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2325640		SUPREME CAFETERIA	
License Type: Permanent Food Service		2650 ALI BABA AVE, OPA-LOCKA 33054	
Inspection Date: 09/18/2019	Inspection Number: 2905861	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: UNZAGA, MILADYS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. By the door of the establishment .	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2317488

CROWNE PLAZA HOTEL MIAMI INTERNATIONAL AIRPORT

License Type: Permanent Food Service

950 NW LEJEUNE RD, MIAMI 33126

Inspection Date: 09/19/2019

Inspection Number: 2914014

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENLEY, LATONYA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. As per operator, establishment installed 3 new boilers since the last inspection. One expired, FI 122648 expired 09/29/18

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2359057

CARMEN CORDERO

License Type: Mobile Food Dispensing Vehicle

1810 NW 21 TERRACE, MIAMI 33142

Inspection Date: 09/16/2019

Inspection Number: 1219996

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HODGE, KRISTEN

Violation CodeObservationViolation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only. **Corrective Action Taken**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334265

PDQ 1015 FOUNTAIN SQUARE

License Type: Permanent Food Service

10121 W FLAGLER ST, MIAMI 33174

Inspection Date: 09/16/2019

Inspection Number: 2931022

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone in back kitchen area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2335331		DICKEY'S BARBECUE PIT	
License Type: Permanent Food Service		10071 W FLAGLER STREET STE C110, MIAMI 33174	
Inspection Date: 09/16/2019	Inspection Number: 2913782	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher in recharging zone in back of store, in front of restrooms.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2334020		PEPITOLANDIA CORP	
License Type: Permanent Food Service		10201 NW 58 ST #105, DORAL 33178	
Inspection Date: 09/18/2019	Inspection Number: 2903688	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher on cook line in "recharge " zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329624		FAVA CATERING	
License Type: Catering		12222 SW 132 CT, MIAMI 33186	
Inspection Date: 09/18/2019	Inspection Number: 1114080	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LODENQUAI, BARRINGTON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2324671		ERNESTO'S TACO SHOP	
License Type: Permanent Food Service		20095 SOUTH DIXIE HIGHWAY, MIAMI 33189	
Inspection Date: 09/20/2019	Inspection Number: 2905437	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HERNANDEZ, NILYAM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Observed exposed electrical wiring nest to walk in cooler.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2611577

HARDEES

License Type: Permanent Food Service

6680 COMMONWEALTH AVE, JACKSONVILLE 32254

Inspection Date: 09/16/2019

Inspection Number: 2911534

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher near rear exit door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917239		HEAVENLY HERSHEY'S ICE CREAM	
License Type: Permanent Food Service		2494 W BRANDON BLVD, BRANDON 33511	
Inspection Date: 09/20/2019	Inspection Number: 2906159	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CANNELLA, MARK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher stored under employee hand wash sink in back prep .	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3917506		DAILY DOSE COFFEE HOUSE AND EATERY	
License Type: Permanent Food Service		302 KNIGHTS RUN # 130, TAMPA 33602	
Inspection Date: 09/17/2019	Inspection Number: 2926156	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: COLEMAN, TONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. 3 propane gas burners - From follow-up inspection 2019-09-17: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 3917308		XIMENA'S MEXICAN RESTAURANT	
License Type: Permanent Food Service		8416 N 56 ST, TEMPLE TERRACE 33617	
Inspection Date: 09/20/2019	Inspection Number: 2923730	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MAIO, BRENNNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Lake County

License Number: 4508763

DOMINO'S PIZZA

License Type: Permanent Food Service

210 N US HWY 441/27, LADY LAKE 32159

Inspection Date: 09/16/2019

Inspection Number: 2914473

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SULLIVAN, SENJUN

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.
Extinguisher behind pizza oven.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4500897

COPPERHEAD BAR & GRILL

License Type: Permanent Food Service

1850 US 441, LEESBURG 34748

Inspection Date: 09/17/2019

Inspection Number: 2946458

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: SULLIVAN, SENJUN

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4606006

EL TARASCO MEXICAN RESTAURANT

License Type: Permanent Food Service

728 PINE ISLAND RD SW STE 8-9, CAPE CORAL 33991

Inspection Date: 09/16/2019

Inspection Number: 2903159

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EHMER, ANNETTE

Violation Code

Observation

Violation Citation

45-02-4

Observed: Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door.
Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5201836

WENDY'S 4938

License Type: Permanent Food Service

3001 E SILVER SPRINGS BLVD, OCALA 34470

Inspection Date: 09/17/2019

Inspection Number: 2943452

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Near back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5300501

SAILFISH POINT CLUBHOUSE

License Type: Permanent Food Service

2201 SE SAILFISH POINT BLVD, STUART 34996-1911

Inspection Date: 09/19/2019

Inspection Number: 2889245

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. One on floor by office.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Monroe County

License Number: 5402727

A SLICE OF PARADISE

License Type: Permanent Food Service

24458 OVERSEAS HWY, SUMMERLAND KEY 33042

Inspection Date: 09/19/2019

Inspection Number: 2891389

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603962

JIMMY BUFFETT'S MARGARITAVILLE CAFE 2ND FLOOR

License Type: Permanent Food Service

76 HARBOR BLVD, DESTIN 32541

Inspection Date: 09/19/2019

Inspection Number: 2947647

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. ****Repeat Violation****

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Okeechobee County

License Number: 5700705

PAPA JOHN'S PIZZA

License Type: Permanent Food Service

414-A NE PARK ST, OKEECHOBEE 34972

Inspection Date: 09/17/2019

Inspection Number: 2911113

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SAYED, MOHAMMED

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Observed at back exterior door. **Repeat Violation**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Observed electrical light fixture in walk-in Cooler with glass globe filling with condensation.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811876		COLD STONE CREAMERY	
License Type: Permanent Food Service		11565 UNIVERSITY BLVD SUITE 3, ORLANDO 32817	
Inspection Date: 09/16/2019	Inspection Number: 2894101	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At the office glass door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5810726		SMOKEY BONES BAR & FIRE GRILL #7519	
License Type: Permanent Food Service		303 N ALAFAYA TRL, ORLANDO 32828	
Inspection Date: 09/16/2019	Inspection Number: 2895184	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: WILSON, LANETTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. In hot water heater room	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
49-03-4	Flammables stored/debris present in boiler room. For reporting purposes only. Propane heaters	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.	
License Number: 5814579		BOLAY	
License Type: Permanent Food Service		12711 NARCOOSEE RD STE 120, LAKE NONA 32832	
Inspection Date: 09/20/2019	Inspection Number: 2922739	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked, empty boxes by back door.. For reporting purposes only. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5811592		SAPORITO	
License Type: Permanent Food Service		2759 OLD WINTER GARDEN RD, OCOEE 34761	
Inspection Date: 09/17/2019	Inspection Number: 2925447	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GREENE, MARVIN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Chair blocking exit in back room.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

Orange County

License Number: 5812945

THE OCOEE TACO COMPANY

License Type: Permanent Food Service

40 TAYLOR ST, OCOEE 34761

Inspection Date: 09/20/2019

Inspection Number: 2909405

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GREENE, MARVIN

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer on table next to ice machine.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5901291

BURGER KING #6662

License Type: Permanent Food Service

1936 E OSCEOLA PKWY, KISSIMMEE 34743

Inspection Date: 09/17/2019

Inspection Number: 2944412

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

45-06-4 Portable fire extinguisher is inaccessible. For reporting purposes only. Silver class extinguisher mounted very high on wall and possibly inaccessible to employees.
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6012029		FRESCO FOOD WORKS	
License Type: Permanent Food Service		1449 YAMATO RD #5, BOCA RATON 33431	
Inspection Date: 09/17/2019	Inspection Number: 2898054	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - flat grill cooking, without exhaust hood or fire suppression system, is producing grease laden vapors as evidenced by HEAVY grease build-Up on undersides of stainless steel shelving above the grill.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6021375		WEST ATLANTIC CHENRON	
License Type: Permanent Food Service		7533 W ATLANTIC AVE, DELRAY BEACH 33446	
Inspection Date: 09/18/2019	Inspection Number: 2909851	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missindesignated location. For reporting purposes only. - ONE "Class ABC" portable extinguisher with a current inspection tag is properly mounted. - TWO "ClassABC" portable extinguishers with inspection tags from 2015 are on the floor below mounted extinguisher..	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6021888		ANGELOS PIZZERIA & RISTORANTE	
License Type: Permanent Food Service		16145 S STATE RD 7 STE C, DELRAY BEACH 33446	
Inspection Date: 09/13/2019	Inspection Number: 2930337	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. "K Class" Portable Fire Extinguisher is on floor beneath K-Placard	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6019355		SUBWAY	
License Type: Permanent Food Service		7459 S MILITARY TRL STE F, LAKE WORTH 33463	
Inspection Date: 09/20/2019	Inspection Number: 2910601	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KHATOON, BEGUM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked . For reporting purposes only.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

Palm Beach County

License Number: 6020330

BAGEL BISTRO

License Type: Permanent Food Service

173 N. US HIGHWAY 1, TEQUESTA 33469

Inspection Date: 09/18/2019

Inspection Number: 2910510

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6021041

MCCARTHY'S PUB

License Type: Permanent Food Service

518 N US HWY 1, TEQUESTA 33469

Inspection Date: 09/18/2019

Inspection Number: 2913502

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6020308

DAVITO'S ITALIAN RESTAURANT

License Type: Permanent Food Service

19635 STATE RD 7, BOCA RATON 33498

Inspection Date: 09/13/2019

Inspection Number: 2927384

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: BANNIGAN, TIM

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.

- Exit path from Dining Rom to rear emergency egress is blocked by
- cases of wine,
- cases of single service items,
- furniture,
- dunnage rack,
- kitchen equipment,

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Pasco County

License Number: 6102098

CHECKERS #212

License Type: Permanent Food Service

9104 SR 52, HUDSON 34667

Inspection Date: 08/09/2019

Inspection Number: 2887744

Inspection Type: Routine - Food

Inspection Disposition: Emergency
Order Callback Complied

Inspector Name: DAHL, MICHELE

Violation CodeObservationViolation Citation

47-02-4

- From initial inspection : Observed scorch marks around electrical outlet. For reporting purposes only. Next to ice machine in kitchen - From follow-up inspection 2019-08-09: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6101385

BROKEN YOLK

License Type: Permanent Food Service

3350 GRAND BLVD, HOLIDAY 34690

Inspection Date: 09/17/2019

Inspection Number: 2891536

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: PIATT, PAUL

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Near the meat slicer

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6216315

ACUNA THE SWEET SPOT LLC

License Type: Permanent Food Service

2609 ALT 19 STE A, PALM HARBOR 34683

Inspection Date: 09/18/2019

Inspection Number: 2946804

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PIATT, PAUL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Kitchen area **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Santa Rosa County

License Number: 6701556

KENTUCKY FRIED CHICKEN #0421

License Type: Permanent Food Service

4683 US HWY 90, PACE 32571

Inspection Date: 09/20/2019

Inspection Number: 2908787

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HALL, DAVID

Violation Code

Observation

Violation Citation

45-02-4

Fire alarm panel alarming "check 974". For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sumter County

License Number: 7000268

JOHN'S QUICK LUNCH

License Type: Permanent Food Service

WEBSTER FLEA MARKET, WEBSTER 33597

Inspection Date: 09/16/2019

Inspection Number: 2890174

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

47-02-4

Observed scorch marks around electrical outlet. For reporting purposes only. On end of reach in cooler, operator pulled out plug. Plug also has scorch marks

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405091		CRACKER BARREL #158	
License Type: Permanent Food Service		2325 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114	
Inspection Date: 09/20/2019	Inspection Number: 2885255	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked by catering boxes by training room. For reporting purposes only. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 7407491		ROCK BOTTOM RESTAURANT AND BREWERY	
License Type: Permanent Food Service		1864 VICTORY LN, DAYTONA BEACH 32114	
Inspection Date: 09/20/2019	Inspection Number: 2918103	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BRANNER, LISELOTTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit door ground floor partial blocked in stairway area by coke rack and dry vacuum.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
48-04-4	4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building under stairwell. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 7407232		RED BOWL	
License Type: Permanent Food Service		1820 DUNLAWTON AVE #105, PORT ORANGE 32127	
Inspection Date: 09/16/2019	Inspection Number: 2912102	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: LARSON, SARAH			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building, dry storage area. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	