

Brevard County

License Number: 1550703

HALEY'S SMOKEHOUSE

License Type: Mobile Food Dispensing Vehicle

3450 BAYSIDE LAKES BLVD SE, PALM BAY 32909

Inspection Date: 10/03/2019

Inspection Number: 1220177

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MAYNARD, DIANE

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1624834	TOOJAYS		
License Type: Permanent Food Service	131 S COMPASS WAY, DANIA BEACH 33004		
Inspection Date: 09/30/2019	Inspection Number: 2932295	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONSIGLIO, CAMILLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 1621753	MYRON'S DELI		
License Type: Permanent Food Service	777 ISLE OF CAPRI CIR, POMPANO BEACH 33069		
Inspection Date: 10/03/2019	Inspection Number: 2915055	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BURGGRAVE, BROCK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 098779 and 134717 both expired 8/31/2019	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 1621754	FARMER'S PICK BUFFET		
License Type: Permanent Food Service	777 ISLE OF CAPRI CIR, POMPANO BEACH 33069		
Inspection Date: 10/03/2019	Inspection Number: 2893622	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BURGGRAVE, BROCK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 098779 and 134717 both expired on 8/31/2019	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 1621762	BRAGOZZO RESTAURANT		
License Type: Permanent Food Service	1800 SW 3 ST, POMPANO BEACH 33069		
Inspection Date: 10/03/2019	Inspection Number: 2893571	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BURGGRAVE, BROCK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 098779 and 134717 8/31/2019 expired.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Broward County

License Number: 1621763

FARRADAYS REST SPORTS BAR & TRACKSIDE BAR

License Type: Permanent Food Service

1800 SW 3 ST, POMPANO BEACH 33069

Inspection Date: 10/03/2019

Inspection Number: 2893572

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BURGGRABE, BROCK

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 098779 and 134717 expired on 8/31/2019.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1621848

EMPLOYEE CAFETERIA 2ND FLOOR

License Type: Permanent Food Service

1 N FT LAUDERDALE BEACH BLVD, FORT LAUDERDALE 33304

Inspection Date: 09/30/2019

Inspection Number: 2896145

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per operator, new boilers were installed recently, however they do not have the certificates.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1611718

KFC #11

License Type: Permanent Food Service

990 W COMMERCIAL BLVD, FORT LAUDERDALE 33309

Inspection Date: 10/03/2019

Inspection Number: 2951268

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Exit door blocked with boxes. **Corrected On-Site** **Repeat Violation**

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Collier County

License Number: 2102881

SALSA BRAVA MEXICAN GRILL

License Type: Permanent Food Service

10265 TAMIAMI TRAIL N #10, NAPLES 34108

Inspection Date: 10/04/2019

Inspection Number: 2899036

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: PFENNING, BRUNO

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Operator moved fire extinguisher to proper location. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2321888		YULY RESTAURANT	
License Type: Permanent Food Service		4256 W 12 AVE, HIALEAH 33012	
Inspection Date: 10/02/2019	Inspection Number: 2922750	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: CUDEMOS, VIRNA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2331931		LA PARRILLA LATINA	
License Type: Permanent Food Service		28864 S DIXIE HWY, HOMESTEAD 33033	
Inspection Date: 10/03/2019	Inspection Number: 2913776	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ORDONEZ, CATALINA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Blocked with cleaning utensils mops, brooms. **Repeat Violation**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2357350		HAPPY FACE HOT DOGS	
License Type: Mobile Food Dispensing Vehicle		1839 NW 22 ST, MIAMI 33142	
Inspection Date: 09/30/2019	Inspection Number: 1214498	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SANCHEZ, JAVIER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2322545		PIZZA HUT #710720	
License Type: Permanent Food Service		6500 SW 8 ST, MIAMI 331444816	
Inspection Date: 09/30/2019	Inspection Number: 2883635	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Wheeled cart. Operator moved during the inspection. **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

Duval County

License Number: 2612054		CURRENTS RIVERVIEW BISTRO	
License Type: Permanent Food Service		841 PRUDENTIAL DR, JACKSONVILLE 32207	
Inspection Date: 10/01/2019	Inspection Number: 2896886	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ARMSTRONG, RICO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 089947 8/16/19 089946 8/16/19 expired	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2614330		TOWERS	
License Type: Permanent Food Service		841 PRUDENTIAL DRIVE STE 170, JACKSONVILLE 32207	
Inspection Date: 10/01/2019	Inspection Number: 2896554	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ARMSTRONG, RICO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificates expired on 8/16/19 08994 089947	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2615757		TEAPOSH NATURALS	
License Type: Permanent Food Service		1818 N DAVIS ST, JACKSONVILLE 32209	
Inspection Date: 10/02/2019	Inspection Number: 2950416	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FEAGANS, ASHLEY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only. Exit door at the back of the kitchen is locked. Owner unlocked the door. **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2613598		WENDY'S	
License Type: Permanent Food Service		10911 BAYMEADOWS RD, JACKSONVILLE 32256	
Inspection Date: 10/02/2019	Inspection Number: 2891285	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOSAI, MATT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rae exit blocked by equipment. Moved by manager. **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

Duval County

License Number: 2615008

DUNKIN DONUTS

License Type: Permanent Food Service

8520 BAYMEADOWS RD, JACKSONVILLE 32256

Inspection Date: 10/01/2019

Inspection Number: 2914607

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
 Rear exit blocked by equipment.
 Moved by manager. **Corrected On-Site**

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Hardee County

License Number: 3500216

PIZZA HUT #4675

License Type: Permanent Food Service

1498 US HWY 17 NORTH, WAUCHULA 33873

Inspection Date: 09/30/2019

Inspection Number: 2896585

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed conduit and light switch, within splash area above handsink rusty and in disrepair .and in disrepair

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4605870		MEL'S DINER	
License Type: Permanent Food Service		1331 PINE ISLAND RD NE, CAPE CORAL 33909	
Inspection Date: 10/01/2019	Inspection Number: 2900455	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: EHMER, ANNETTE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door in back prep area. - From follow-up inspection 2019-10-01: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 4603108		MCDONALDS #10835	
License Type: Permanent Food Service		13600 INDIAN PAINT LN, FORT MYERS 33912	
Inspection Date: 09/30/2019	Inspection Number: 2914177	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PAGAN, VIRMAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed the exit door blocked by trash cart. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 4604448		RESTAURANT & LECHONERA EL JIBARITO INC	
License Type: Permanent Food Service		522 JOEL BLVD STE A, LEHIGH ACRES 33972	
Inspection Date: 10/02/2019	Inspection Number: 2928643	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: JOHNSON, JONATHAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Levy County

License Number: 4800430

HARDEE'S

License Type: Permanent Food Service

306 W NOBLE AVE, WILLISTON 32696

Inspection Date: 10/01/2019

Inspection Number: 2908011

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PACE, PATRICK

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
On silver extinguisher near hand washing sink, on red extinguisher next to back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5105683

WINGSTOP

License Type: Permanent Food Service

3553 1 ST E, BRADENTON 34208

Inspection Date: 09/30/2019

Inspection Number: 2916993

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: KNOX, KHALENA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5105042

LITTLE CAESERS 2044-0006

License Type: Permanent Food Service

4458 CORTEZ RD, BRADENTON 34210

Inspection Date: 10/04/2019

Inspection Number: 2918485

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: RICHENDOLLAR, SANDRA

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Observed two fire extinguishers on floor, front register area, back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5201551

DALLAS INN

License Type: Permanent Food Service

16860 S HWY 301, SUMMERFIELD 34491

Inspection Date: 09/30/2019

Inspection Number: 2947632

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
At the bar area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301290

CATFISH HOUSE

License Type: Permanent Food Service

11500 SE FEDERAL HWY, HOBE SOUND 33455

Inspection Date: 10/02/2019

Inspection Number: 2889296

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. electrical outlet
by walk in cooler/missing cover plate.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5300781

MONARCH C C MAIN KITCHEN

License Type: Permanent Food Service

1801 SW MONARCH CLUB DR, PALM CITY 34990-4712

Inspection Date: 10/03/2019

Inspection Number: 2886812

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside
of the building. For reporting purposes only. 2 lp tanks in storage room, were
removed to exterior. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5808961		COURTYARD ORLANDO ALTAMONTE SPRINGS MAITLAND	
License Type: Permanent Food Service		1750 PEMBROOK DR, ORLANDO 32810	
Inspection Date: 10/04/2019	Inspection Number: 2920380	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LUI, SUK HAN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Per manager, inspection was done last week/waiting for certificate.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 5812921		MEXAS TACOS	
License Type: Permanent Food Service		8788 VINELAND AVENUE, ORLANDO 32821	
Inspection Date: 09/30/2019	Inspection Number: 2921020	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: FERTIL, SYLVERST			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-01-4	Multi plug in use for small equipment.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5810902		HOFFNER CATERING & SUPPLY	
License Type: Catering		4880 B DISTRIBUTION CT UNIT 1-2, ORLANDO 32822	
Inspection Date: 09/30/2019	Inspection Number: 1113309	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed, establishment is using flat grills on prep table.. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5814255		SUBWAY 748	
License Type: Permanent Food Service		7780 LAKE UNDERHILL RD, ORLANDO 32822	
Inspection Date: 10/04/2019	Inspection Number: 2922057	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RULLAN, ALFONSO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked, empty boxes by back door.. For reporting purposes only.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

Orange County

License Number: 5811307

BANQUET PRODUCTION KITCHEN

License Type: Permanent Food Service

1500 MASTERS BLVD, CHAMPIONS GATE 33896

Inspection Date: 10/02/2019

Inspection Number: 2891302

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BELTRAN, SANDRA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.61C-1.004(9) FAC Reporting: (9) Heating and ventilation
- The heating and ventilation system shall be kept in
good repair or be installed to maintain a minimum of 68
degrees Fahrenheit throughout the building. The
insurance inspector's boiler report is required annually
for power boilers and high pressure/high temperature
boilers and biannually for low pressure steam or vapor
heating boilers and shall be posted in the boiler room.
For reporting purposes only.

License Number: 5814463

HIBACHI EXPRESS

License Type: Permanent Food Service

320 MOORE RD, OCOEE 34761

Inspection Date: 09/16/2019

Inspection Number: 2922487

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GREENE, MARVIN

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Osceola County

License Number: 5910870 ZEN/ DAVID'S CLUB / LOBBY BAR
 License Type: Permanent Food Service 1500 MASTERS BLVD, CHAMPIONS GATE 33896

Inspection Date: 10/02/2019 Inspection Number: 2922603 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5910873 MORSEL'S
 License Type: Permanent Food Service 1500 MASTERS BLVD, CHAMPIONS GATE 33896

Inspection Date: 10/02/2019 Inspection Number: 2918698 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5910890 ASSOCIATE DINING
 License Type: Permanent Food Service 1500 MASTERS BLVD, CHAMPIONS GATE 33896

Inspection Date: 10/02/2019 Inspection Number: 2922604 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5910894 TREVIS
 License Type: Permanent Food Service 1500 MASTERS BLVD, CHAMPIONS GATE 33896

Inspection Date: 10/02/2019 Inspection Number: 2918772 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Osceola County

License Number: 5910895 BAKERY
 License Type: Permanent Food Service 1500 MASTERS BLVD, CHAMPIONS GATE 33896

Inspection Date: 10/02/2019 Inspection Number: 2918771 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5910896 BROADWAY DELI
 License Type: Permanent Food Service 1500 MASTERS BLVD, CHAMPIONS GATE 33896

Inspection Date: 10/02/2019 Inspection Number: 2920413 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5911593 OSCEOLA COUNTY CONFERENCE CENTER
 License Type: Permanent Food Service 8494 MIRACLE WAY, CHAMPIONS GATE 33896

Inspection Date: 10/02/2019 Inspection Number: 2919083 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5911594 MARKET PLACE KITCHEN
 License Type: Permanent Food Service 8494 MIRACLE WAY, CHAMPIONS GATE 33896

Inspection Date: 10/02/2019 Inspection Number: 2921369 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BELTRAN, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Osceola County

License Number: 5908186

MCDONALD'S #4112

License Type: Permanent Food Service

2576 SIMPSON RD, KISSIMMEE 34744

Inspection Date: 10/03/2019

Inspection Number: 2894597

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only./trash cart
Corrected On-Site

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Palm Beach County

License Number: 6013364		OPEN KITCHEN CAFE	
License Type: Permanent Food Service		2500 N MILITARY TRL STE 115, BOCA RATON 33431	
Inspection Date: 10/01/2019	Inspection Number: 2930447	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - There is a mobile Exhaust Hood System in use foe grease laden cooking but there is no Fire Suppress	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6020265		FIVE GUYS BURGERS AND FRIES	
License Type: Permanent Food Service		2240 NW 19 ST STE 900, BOCA RATON 33431	
Inspection Date: 09/30/2019	Inspection Number: 2896488	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only. - rear exit door.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 6021949		HANNAH MEDITERRANEAN	
License Type: Permanent Food Service		4822 NW 2ND AVE, BOCA RATON 33431	
Inspection Date: 10/01/2019	Inspection Number: 2921824	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. "K Class" Portable Extinguisher.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6019292		MICHEL CARIBBEAN RESTAURANT	
License Type: Permanent Food Service		1561 S CONGRESS AVE, DELRAY BEACH 33445	
Inspection Date: 10/02/2019	Inspection Number: 2911553	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: AHLE, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed in rear kitchen and dry storage.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Palm Beach County

License Number: 6007073

STELLA'S PIZZERIA

License Type: Permanent Food Service

19585 SR 7 STE M, BOCA RATON 33498

Inspection Date: 10/03/2019

Inspection Number: 2950889

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BANNIGAN, TIM

Violation Code

Observation

Violation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only.
 - deep fryers not separated from open top gas range by 16" separation. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6112991

DUNKIN DONUTS/BASKIN ROBBINS

License Type: Permanent Food Service

2409 HWY 19, HOLIDAY 34691

Inspection Date: 10/02/2019

Inspection Number: 2891703

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PIATT, PAUL

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Trash can
Corrected On-Site

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Pinellas County

License Number: 6217532		DUNKIN DONUTS	
License Type: Permanent Food Service		2298 SEMINOLE BLVD, LARGO 33778	
Inspection Date: 09/30/2019	Inspection Number: 2919004	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: LANTIGUA, ROBERTO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Back door Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6208560		BURGER KING #4010	
License Type: Permanent Food Service		32375 US HWY 19 N, PALM HARBOR 34684	
Inspection Date: 10/01/2019	Inspection Number: 2902618	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PIATT, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. A 6 foot high stack of bread is in the path of the exit. Moved bread **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 6217447		CHICKEN SALAD CHICK	
License Type: Permanent Food Service		35267 US-19, PALM HARBOR 34684	
Inspection Date: 10/03/2019	Inspection Number: 2915258	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PIATT, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Trash bin, removed **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 6217608		GRAIN & BERRY	
License Type: Permanent Food Service		33840 US 19 N, PALM HARBOR 34684	
Inspection Date: 10/01/2019	Inspection Number: 2917082	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PIATT, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Back kitchen area	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Seminole County

License Number: 6904551

SEASONS 52 #4503

License Type: Permanent Food Service

463 E ALTAMONTE DR, ALTAMONTE SPRINGS 32701

Inspection Date: 10/02/2019

Inspection Number: 2911200

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Suwannee County

License Number: 7100290

PILGRIMS PRIDE CAFE

License Type: Permanent Food Service

19740 US HWY 90 W, LIVE OAK 32060

Inspection Date: 09/30/2019

Inspection Number: 2896465

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. On shelf next to oven.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7405261

DELICIAS CENTROAMERICANAS LLC

License Type: Permanent Food Service

722 MASON AVE, DAYTONA BEACH 32117

Inspection Date: 10/04/2019

Inspection Number: 2920695

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7403804

MCDONALD'S #10578

License Type: Permanent Food Service

2697 S WOODLAND BLVD, DELAND 32720

Inspection Date: 10/04/2019

Inspection Number: 2907985

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: OCASIO-LOPEZ, LISA

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
- path to back exit door blocked by rolling bread racks **Corrected On-Site**

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 7406607

EL TACO AMIGO

License Type: Permanent Food Service

201 1/2 WEST NEW YORK AVENUE, DELAND 32720

Inspection Date: 10/03/2019

Inspection Number: 2895225

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: OCASIO-LOPEZ, LISA

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Blue Rhino propane tank, connected to burner, in kitchen by stove.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.