

**Brevard County**

License Number: 1506360 SOUTHERN CHARM CAFE  
 License Type: Permanent Food Service 8501 ASTRONAUT BLVD UNITS 6 - 8, CAPE CANAVERAL 32920

Inspection Date: 11/06/2019 Inspection Number: 2947063 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended  
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Gas can (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Stored in storage room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1506313 MOM & POPS BAR AND GRILL  
 License Type: Permanent Food Service 900 N ATLANTIC AVE STE D, COCOA BEACH 32931

Inspection Date: 11/04/2019 Inspection Number: 2960251 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1504191 RJ'S 2002 RESTAURANT  
 License Type: Permanent Food Service 935 BAREFOOT BLVD STE C, BAREFOOT BAY 32976

Inspection Date: 11/04/2019 Inspection Number: 2920970 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WOODS, CHRISTAL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In bag n box closet 2 20 lb cylinders	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Brevard County**

License Number: 1503612

PAPA'S BBQ

License Type: Permanent Food Service

5675 MICCO RD #6, MICCO 32976

Inspection Date: 11/07/2019

Inspection Number: 2919094

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WOODS, CHRISTAL

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 2 20 lb cylinders

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1624503

HOTEL MORRISON

License Type: Permanent Food Service

28 S FEDERAL HWY, DANIA BEACH 33004

Inspection Date: 11/06/2019

Inspection Number: 2938074

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CONSIGLIO, CAMILLE

Violation Code    ObservationViolation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1621463

PRODUCTION KITCHEN / BAR AND SOUTH PADDOCK CONCESSIONS

License Type: Permanent Food Service

901 S FEDERAL HWY, HALLANDALE 33009

Inspection Date: 11/07/2019

Inspection Number: 2891842

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation Code    ObservationViolation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Certification expired	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	---	---

License Number: 1621470

FLAMINGO ROOM

License Type: Permanent Food Service

901 S FEDERAL HWY, HALLANDALE 33009

Inspection Date: 11/07/2019

Inspection Number: 2923405

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation Code    ObservationViolation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Certification expired	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	---	---

**Broward County**

License Number: 1610568 ANGELA'S ON THE BEACH AT THE QUADOMAIN  
 License Type: Permanent Food Service 2201 S OCEAN DR, HOLLYWOOD 33019

Inspection Date: 11/05/2019 Inspection Number: 2944063 Inspection Type: Complaint Full Inspection Disposition: Call Back -  
 Inspector Name: CONSIGLIO, CAMILLE Complied

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2019-11-05: **Time Extended**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	- From initial inspection : Insurance inspector boiler report not posted in boiler room. For reporting purposes only. - From follow-up inspection 2019-11-05: **Time Extended**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1653148 GRANDMA'S KITCHEN  
 License Type: Mobile Food Dispensing Vehicle 731 NW 18TH STREET, POMPANO BEACH 33060

Inspection Date: 11/07/2019 Inspection Number: 1220993 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection  
 Inspector Name: GANPAT, INDAR Completed - No Further Action

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2102541

MYKONOS KUZINA

License Type: Permanent Food Service

13510 TAMIAMI TRAIL N #1, NAPLES 34110

Inspection Date: 11/04/2019

Inspection Number: 2913990

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PFENNING, BRUNO

Violation Code    Observation

Violation Citation

45-05-4    Portable fire extinguisher missing from its designated location. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2357839 VIBE 305  
 License Type: Mobile Food Dispensing Vehicle 1450 BRICKELL BAY DR #1414, MIAMI 33131

Inspection Date: 11/07/2019 Inspection Number: 1215120 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: HARVIE, HARUKO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335610 LA PIAZZETTA  
 License Type: Permanent Food Service 5143 NE 2 AVE, MIAMI 33137

Inspection Date: 11/05/2019 Inspection Number: 2932763 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SEYBA, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed fire extinguisher in the "recharge" zone by pizza oven.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2330738 MAO COLOMBIAN FAST FOOD  
 License Type: Permanent Food Service 8438 SW 40TH ST, MIAMI 33155

Inspection Date: 11/08/2019 Inspection Number: 2929087 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended  
 Inspector Name: ALVAREZ, MARGARET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Observed empty boxes blocking the way in front of back door emergency exit. - From follow-up inspection 2019-11-08: Marked exit/path to marked exit blo	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2335354 SPOLETO  
 License Type: Permanent Food Service 7535 N KENDALL DR., MIAMI 33156

Inspection Date: 11/08/2019 Inspection Number: 2923106 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MASKASEM, SUPPACHAI

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exit path blocked by boxes. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Dade County**

License Number: 2328386

DAVE & BUSTERS

License Type: Permanent Food Service

11481 NW 12 ST STE E622, MIAMI 33172

Inspection Date: 11/04/2019

Inspection Number: 2883398

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation Code

Observation

Violation Citation

49-04-4

Flammables stored/debris present in laundry room. For reporting purposes only.  
Observed lint behind dryers.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

**DeSoto County**

License Number: 2400314

PIZZA HUT #4600

License Type: Permanent Food Service

2527 SE HWY 70, ARCADIA 34266

Inspection Date: 10/29/2019

Inspection Number: 2918620

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

49-05-4 Flammables stored near a source of ignition. For reporting purposes only.  
\*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Duval County**

License Number: 2613331

RIVERFRONT CAFE & CATERING

License Type: Permanent Food Service

111 RIVERSIDE AVE, JACKSONVILLE 32202

Inspection Date: 11/04/2019

Inspection Number: 2891097

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROZIER, TORRANCE

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small Fryers in the back prep area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3917627

NIDIAS LATIN GRILL

License Type: Permanent Food Service

14164 MARTIN LUTHER KING BLVD JR, DOVER 33527

Inspection Date: 11/04/2019

Inspection Number: 2912448

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation Code    ObservationViolation Citation

45-05-4      Portable fire extinguisher missing from its designated location. For reporting purposes only. K class fire extinguisher stored on floor under employee hand wash sink by three comp sink

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3915620

COLD STONE CREAMERY #20656

License Type: Permanent Food Service

3426 LITHIA PINECREST RD, VALRICO 33596

Inspection Date: 11/06/2019

Inspection Number: 2911645

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: CANNELLA, MARK

Violation Code    ObservationViolation Citation

45-05-4      - From initial inspection : Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher on floor by back door .  
From follow-up inspection 2019-11-06: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906818

POPEYES CHICKEN &amp; BISCUITS #96

License Type: Permanent Food Service

2619 W WATERS AVE, TAMPA 336141834

Inspection Date: 11/05/2019

Inspection Number: 2886588

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AIELLO, ROCCI

Violation Code    ObservationViolation Citation

46-01-4      Marked exit/path to marked exit blocked. For reporting purposes only. Latge amount of empty boxes. \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Lake County**

License Number: 4508685

PICKLE BARREL GENERAL STORE LLC

License Type: Permanent Food Service

9945 CR 44, LEESBURG 34788

Inspection Date: 11/07/2019

Inspection Number: 2908970

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SULLIVAN, SENJUN

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Fryer outside. **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4605477 POPEYES  
 License Type: Permanent Food Service 4400 PALM BEACH BLVD, FORT MYERS 33905

Inspection Date: 11/05/2019 Inspection Number: 2936547 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MOREHEAD, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only above stand up reach-in freezer. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4605710 MIMI'S CAFE  
 License Type: Permanent Food Service 5070 BELL TOWER SHOPS AVE, FORT MYERS 33907

Inspection Date: 11/08/2019 Inspection Number: 2892869 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: EHMER, ANNETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Face plate hanging from outlet by dish machine.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4607333 SPRINGHILL SUITES BY MARRIOTT FORT MYERS / ESTERO  
 License Type: Permanent Food Service 10370 CORKSCREW COMMONS DR, ESTERO 33928

Inspection Date: 11/06/2019 Inspection Number: 2950415 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: JOHNSON, JONATHAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Levy County**

License Number: 4800609

BUBBAQUE'S BBQ #6006

License Type: Permanent Food Service

143 E NOBLE AVE, WILLISTON 32696

Inspection Date: 11/06/2019

Inspection Number: 2910376

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PACE, PATRICK

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Silver extinguisher next to back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5100081

TARPON BAY GRILL & TIKI BAR

License Type: Permanent Food Service

7150 N TAMIAMI TRL, SARASOTA 34243

Inspection Date: 11/05/2019

Inspection Number: 2928522

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

49-05-4 Flammables stored near a source of ignition. For reporting purposes only. Observed torch fuel stored next to gas water heater. Operator removed. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Marion County**

License Number: 5202405

LITTLE CAESARS

License Type: Permanent Food Service

1606 NW 10 ST, OCALA 34475

Inspection Date: 11/04/2019

Inspection Number: 2887154

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HENTGES, JUDY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.next to the phone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Monroe County**

License Number: 5428122

CHAD S

License Type: Permanent Food Service

92330 OVERSEAS HWY, TAVERNIER 33070

Inspection Date: 11/05/2019

Inspection Number: 2930106

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Near front counter

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Nassau County**

License Number: 5501103

WHEEL HOUSE

License Type: Permanent Food Service

41 BEACH-LAGOON ROAD, AMELIA ISLAND 32034

Inspection Date: 11/04/2019

Inspection Number: 2902663

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Little fryer on prep table, frying food

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603534 ARIRANG  
 License Type: Permanent Food Service 172 E WOODUFF AVE, CRESTVIEW 32536

Inspection Date: 11/08/2019 Inspection Number: 2961667 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: STEINMAN, MARC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Hood fire suppression system in place . At time of the inspection no fire suppressive chemical caniste	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5603961 JIMMY BUFFETT'S MARGARITAVILLE  
 License Type: Permanent Food Service 76 HARBOR BLVD, DESTIN 32541

Inspection Date: 11/05/2019 Inspection Number: 2905613 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: STEINMAN, MARC

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Zurich Services arrived during the inspection for Boiler inspection **Corrective Action Taken** **Repeat Violation**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Orange County**

License Number: 5813956

KING BAO

License Type: Permanent Food Service

710 N MILLS AVENUE, ORLANDO 32803

Inspection Date: 11/06/2019

Inspection Number: 2916423

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GREENE, MARVIN

Violation Code

Observation

Violation Citation

46-04-4 Exit door locked. For reporting purposes only. Trash can blocking door.  
\*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Palm Beach County**

License Number: 6020355 GRILLED CHEESE GALLERY  
 License Type: Permanent Food Service 422 NORTHWOOD ROAD, WEST PALM BEACH 33407

Inspection Date: 11/07/2019 Inspection Number: 2930284 Inspection Type: Routine - Food Inspection Disposition: Emergency order recommended  
 Inspector Name: PITRE, ASTRID

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Hood not operating, vapors in kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6018980 SPOTOS OYSTER BAR  
 License Type: Permanent Food Service 4560 PGA BLVD, PALM BEACH GARDENS 33418

Inspection Date: 11/06/2019 Inspection Number: 2923719 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GOLDMAN, BARRY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6019972 FIREHOUSE SUBS  
 License Type: Permanent Food Service 975 GATEWAY BLVD #113, BOYNTON BEACH 33426

Inspection Date: 11/05/2019 Inspection Number: 2936047 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GONZALEZ, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Boxes and garbage	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6020095 LAQUINTA INN  
 License Type: Permanent Food Service 34 FISHERMANS WHARF, JUPITER 33477

Inspection Date: 11/04/2019 Inspection Number: 2944163 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ROTONDI, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Palm Beach County**

License Number: 6021941

PRESS CREAMERY

License Type: Permanent Food Service

9858 CLINT MOORE RD UNIT C132, BOCA RATON 33496

Inspection Date: 10/30/2019

Inspection Number: 2924571

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BANNIGAN, TIM

Violation Code

Observation

Violation Citation

45-06-4

Portable fire extinguisher is inaccessible. For reporting purposes only.

ABC Portable Extinguisher In corner near rear door.. It is completely blocked and inaccessible due to shelving and debris.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Pasco County**

License Number: 6113561 TOP SHELF SNACK BAR  
 License Type: Permanent Food Service 3173 CYPRESS RIDGE BLVD, WESLEY CHAPEL 33544

Inspection Date: 11/04/2019 Inspection Number: 2924445 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: HIRST, DAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.  Restaurant is located in ice rink in Wesley Chapel. Facility provides hot water for all operations for the building. Restaurant has no control or access to the bo	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6102261 LATINO'S CUISINE  
 License Type: Permanent Food Service 4464 GRAND BLVD, NEW PORT RICHEY 34652

Inspection Date: 11/08/2019 Inspection Number: 2920833 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: TORRACO, MARIANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-04-4	- From initial inspection : Establishment did not report seating change that affects the license fee, Clean Indoor Air Act, sewage system approval or other related requirements. 48 seats are present, licensed for 24. Seating increase form emailed . -	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

**Pinellas County**

License Number: 6210275 TACO BELL #3861  
 License Type: Permanent Food Service 10749 PARK BLVD, SEMINOLE 337725420

Inspection Date: 11/07/2019 Inspection Number: 2889820 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LANTIGUA, ROBERTO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked by cardboard boxes. For reporting purposes only.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6212684 BAYOU CLUB  
 License Type: Permanent Food Service 7979 BAYOU CLUB BLVD, LARGO 33777

Inspection Date: 11/05/2019 Inspection Number: 2960258 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LANTIGUA, ROBERTO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Polk County**

License Number: 6308159

PHOLICIOUS

License Type: Permanent Food Service

815 EAGLE RIDGE DR, LAKE WALES 33859

Inspection Date: 11/07/2019

Inspection Number: 2930446

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed fryer with potential of producing grease vapors. Back prep area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





**St. Johns County**

License Number: 6502244

MARCOS PIZZA

License Type: Permanent Food Service

2550 RACETRACK ROAD, SUITE-C, SAINT JOHNS 32259

Inspection Date: 11/08/2019

Inspection Number: 2923452

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
Rear exit blocked by equipment. Moved by manager. **\*\*Corrected On-Site\*\***

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**St. Lucie County**

License Number: 6602458

HAMPTON INN & SUITES

License Type: Permanent Food Service

155 SW PEACOCK BLVD, PORT ST. LUCIE 34986

Inspection Date: 11/07/2019

Inspection Number: 2903074

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code

Observation

Violation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.