

**Broward County**

License Number: 1624297

HOME 2 SUITES BY HILTON FORT LAUDERDALE

License Type: Permanent Food Service

161 SW 19 CT, DANIA BEACH 33004

Inspection Date: 12/05/2019

Inspection Number: 2966424

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CONSIGLIO, CAMILLE

Violation Code    ObservationViolation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1621464

NORTH APRON FOOD COURT - CLUCKERS - BASIL'S - ORALE WAY - SILK'S

License Type: Permanent Food Service

901 S FEDERAL HWY, HALLANDALE 33009

Inspection Date: 12/04/2019

Inspection Number: 2892945

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation Code    ObservationViolation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Expired	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	---	---

License Number: 1621465

SOUTH APRON FOOD COURT - FINISH LINE BAR - MICKIE'S- FINISH LINE

License Type: Permanent Food Service

901 S FEDERAL HWY, HALLANDALE 33009

Inspection Date: 12/04/2019

Inspection Number: 2891843

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation Code    ObservationViolation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certification expired	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
---------	--	---

**Broward County**

License Number: 1621468 TEN PALMS - JOKERS WILD - PEARLS BAR  
 License Type: Permanent Food Service 901 S FEDERAL HWY, HALLANDALE 33009

Inspection Date: 12/04/2019 Inspection Number: 2891848 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GANPAT, INDAR

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certification expired

Violation Citation

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1621469 SERANATA - SPORT OF KINGS - ACE'S HIGH  
 License Type: Permanent Food Service 901 S FEDERAL HWY, HALLANDALE 33009

Inspection Date: 12/04/2019 Inspection Number: 2891849 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GANPAT, INDAR

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certifications expired 9/25/2019.

Violation Citation

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1620490 CHEESECAKE FACTORY (THE)  
 License Type: Permanent Food Service 600 E LAS OLAS BLVD, FORT LAUDERDALE 33301

Inspection Date: 12/02/2019 Inspection Number: 2965553 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BRANN, JUSTIN

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. \*\*Repeat Violation\*\*

Violation Citation

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1616992 BAMMYZ RESTAURANT  
 License Type: Permanent Food Service 105 NORTH STATE ROAD 7, PLANTATION 33309

Inspection Date: 12/04/2019 Inspection Number: 2921185 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: ROSE, MONIQUE

Violation Code Observation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.

Violation Citation

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Broward County**

License Number: 1614235 MIAMI SUBS GRILL  
 License Type: Permanent Food Service 661 W SUNRISE BLVD, FORT LAUDERDALE 33311

Inspection Date: 12/05/2019 Inspection Number: 2951975 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MATTIELLO-ATASSI, MARIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-01-4	Flammables stored/debris present in meter room. For reporting purposes only. Observed a shelf where towels are stored.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 1620585 KENTUCKY FRIED CHICKEN  
 License Type: Permanent Food Service 3061 W SUNRISE, FORT LAUDERDALE 33311

Inspection Date: 12/05/2019 Inspection Number: 2946335 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MATTIELLO-ATASSI, MARIA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1622485 LA BELLE MONIQUE RESTAURANT AND BAKERY  
 License Type: Permanent Food Service 937 STATE ROAD 7, PLANTATION 33317

Inspection Date: 12/05/2019 Inspection Number: 2921720 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: ROSE, MONIQUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Dade County**

License Number: 2332481		EL TROPICO PALETERIA TAQUERIA	
License Type: Permanent Food Service		306 NE 8TH STREET, HOMESTEAD 33030	
Inspection Date: 10/29/2019	Inspection Number: 2931857	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GONZALEZ, ALEJANDRO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Due to delivery boxes. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2331488		GEO'S ICE CREAM	
License Type: Permanent Food Service		204 SW 107 AVE, MIAMI 33174	
Inspection Date: 12/05/2019	Inspection Number: 2893620	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher by restroom in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2315581		BURGER KING 2531	
License Type: Permanent Food Service		955 SW 107 AVE, MIAMI 331742504	
Inspection Date: 12/06/2019	Inspection Number: 2966453	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone by hand wash sink in front of walk in cooler. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330648		KILLER MELTS	
License Type: Permanent Food Service		12310 SW 127 AVE, MIAMI 33186	
Inspection Date: 12/03/2019	Inspection Number: 2949107	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LODENQUAI, BARRINGTON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Duval County**

License Number: 2614425

TIPSY BAR AND GRILL

License Type: Permanent Food Service

243 S EDGEWOOD AVE, JACKSONVILLE 32254

Inspection Date: 11/30/2019

Inspection Number: 2913250

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
Tank in kitchen near cook line. Tank removed. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Escambia County**

License Number: 2706485

SHARON'S DINER

License Type: Permanent Food Service

202 S HWY 29, CANTONMENT 32533

Inspection Date: 12/03/2019

Inspection Number: 2928804

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: RUSSELL, SARAH

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Fire Marshal notified fryer being used without hood.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Highlands County**

License Number: 3801012

BOB EVANS RESTAURANT #478

License Type: Permanent Food Service

2541 US 27 N, SEBRING 33870

Inspection Date: 12/06/2019

Inspection Number: 2927035

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SCHNELL, PAMELA

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. By mass of boxes at back kitchen fire exit.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 3801090

FAIRMOUNT CAFE

License Type: Permanent Food Service

3750 HWY 27 N, SUITE 4E, SEBRING 33870

Inspection Date: 12/06/2019

Inspection Number: 2898545

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: SCHNELL, PAMELA

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with hood not in operation during cooking. Grease laden vapors in air per easily observed odor. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





**Manatee County**

License Number: 5104432

MCDONALDS 4002

License Type: Permanent Food Service

8164 N TAMIAMI TRL, SARASOTA 34243

Inspection Date: 12/02/2019

Inspection Number: 2965398

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Observed wiring and rusted gauges under counter of soda dispensing unit near takeout window.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603245

OLE TIMES COUNTRY BUFFET

License Type: Permanent Food Service

733 E HWY 98, DESTIN 32541

Inspection Date: 12/03/2019

Inspection Number: 2922505

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation Code

Observation

Violation Citation

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Orange County**

License Number: 5812312 MRS POTATO RESTAURANT  
 License Type: Permanent Food Service 4550 S KIRKMAN RD, ORLANDO 32811

Inspection Date: 12/04/2019 Inspection Number: 2896870 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By back exit door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5804349 ISLEWORTH COUNTRY CLUB  
 License Type: Permanent Food Service 6100 PAYNE STEWART DR, WINDERMERE 347868936

Inspection Date: 12/06/2019 Inspection Number: 2887395 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed expired boiler certification 12/6/2019	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



**Pinellas County**

License Number: 6211023 THE PRINCESS MARTHA  
 License Type: Permanent Food Service 411 N 1 AVE, ST. PETERSBURG 33701

Inspection Date: 12/06/2019 Inspection Number: 2900605 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: KOUSTIS, TIMOTHY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. One certificate expired 123643 expired 9/29/18.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6200448 SUNSET GRILLE  
 License Type: Permanent Food Service 2996 DR MARTIN LUTHER KING JR ST N, ST. PETERSBURG 33704

Inspection Date: 12/03/2019 Inspection Number: 2897150 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: WAGNER, MARGARET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215987 PIEROGI GRILL & STEAKHOUSE  
 License Type: Permanent Food Service 1535 GULF TO BAY BLVD, CLEARWATER 33755

Inspection Date: 12/06/2019 Inspection Number: 2892013 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BENEDICT, TRACY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6214001 STROKERS  
 License Type: Permanent Food Service 30901 US HWY 19 N, PALM HARBOR 34684

Inspection Date: 12/05/2019 Inspection Number: 2888266 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PIATT, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Back door near the dry storage area	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Pinellas County**

License Number: 6215720 JETS PIZZA  
 License Type: Permanent Food Service 33486 US 19 N, PALM HARBOR 34684

Inspection Date: 12/03/2019 Inspection Number: 2918057 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: PIATT, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Back door, unlocked **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6214869 HUNGRY HOWIES PIZZA  
 License Type: Permanent Food Service 2109 MAIN ST, DUNEDIN 34698

Inspection Date: 12/04/2019 Inspection Number: 2889842 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PIATT, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Back door	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6215619 FIREHOUSE SUBS-DUNEDIN #92  
 License Type: Permanent Food Service 1547 MAIN STREET, DUNEDIN 34698

Inspection Date: 12/03/2019 Inspection Number: 2890239 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PIATT, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Garbage can removed **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Polk County**

License Number: 6308047

PIZZANOS PIZZA & GRINDERZ

License Type: Permanent Food Service

126 CALIFORNIA BLVD, DAVENPORT 33897

Inspection Date: 12/04/2019

Inspection Number: 2935056

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JACKSON, SHARON

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed a small table top fryer in the kitchen. Farb **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6804840

SOLORZANOS PIZZERIA NORTH PORT

License Type: Permanent Food Service

13001 TAMIAMI TRL, NORTH PORT 34287

Inspection Date: 12/02/2019

Inspection Number: 2965583

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: FERRY, WILLIAM

Violation Code

Observation

Violation Citation

45-04-4

Observed: Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small deep fryer in back no hood.  
Priority: Reporting

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**St. Lucie County**

License Number: 6602746

SAKE TOO JAPANESE AND THAI RESTAURANT

License Type: Permanent Food Service

10785 S.W. TRADITION SQUARE, PORT ST LUCIE 34987

Inspection Date: 12/04/2019

Inspection Number: 2893032

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.by trash can  
\*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Volusia County**

License Number: 7407493 WORM BURNERS GRILL  
 License Type: Permanent Food Service 600 WILDER BLVD, DAYTONA BEACH 32114

Inspection Date: 12/06/2019 Inspection Number: 2919715 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: BRANNER, LISELOTTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-01-4	Flammables stored/debris present in meter room. For reporting purposes only. Grill lighter stored in water heater room. **Corrected On-Site**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 7407046 BRUNO'S PIZZA  
 License Type: Permanent Food Service 1254 OCEANSHORE BLVD, ORMOND BEACH 32176

Inspection Date: 12/05/2019 Inspection Number: 2935755 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RUTLEDGE, REBECCA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406351 ENCORE CATERING OF CENTRAL FL  
 License Type: Catering 105 MANDARIN AVE, DELAND 32720

Inspection Date: 12/03/2019 Inspection Number: 1113211 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: OCASIO-LOPEZ, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 tanks located inside building above refrigerator.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.