

Alachua County

License Number: 1102847 CHINA KING
 License Type: Permanent Food Service 3230 SW 35 BLVD, GAINESVILLE 32608

Inspection Date: 12/09/2019 Inspection Number: 2936596 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed the silver fire extinguisher at the back door, indicator in the red zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1103560 THE CHEESECAKE FACTORY
 License Type: Permanent Food Service 2851 SW 35 DR STE 70, BUTLER TOWN CENTER, GAINESVILLE 32608

Inspection Date: 12/13/2019 Inspection Number: 2942450 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CASEY, KEITH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed lack of a boiler certificate for the 499,900 btu input water heating device. **Repeat Violation**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Broward County

License Number: 1622543

FOUR POINT BY SHERATON FORT LAUDERDALE AIRPORT-DANIA BEACH

License Type: Permanent Food Service

1900 STIRLING RD, DANIA BEACH 33004

Inspection Date: 12/11/2019

Inspection Number: 2967613

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CONSIGLIO, CAMILLE

Violation Code ObservationViolation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1620390

ALEX CUBAN CUISINE

License Type: Permanent Food Service

3153 W HALLANDALE BEACH BLVD, PEMBROKE PARK 33009

Inspection Date: 12/11/2019

Inspection Number: 2940765

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GANPAT, INDAR

Violation Code ObservationViolation Citation

48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Under power soaker in kitchen and under grill across from kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
---------	--	---

License Number: 1624485

COSTA HOLLYWOOD - ROOFTOP

License Type: Permanent Food Service

777 N OCEAN DR ROOFTOP, HOLLYWOOD 33019

Inspection Date: 12/10/2019

Inspection Number: 2965393

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: CONSIGLIO, CAMILLE

Violation Code ObservationViolation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Broward County

License Number: 1624587 THE COFFEE STORE
 License Type: Permanent Food Service 777 N OCEAN DR UNIT N104, HOLLYWOOD 33019

Inspection Date: 12/10/2019 Inspection Number: 2953161 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: CONSIGLIO, CAMILLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. notified AHJ Hollywood Mr Castano by email. Cooking on grill and hot plates. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1619567 POLLO TROPICAL #51
 License Type: Permanent Food Service 17539 PINES BLVD, PEMBROKE PINES 33029

Inspection Date: 12/13/2019 Inspection Number: 2967327 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. -Observed exit door blocked with garbage container.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 1618223 CYRESS CREEK STATION STADIUM 16
 License Type: Permanent Food Service 6415 N ANDREWS AVE, FORT LAUDERDALE 33309

Inspection Date: 12/10/2019 Inspection Number: 2967346 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621945

FRATERNEL'S TAKE OUT RESTAURANT

License Type: Permanent Food Service

557 W OAKLAND PARK BLVD STE 557, OAKLAND PARK 33311

Inspection Date: 12/13/2019

Inspection Number: 2958133

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MATTIELLO-ATASSI, MARIA

Violation Code ObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed operator cooking out of a burner connected to a 15lb tank. Operator disconnected. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1620631

ULTIMATE CUISINE INC

License Type: Catering

4072 NE 5 TER, OAKLAND PARK 33334

Inspection Date: 12/09/2019

Inspection Number: 1113245

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation Code ObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2103279

PANERA BREAD #982

License Type: Permanent Food Service

6438 NAPLES BLVD, NAPLES 34109

Inspection Date: 12/12/2019

Inspection Number: 2944666

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LUNESKI, DANIEL

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed rear exit door blocked by boxes. Boxes removed. ****Corrected On-Site****

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Columbia County

License Number: 2200678 SUBWAY 52619
 License Type: Permanent Food Service 3586 W US HWY 90, LAKE CITY 32055

Inspection Date: 12/11/2019 Inspection Number: 2905129 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GRODEWALD, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher next to back door. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2200738 CHILI'S
 License Type: Permanent Food Service 2893 WEST US HWY 90, LAKE CITY 32055

Inspection Date: 12/13/2019 Inspection Number: 2937807 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GRODEWALD, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2315390 WENDY'S #1703
 License Type: Permanent Food Service 1532 NE 163 ST, NORTH MIAMI BEACH 33162

Inspection Date: 12/13/2019 Inspection Number: 2938736 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed multiple bun trays blocking the back door, marked exit.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2329257 EPIC EVENTS
 License Type: Catering 4747 NW 79 AVE FLR 2, MIAMI 33166

Inspection Date: 12/10/2019 Inspection Number: 1113847 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TAYLOR, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two 15 lb gallon propane tanks stored under hand washing sink.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335751 EPIC EVENTS
 License Type: Permanent Food Service 4747 NW 79 AVE FLOOR 2, MIAMI 33166

Inspection Date: 12/10/2019 Inspection Number: 2920614 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TAYLOR, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two 15 lb propane tanks stored under hand washing sink.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332157 SUBWAY
 License Type: Permanent Food Service 10728 NW 74 ST, DORAL 33178

Inspection Date: 12/10/2019 Inspection Number: 2894438 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HERNANDEZ, NILYAM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Dade County

License Number: 2330521

QUIZNOS SUB

License Type: Permanent Food Service

9700 NW 115 WAY, MEDLEY 33178

Inspection Date: 12/12/2019

Inspection Number: 2893143

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HERNANDEZ, NILYAM

Violation Code ObservationViolation Citation

45-06-4 Portable fire extinguisher is inaccessible. For reporting purposes only. Observed extinguisher covered by empty boxes.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed empty boxes covering back door.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2325602

SUBWAY

License Type: Permanent Food Service

20521 OLD CUTLER RD, MIAMI 331892454

Inspection Date: 12/13/2019

Inspection Number: 2967619

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HERNANDEZ, NILYAM

Violation Code ObservationViolation Citation

47-03-4 Observed electrical wiring in disrepair. For reporting purposes only. Observed outlet next to soda containers in disrepair.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2613470

BEAVER STREET COMMISSARY 2

License Type: Catering

2362-2356 WEST BEAVER STREET, JACKSONVILLE 32209

Inspection Date: 12/10/2019

Inspection Number: 1115192

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Grey Fire extinguisher in red.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2612573

NEW WORLD GRILL

License Type: Permanent Food Service

13715 LAKE NEWMAN ST, JACKSONVILLE 32221

Inspection Date: 12/10/2019

Inspection Number: 2929944

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code ObservationViolation Citation45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By cook line - From follow-up inspection 2019-12-10:
Good now

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2611916

LARRY'S GIANT SUBS

License Type: Permanent Food Service

5733 ROOSEVELT BLVD, JACKSONVILLE 32244

Inspection Date: 12/12/2019

Inspection Number: 2931791

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code ObservationViolation Citation47-02-4 Observed scorch marks around electrical outlet. For reporting purposes only.
Behind main make line cooler across from front counter.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2607689

ANDREW'S DELI

License Type: Permanent Food Service

7825 BAYMEADOWS WAY STE 109, JACKSONVILLE 32256

Inspection Date: 12/10/2019

Inspection Number: 2926817

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation Code ObservationViolation Citation45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Establishment has table top fryer and few griddles and no hood suppression system **Repeat Violation*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Flagler County

License Number: 2800175

PINE LAKES GOLF CLUB

License Type: Permanent Food Service

400 PINE LAKES PKWY, PALM COAST 32164

Inspection Date: 12/13/2019

Inspection Number: 2946219

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANDERSON, EDWARD

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. 098834 exp date 8/29/19, New inspection performed on 12/10/19 **Corrective Action Taken** **Repeat Violation**

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Hillsborough County

License Number: 3915444 PICCOLLA ITALIA BISTRO
 License Type: Permanent Food Service 2140 W MARTIN LUTHER KING JR BLVD, TAMPA 33607

Inspection Date: 12/13/2019 Inspection Number: 2917846 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BEACHAM, MICHELLE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Fryer not under hood**Repeat Violation** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918192 CHINA 1
 License Type: Permanent Food Service 4350 W WATER AVE STE 103, TAMPA 33614

Inspection Date: 12/12/2019 Inspection Number: 2925535 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: EHLERS, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	- From initial inspection : For reporting purposes only. Licensed at NOST currently has seats. - From follow-up inspection 2019-12-12: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
49-05-4	For reporting purposes only. Licensed at NOST currently has seats.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Indian River County

License Number: 4105383

MISS SAIGON RESTAURANT

License Type: Permanent Food Service

737 22 STREET, VERO BEACH 32960

Inspection Date: 12/09/2019

Inspection Number: 2929480

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Establishment utilizing small fryers in kitchen explained they have to be

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500948

SLIDERS SEASIDE GRILL

License Type: Permanent Food Service

1998 S FLETCHER AVE, FERNANDINA BEACH 32034

Inspection Date: 12/13/2019

Inspection Number: 2936138

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code ObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. By stairs

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5501133

JERSEY MIKE'S SUBS

License Type: Permanent Food Service

1464 SADLER ROAD, FERNANDINA BEACH 32034

Inspection Date: 12/09/2019

Inspection Number: 2933740

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code ObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Rear door blocked with rack, mgr moved rack **Corrected On-Site**

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Orange County

License Number: 5802822 PIZZA HUT
 License Type: Permanent Food Service 883 SEMORAN BLVD, APOPKA 32703

Inspection Date: 12/10/2019 Inspection Number: 2898320 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MONTGOMERY, DOREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. **Corrected On-Site** **Repeat Violation**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5807585 WENDY'S 205
 License Type: Permanent Food Service 155 E MAIN ST, APOPKA 32703

Inspection Date: 12/09/2019 Inspection Number: 2933417 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MONTGOMERY, DOREEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only, side entrance door to facility is locked during operating hours **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5808809 ASIAN EXPRESS LB INC
 License Type: Permanent Food Service 3749 S KIRKMAN RD STE A, ORLANDO 32811

Inspection Date: 12/10/2019 Inspection Number: 2932604 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-06-4	Portable fire extinguisher is inaccessible. For reporting purposes only. Blocked by a rolling cart	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813726 SLATE RESTAURANT
 License Type: Permanent Food Service 8323 WEST SAND LAKE ROAD, SUITE 121, ORLANDO 32819

Inspection Date: 12/10/2019 Inspection Number: 2917246 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MANTI, KATHRYN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911708

RODEWAY INN

License Type: Permanent Food Service

7455 WEST IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34747

Inspection Date: 12/10/2019

Inspection Number: 2954222

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2019-12-10: **Time Extended**

61C-1.004(9) FAC Reporting: (9) Heating and ventilation
- The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6013298

PHOLICIOUS AT WELLINGTON MALL INC

License Type: Permanent Food Service

10300 FOREST HILL BLVD STE K106, WELLINGTON 33414

Inspection Date: 12/13/2019

Inspection Number: 2939066

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MENOR, MICHAEL

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Operator using a fryer without a hood or fire suppression system

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6211727		STACK 'N' SIZZLE	
License Type: Permanent Food Service		401 49 ST S, ST PETERSBURG 33707	
Inspection Date: 12/11/2019	Inspection Number: 2950332	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HOBBS, ANDREW			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank in kitchen by back door **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6216189		EL CARRIEL	
License Type: Permanent Food Service		1215 N MARTIN LUTHER KING, CLEARWATER 33755	
Inspection Date: 12/11/2019	Inspection Number: 2917289	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BENEDICT, TRACY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6216371		MANA MANA FALAFEL	
License Type: Permanent Food Service		530 PARK ST, CLEARWATER 33755	
Inspection Date: 12/12/2019	Inspection Number: 2903505	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BENEDICT, TRACY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6215586		LA POLLERA COLORADA	
License Type: Permanent Food Service		1226 S HIGHLAND AVE, CLEARWATER 33756	
Inspection Date: 12/11/2019	Inspection Number: 2900911	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: AUSTIN, MARK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. - silver fire extinguisher by fryers	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Pinellas County

License Number: 6217261

WOODEN LADLE NOODLE SHOP

License Type: Permanent Food Service

3689 TAMPA RD # 305, OLDSMAR 34677

Inspection Date: 12/13/2019

Inspection Number: 2911959

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
On table next to cooler

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501322

SHAUGHNESSY'S SPORTS GRILL

License Type: Permanent Food Service

4255 US 1 SOUTH, UNIT 11, ST. AUGUSTINE 32086

Inspection Date: 12/10/2019

Inspection Number: 2908353

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANCO, RICHARD

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher next to hand washing sink at the dish area is in the red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6501734

IHOP 36-179

License Type: Permanent Food Service

2560 SR 16, SAINT AUGUSTINE 32092

Inspection Date: 12/10/2019

Inspection Number: 2932031

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
Boxes in front of rear exit. Moved by manager. **Corrected On-Site** **Repeat Violation**

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6501745

BONO'S BAR B Q

License Type: Permanent Food Service

100 BARTRAM OAKS WALK, JACKSONVILLE 32259

Inspection Date: 12/12/2019

Inspection Number: 2937441

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: GOSAI, MATT

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Large 20 pound LP tank in building at frontline. Used to fire pit.
Removed by manager. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7406882

BURGEY'S TIKI BAR

License Type: Permanent Food Service

1010 MAIN ST, DAYTONA BEACH 32118

Inspection Date: 12/09/2019

Inspection Number: 2917873

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

47-02-4

- From initial inspection : Observed scorch marks around electrical outlet. For reporting purposes only. - From follow-up inspection 2019-12-09: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7407172

SUSHI 99 INC

License Type: Permanent Food Service

1665 DUNLAWTON AVE #111, PORT ORANGE 32129

Inspection Date: 12/09/2019

Inspection Number: 2940390

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: LARSON, SARAH

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.