

Alachua County

License Number: 1100159

GAINESVILLE GOLF & COUNTRY CLUB INC

License Type: Permanent Food Service

7300 SW 35 WAY, GAINESVILLE 32608

Inspection Date: 12/27/2019

Inspection Number: 2945590

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
Observed no boiler inspection. **Repeat Violation**

61C-1.004(9) FAC Reporting: (9) Heating and ventilation
- The heating and ventilation system shall be kept in
good repair or be installed to maintain a minimum of 68
degrees Fahrenheit throughout the building. The
insurance inspector's boiler report is required annually
for power boilers and high pressure/high temperature
boilers and biannually for low pressure steam or vapor
heating boilers and shall be posted in the boiler room.
For reporting purposes only.

License Number: 1103413

SOHAO STREET FARE CAFE

License Type: Permanent Food Service

3045 SW 34 ST STE 16, GAINESVILLE 32608

Inspection Date: 12/26/2019

Inspection Number: 2944327

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: CASEY, KEITH

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Observed multiple vacuums blocking the rear exit. The vacuums were moved.
Corrected On-Site

61C-1.004(9) FAC: (9 Reporting: Means of access,
including entrances, halls, and stairways, must permit
unobstructed travel at all times and shall be clean,
ventilated and well-lighted day and night. Hall and stair
runners shall be kept in good condition. Railways, as
defined in 61C-1.001(23), F.A.C., shall be installed on
all stairways and around all porches and steps. For
reporting purposes only.

Broward County

License Number: 1612654

RED LOBSTER #0424

License Type: Permanent Food Service

296 N UNIVERSITY DR, PEMBROKE PINES 33024

Inspection Date: 12/26/2019

Inspection Number: 2909839

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BENJAMIN, ALEXANDER

Violation Code ObservationViolation Citation

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
49-01-4	Flammables stored/debris present in meter room. For reporting purposes only. Bag and shredding bin full of paper in boiler room. Gas can in boiler room. Bags of towels and aprons in boiler room. Manager removed gas can	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 1611718

KFC #11

License Type: Permanent Food Service

990 W COMMERCIAL BLVD, FORT LAUDERDALE 33309

Inspection Date: 12/13/2019

Inspection Number: 2967855

Inspection Type: Complaint Full

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SEWELL, SANGAY

Violation Code ObservationViolation Citation

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.
---------	---	--

Clay County

License Number: 2001188

SOUTHERN SOCIAL WHISKEY BAR AND LOUNGE

License Type: Permanent Food Service

2223 COUNTY ROAD 220 STE 203 - 206, MIDDLEBURG 32068

Inspection Date: 12/27/2019

Inspection Number: 2950871

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Warning Issued

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Gas tanks will be removed per manager.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500984

FOUR SEASONS BISTRO

License Type: Permanent Food Service

474305 STATE RD 200, FERNANDINA BEACH 32034

Inspection Date: 12/23/2019

Inspection Number: 2937724

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code ObservationViolation Citation46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. With wine
cooked61C-1.004(9) FAC: (9 Reporting: Means of access,
including entrances, halls, and stairways, must permit
unobstructed travel at all times and shall be clean,
ventilated and well-lighted day and night. Hall and stair
runners shall be kept in good condition. Railways, as
defined in 61C-1.001(23), F.A.C., shall be installed on
all stairways and around all porches and steps. For
reporting purposes only.

License Number: 5501178

BANTAM AND BIDDY

License Type: Permanent Food Service

4800 FIRST COAST HWY STE 470, FERNANDINA BEACH 32034

Inspection Date: 12/23/2019

Inspection Number: 2968875

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Orange County

License Number: 5810905 ROSE ISLAND SPICE LLC
 License Type: Permanent Food Service 4759 RALEIGH ST, ORLANDO 32811

Inspection Date: 12/27/2019 Inspection Number: 2919442 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GREENE, MARVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Corrected On-Site** **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813781 ITAR BISTRO & MARKET
 License Type: Permanent Food Service 7065 WESTPOINT BLVD STE 100, ORLANDO 32835

Inspection Date: 12/20/2019 Inspection Number: 2907859 Inspection Type: Routine - Food Inspection Disposition: Call Back - Extension given, pending
 Inspector Name: CONNOLLY, MADELINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. The one by Espresso machine, - From follow-up inspection 2019-12-20: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6021852

R1 COFFEE

License Type: Permanent Food Service

17940 S MILITARY TRL UNIT 600, BOCA RATON 33496

Inspection Date: 12/27/2019

Inspection Number: 2921163

Inspection Type: Routine - Food

Inspection Disposition: Admin.

Inspector Name: BANNIGAN, TIM

Complaint Callback Not Complied

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

- flat grill and two induction burners added. - From follow-up inspec

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407507

BUILT CUSTOM BURGERS

License Type: Permanent Food Service

260 DAYTONA BLVD STE 440, DAYTONA BEACH 32114

Inspection Date: 12/20/2019

Inspection Number: 2923558

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Exit path
partial blocked in hallway from kitchen. Trash cans,boxes buckets61C-1.004(9) FAC: (9 Reporting: Means of access,
including entrances, halls, and stairways, must permit
unobstructed travel at all times and shall be clean,
ventilated and well-lighted day and night. Hall and stair
runners shall be kept in good condition. Railways, as
defined in 61C-1.001(23), F.A.C., shall be installed on
all stairways and around all porches and steps. For
reporting purposes only.

License Number: 7406473

RIVERVIEW HOTEL

License Type: Permanent Food Service

103 FLAGLER AVE, NEW SMYRNA BEACH 32169

Inspection Date: 12/26/2019

Inspection Number: 2901519

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Third floor
kitchen **Repeat Violation**61C-1.004(9) FAC: (9 Reporting: Means of access,
including entrances, halls, and stairways, must permit
unobstructed travel at all times and shall be clean,
ventilated and well-lighted day and night. Hall and stair
runners shall be kept in good condition. Railways, as
defined in 61C-1.001(23), F.A.C., shall be installed on
all stairways and around all porches and steps. For
reporting purposes only.