

Alachua County

License Number: 1102843

CARIBBEAN QUEEN

License Type: Permanent Food Service

507 NW 5 AVE, GAINESVILLE 32601

Inspection Date: 01/08/2020

Inspection Number: 2952893

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: WEATHERS, TIM

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 1 tank in back room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1505190 BAGEL 13
 License Type: Permanent Food Service 1301 S BABCOCK ST, MELBOURNE 32901

Inspection Date: 01/10/2020 Inspection Number: 2940250 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: MITTEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Shopping cart blocking back door	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 1506382 DAO JAPANESE SUSHI BUFFET
 License Type: Permanent Food Service 1153 MALABAR RD, PALM BAY 32907

Inspection Date: 01/09/2020 Inspection Number: 2970768 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: WOODS, CHRISTAL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door - From follow-up inspection 2020-01-09: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1550649 SANDRA'S LATIN KITCHEN
 License Type: Mobile Food Dispensing Vehicle 660 TUCKER LN, COCOA 32926

Inspection Date: 07/19/2019 Inspection Number: 1221127 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: FRANZ, LINDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	Observed: Flammables stored near a source of ignition. For reporting purposes only. Plus tanks stored inside unit, 5 tanks Priority: Reporting	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1506313

MOM & POPS BAR AND GRILL

License Type: Permanent Food Service

900 N ATLANTIC AVE STE D, COCOA BEACH 32931

Inspection Date: 01/07/2020

Inspection Number: 2960251

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Extension given, pending

Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2020-01-07: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2020-01-07: **Time Extended**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Broward County

License Number: 1622295

GIORGIOS BAKERY & BISTRO

License Type: Permanent Food Service

800 N OCEAN DR, HOLLYWOOD 33019

Inspection Date: 01/08/2020

Inspection Number: 2970595

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: CHAPDELAIN, MARIE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Gas Pressure cleaner inside building	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Gas Pressure cleaner inside building - From follow-up inspection 2020-01-09: Still in build	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Citrus County

License Number: 1900890

MANGO TANGOS TROPICAL GRILL

License Type: Permanent Food Service

10350 W YULEE DR, HOMOSASSA 34448

Inspection Date: 01/08/2020

Inspection Number: 2925045

Inspection Type: Routine - Food

Inspection Disposition: Emergency
Order Callback Time Extension

Inspector Name: MEAKINS, ALLISON

Violation Code Observation

Violation Citation

45-04-4 - From initial inspection : Hood not pulling smoke inside of system, hood making loud noise. Excessive smoke on cooks line. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2020-01-08: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-04-4 Hood not pulling smoke inside of system, hood making loud noise. Excessive smoke on cooks line. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2322128 REDLAND ICE CREAM & BAKERY
 License Type: Permanent Food Service 24810 SW 177 AVE, HOMESTEAD 33031

Inspection Date: 01/08/2020 Inspection Number: 2935125 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ALEJANDRO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328005 KRAZY CHICKEN PLUS LLC
 License Type: Permanent Food Service 15030 NE 6 AVE, MIAMI 33161

Inspection Date: 01/06/2020 Inspection Number: 2938678 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: TAYLOR, JOHN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Located in kitchen area. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2328296 JR'S GOURMET BURGERS
 License Type: Permanent Food Service 7 WESTWARD DRIVE, MIAMI SPRINGS 33166

Inspection Date: 01/09/2020 Inspection Number: 2939851 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: HODGE, KRISTEN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed cases labeled tuba blonde ale beverages stored in hallway area towards back exit door.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2332126 COURTYARD BY MARRIOTT MIAMI DOLPHIN MALL
 License Type: Permanent Food Service 11275 NW 12TH STREET, MIAMI 33172

Inspection Date: 01/10/2020 Inspection Number: 2948603 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: GONZALEZ, ERIK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-04-4	Flammables stored/debris present in laundry room. For reporting purposes only. Observed excessive lint behind washers and dryers. **Repeat Violation**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Dade County

License Number: 2332219

PANDA EXPRESS 1752

License Type: Permanent Food Service

8750 W FLAGLER ST, MIAMI 33174

Inspection Date: 01/10/2020

Inspection Number: 2951224

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed extinguisher by hand wash sink in front of walk in cooler in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2612199

GOLDEN CORRAL #632 MERRILL ROAD

License Type: Permanent Food Service

9070 MERRILL RD, JACKSONVILLE 32225

Inspection Date: 01/06/2020

Inspection Number: 2970394

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THOMAS, PHILIP

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificate expired 11/18/19. Manager called for inspection to be made. ****Corrective Action Taken****

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Highlands County

License Number: 3801044

DENNY'S

License Type: Permanent Food Service

4390 US 27 N, SEBRING 33870

Inspection Date: 01/08/2020

Inspection Number: 2970789

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHNELL, PAMELA

Violation Code

Observation

Violation Citation

46-04-4

Exit door locked. For reporting purposes only. Front double entry door, one of double entry doors locked in place due to door in need of repair. One of the doors still in working condition.

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Hillsborough County

License Number: 3918244

ANDREW PANDREW'S JERK HUT A JAMAICAN DRIVE UP EATERY

License Type: Permanent Food Service

1045 E HILLSBOROUGH AVE, TAMPA 33603

Inspection Date: 01/06/2020

Inspection Number: 2925673

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: MARQUETTI, JESSICA

Violation CodeObservationViolation Citation

49-05-4

Establishment currently licensed as a non seating has 20 seats outside . For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3915970

YARD OF ALE

License Type: Permanent Food Service

406 S HOWARD, TAMPA 33606

Inspection Date: 01/09/2020

Inspection Number: 2896020

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: COLEMAN, TONYA

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryers

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4603176

SOUTH CAPE DINER

License Type: Permanent Food Service

1215 CAPE CORAL PKWY E, CAPE CORAL 33904

Inspection Date: 01/08/2020

Inspection Number: 2944901

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: SOMMERS, KARA

Violation Code ObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4606006

EL TARASCO MEXICAN RESTAURANT

License Type: Permanent Food Service

728 PINE ISLAND RD SW STE 8-9, CAPE CORAL 33991

Inspection Date: 01/09/2020

Inspection Number: 2946588

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: EHMER, ANNETTE

Violation Code ObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5201967

HOWARD JOHNSON

License Type: Permanent Food Service

3951 NW BLITCHTON RD, OCALA 344824065

Inspection Date: 01/06/2020

Inspection Number: 2957616

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: WEATHERS, TIM

Violation Code

Observation

Violation Citation

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.
B00057794 131959, 131958 expired 4/12/2018 - From follow-up inspection
2020-01-06: Manager stated invoic

61C-1.004(9) FAC Reporting: (9) Heating and ventilation
- The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Martin County

License Number: 5301047

LA MEXICANA RESTAURANTE

License Type: Permanent Food Service

15535 SW WARFIELD BLVD, INDIANTOWN 34956

Inspection Date: 01/09/2020

Inspection Number: 2958135

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Nassau County

License Number: 5500801

CONNIES PIZZA & BBQ

License Type: Permanent Food Service

15899 CR 108, HILLIARD 32046

Inspection Date: 01/06/2020

Inspection Number: 2887268

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ESPINOSA-BECKERT, ILIANA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By ice machine

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5810392 TIJUANA FLATS BURRITO CO
 License Type: Permanent Food Service 2320 S KIRKMAN RD, ORLANDO 32811

Inspection Date: 01/08/2020 Inspection Number: 2937469 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONNOLLY, MADELINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Back door blocked with garbage cans and empty boxes	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5814293 KAREN'S TASTY CRABS
 License Type: Permanent Food Service 4898 S KIRKMAN RD, ORLANDO 32811

Inspection Date: 01/07/2020 Inspection Number: 2924433 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONNOLLY, MADELINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-01-4	Observed frayed/spliced electrical wires. For reporting purposes only. Outside Walk in freezer door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811406 CICI'S PIZZA 580
 License Type: Permanent Food Service 7437 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 01/08/2020 Inspection Number: 2903212 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, COLIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Back door in dining area secured with bar that locks door making it unable to push open. Advised operator to remove when there area customers in restaurant **Corrective Action Taken**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5811409 PAO GOSTOSO BAKERY
 License Type: Permanent Food Service 5472 INTERNATIONAL DRIVE, ORLANDO 32819

Inspection Date: 01/09/2020 Inspection Number: 2935366 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONNOLLY, MADELINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Located across from mop sink	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811591 MCDONALDS #4116
 License Type: Permanent Food Service 10701 NARCOOSSEE RD, ORLANDO 32827

Inspection Date: 01/08/2020 Inspection Number: 2894594 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked With Trashcan.. For reporting purposes only. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5804891 LAKE NONA DINING ROOM
 License Type: Permanent Food Service 9100 CHILTERN DR, ORLANDO 328277029

Inspection Date: 01/08/2020 Inspection Number: 2944480 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certification was expired 10-24-19.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5804892 GRILL ROOM (THE)
 License Type: Permanent Food Service 9100 CHILTERN DR, ORLANDO 328277029

Inspection Date: 01/08/2020 Inspection Number: 2944467 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Expired 10-24-19	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5811536 CHAAT HOUSE
 License Type: Permanent Food Service 9472 S ORANGE BLOSSOM TR, ORLANDO 32837

Inspection Date: 01/08/2020 Inspection Number: 2970786 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: GUTTERMAN, KENNETH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-01-4	Flammables stored/debris present. For reporting purposes only. Observed gas tank on top shelf inside kitchen p, **Corrected On-Site**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Palm Beach County

License Number: 6012447

STEVE'S WOOD FIRED PIZZA

License Type: Permanent Food Service

9180 GLADES RD, BOCA RATON 33434

Inspection Date: 01/09/2020

Inspection Number: 2935911

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BANNIGAN, TIM

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6012660

BEAUVAIS CARIBBEAN RESTAURANT

License Type: Permanent Food Service

6150 S CONGRESS AVE, LANTANA 33462

Inspection Date: 01/08/2020

Inspection Number: 2930523

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguisher on floor

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6113611

THE GAMERS' GUILD CAFÉ

License Type: Permanent Food Service

7135 STATE RD 52 STE 306, HUDSON 34667

Inspection Date: 01/10/2020

Inspection Number: 2946311

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TORRACO, MARIANNE

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Flat top used to cook eggs, bacon, sausage patties, Philly cheesesteak beef, chicken breast, gyros,

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6113435

TASTE OF CURRY

License Type: Permanent Food Service

10136 US HWY 19, PORT RICHEY 34668

Inspection Date: 01/09/2020

Inspection Number: 2936300

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TORRACO, MARIANNE

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Back door: bikes, propane tank, ladder, tools, folded table, vacuum cleaner, paint supplies, etc

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Pinellas County

License Number: 6213699 METRO DELI
 License Type: Permanent Food Service 28100 US 19 N STE 103, CLEARWATER 33761

Inspection Date: 01/09/2020 Inspection Number: 2953069 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PEARCE, LAURA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Electric flat top grill added - observed eggs cooked and bacon reheated on grill - used to cook hamburgers also . Notified Fire AHJ. For reporting	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6210391 RED LOBSTER #0454
 License Type: Permanent Food Service 10500 E ULMERTON RD #490, LARGO 33771

Inspection Date: 01/06/2020 Inspection Number: 2908333 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LANTIGUA, ROBERTO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Repeat Violation**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Polk County

License Number: 6307955

GOLDEN DRAGON CHINESE RESTAURANT

License Type: Permanent Food Service

39871 US HIGHWAY 27, HAINES CITY 33844

Inspection Date: 01/09/2020

Inspection Number: 2970431

Inspection Type: Complaint Full

Inspection Disposition: Call Back -
Complied

Inspector Name: JACKSON, SHARON

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Single basket fryer next to the rice cooker. - From follow-up inspecti	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Single basket fryer next to the rice cooker.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Putnam County

License Number: 6400879

THIS & THAT CAFE

License Type: Permanent Food Service

700 ST JOHNS AVE, PALATKA 32177

Inspection Date: 01/08/2020

Inspection Number: 2916237

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small flattop grill on counter next to oven. Used to cook eggs, and heat bacon and sausage. **Repeat V

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6501473 TACO BELL- 26464
 License Type: Permanent Food Service 2453 SR 16, SAINT AUGUSTINE 32092

Inspection Date: 01/09/2020 Inspection Number: 2954174 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by boxes. Recent delivery. Moved by manager. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6502027 PIZZA HUT #4285
 License Type: Permanent Food Service 52 TUSCAN WAY STE-208, SAINT AUGUSTINE 32092

Inspection Date: 01/09/2020 Inspection Number: 2902520 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rea exit door blocked by chores. Moved by manager. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6501826 BRUCCI'S PIZZA HOUSE
 License Type: Permanent Food Service 540 SR 13 STE #10, FRUIT COVE 32259

Inspection Date: 01/10/2020 Inspection Number: 2954699 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: GOSAI, MATT

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by equipment. Moved by manager. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Volusia County

License Number: 7407351

CHEDDAR'S CASUAL CAFE

License Type: Permanent Food Service

1770 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 01/08/2020

Inspection Number: 2920315

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

49-03-4

Flammables stored/containers of paper work stored in water heater room. For reporting purposes only.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 7406892

WILD HOG CAFE

License Type: Permanent Food Service

1637 N US HIGHWAY 1, ORMOND BEACH 32174

Inspection Date: 01/07/2020

Inspection Number: 2943551

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.