

Alachua County

License Number: 1102843

CARIBBEAN QUEEN

License Type: Permanent Food Service

507 NW 5 AVE, GAINESVILLE 32601

Inspection Date: 01/14/2020

Inspection Number: 2952893

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: WEATHERS, TIM

Violation Code

Observation

Violation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 1 tank in back room. - From follow-up inspection 2020-01-14: Propane tank outside.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1504760

RED LOBSTER #6205

License Type: Permanent Food Service

2355 W NEW HAVEN AVE, MELBOURNE 32904

Inspection Date: 01/17/2020

Inspection Number: 2932040

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MITTEN, JAMES

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. **Corrected On-Site**

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 1506767

DUNKIN DONUTS

License Type: Permanent Food Service

4200 WEST KING ST, COCOA 32926

Inspection Date: 01/17/2020

Inspection Number: 2913839

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By rear door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1623290

CHIPOTLE MEXICAN GRILL

License Type: Permanent Food Service

6320 N ANDREWS AVE, FORT LAUDERDALE 33334

Inspection Date: 01/17/2020

Inspection Number: 2935706

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
-Observed rear exit door blocked with boxes.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 1619368

EL COLOMBIANO

License Type: Permanent Food Service

3457 N HIATUS RD, SUNRISE 33351

Inspection Date: 01/17/2020

Inspection Number: 2971361

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: REED, SHANE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Hallway leading to restrooms with furniture.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Collier County

License Number: 2103107

TRATTORIA ABRUZZO

License Type: Permanent Food Service

2359 VANDERBILT BEACH RD #416, NAPLES 34109

Inspection Date: 01/17/2020

Inspection Number: 2928835

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PFENNING, BRUNO

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside Office area of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2334707 SUBWAY
 License Type: Permanent Food Service 4200 NW 21 ST, CONC H-4, MIAMI 33122

Inspection Date: 01/17/2020 Inspection Number: 2912436 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: SANCHEZ, JAVIER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317962 IMPRESSIONS/RIOJA GRILLE
 License Type: Permanent Food Service 711 NW 72 AVE, MIAMI 33126

Inspection Date: 01/17/2020 Inspection Number: 2937455 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MARTINEZ, YANET

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Observed 4 boiler certification expired. FL# 123277 expired 5/22/19; FL 121771 expired 5/22/19; FL# 123142 expired 5/22/19; FL#123171 expired 5/22/19	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2329574 CHEF ARYEH LLC
 License Type: Catering 1850 NE 164 ST (2ND FLOOR), NORTH MIAMI BEACH 33162

Inspection Date: 01/17/2020 Inspection Number: 1113939 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: STUBBS, CHRISTINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. - From follow-up inspection 2020-01-17: At time of call back inspection propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2325612

JARDINES DE CONFUCIO

License Type: Permanent Food Service

10658 NW 7 STREET, MIAMI 33172

Inspection Date: 01/16/2020

Inspection Number: 2947724

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed extinguisher in recharge zone by coffee station.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334287

CHICK-FIL-A FSU #03238

License Type: Permanent Food Service

9301 WEST FLAGLER STREET, MIAMI 33174

Inspection Date: 01/17/2020

Inspection Number: 2949600

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation Code ObservationViolation Citation45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed extinguisher in recharge zone in dry storage.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615372

SMKNQ

License Type: Permanent Food Service

7111 BONNEVAL RD UNIT 8, JACKSONVILLE 32256

Inspection Date: 01/15/2020

Inspection Number: 2930474

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Flat top grill on kitchen line used to cook food not under a hood suppression system.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Flat top grill on kitchen line used to cook food not under a hood suppression system. - From follow-up inspection 2020-01-16: Flat top grill on kitchen line used to cook food not under a hood suppression system. Still the same. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917092

BAHAMA BREEZE #3054

License Type: Permanent Food Service

805 BRANDON TOWN CENTER DR, BRANDON 33511

Inspection Date: 01/16/2020

Inspection Number: 2952189

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCCLOUD, BREANNA

Violation Code ObservationViolation Citation

45-05-4 Portable fire extinguisher missing from its designated location. For reporting purposes only. On floor in front of back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

47-01-4 Sliced electrical cord across Employee handsink. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3917864

HOTEL BAR

License Type: Permanent Food Service

200 NORTH TAMPA STREET SUITE G-100, TAMPA 33602

Inspection Date: 01/16/2020

Inspection Number: 2918010

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: COLEMAN, TONYA

Violation Code ObservationViolation Citation45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Repeat Violation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3903008

GIRL AND A GRILL LLC

License Type: Permanent Food Service

4330 N NEBRASKA AVE, TAMPA 33603

Inspection Date: 01/17/2020

Inspection Number: 2971649

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Warning Issued

Inspector Name: MARQUETTI, JESSICA

Violation Code ObservationViolation Citation

45-06-4 Applied as a non seating and currently has two picnic tables outside and 4 bar stools inside. Operator plans on adding more seats. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3906785

ITALIAN DREAM GROUP INC

License Type: Permanent Food Service

4300 W CYPRESS ST, TAMPA 33607

Inspection Date: 01/17/2020

Inspection Number: 2912653

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: FEDERORVITCH, CASEY

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Flat top grill, deep fryers. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3905412

THE CONCOURSE CAFE

License Type: Permanent Food Service

3505 E FRONTAGE RD STE 138, TAMPA 33607-1748

Inspection Date: 01/15/2020

Inspection Number: 2905161

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: FEDERORVITCH, CASEY

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Press used for sandwiches, butter used. Notified Fire AHJ. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4701775 SHUCKERS OYSTER BAR & SEAFOOD
 License Type: Permanent Food Service 4806 JACKSON COVE RD, TALLAHASSEE 32303

Inspection Date: 01/16/2020 Inspection Number: 2890254 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SMITH, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4750476 RYRY'S KITCHEN
 License Type: Mobile Food Dispensing Vehicle 513 W GAINES ST, TALLAHASSEE 32399

Inspection Date: 01/16/2020 Inspection Number: 1222071 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: SMITH, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Battery connections for water pump not protected.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811110

TAKUMI

License Type: Permanent Food Service

8933 W COLONIAL DR, OCOEE 34761

Inspection Date: 01/06/2020

Inspection Number: 2943091

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: GREENE, MARVIN

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. K extinguisher by back kitchen exit door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911447

REGAL OAKS BAR & GRILL

License Type: Permanent Food Service

5780 GOLDEN HAWK WAY, KISSIMMEE 34746

Inspection Date: 01/17/2020

Inspection Number: 2920847

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BELTRAN, SANDRA

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only, underneath the hand wash sink located on the ice tea station.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911553

WORLD FOOD TRUCK COMMISSARY

License Type: Permanent Food Service

5811 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 01/15/2020

Inspection Number: 2918583

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BELTRAN, SANDRA

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building in storage 180-183. In storage 98. For reporting purposes only. Also a mini gas motorcycle located in storage number 120.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6012601 TRUE FOOD KITCHEN
 License Type: Permanent Food Service 6000 GLADES RD #1015A, BOCA RATON 33431

Inspection Date: 01/17/2020 Inspection Number: 2918689 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BANNIGAN, TIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. - multiple tanks in rear kitchen. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6021164 UNCLE EDDIE'S RISTORANTE
 License Type: Permanent Food Service 4050 US 1 #307, JUPITER 33477

Inspection Date: 01/15/2020 Inspection Number: 2907423 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: ROTONDI, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only.electrical switch /cover plate missing/walk in freezer	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6019999 OFFICE DEPOT CORPORATION - OFFICE DEPOT CAFE
 License Type: Permanent Food Service 6600 MILITARY TRL, BOCA RATON 33496

Inspection Date: 01/17/2020 Inspection Number: 2894395 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: STEUBER, RYAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6020567 OSPREY POINT GOLF COURSE
 License Type: Permanent Food Service 12551 GLADES RD, BOCA RATON 33498

Inspection Date: 01/17/2020 Inspection Number: 2899734 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BANNIGAN, TIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - "Chef Built" deep fryer sitting atop prep table in rear kitchen. Plugged in and soiled with grease..	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6207020 EXECUTIVE DELI & CAFE
 License Type: Permanent Food Service 25400 US 19 N #205, CLEARWATER 33763

Inspection Date: 01/14/2020 Inspection Number: 2936096 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PEARCE, LAURA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Frying burgers on stove . Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6211703 GINO'S NEW YORK PIZZERIA
 License Type: Permanent Food Service 3394 TAMPA RD, PALM HARBOR 34684

Inspection Date: 01/17/2020 Inspection Number: 2934970 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PEARCE, LAURA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By women's restroom **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6212300 BRENDA'S ON THE CAUSEWAY
 License Type: Permanent Food Service 314 CAUSEWAY BLVD, DUNEDIN 346981705

Inspection Date: 01/15/2020 Inspection Number: 2950451 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PIATT, PAUL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Mop bucket, moved **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Sarasota County

License Number: 6801728

PHILLIPPI CREEK VILLAG OYS BAR

License Type: Permanent Food Service

5353 S TAMIAMI TRL, SARASOTA 342314200

Inspection Date: 01/15/2020

Inspection Number: 2885080

Inspection Type: Routine - Food

Inspection Disposition: Emergency
Order Callback Complied

Inspector Name: SARCOMO, TONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-01-4	- From initial inspection : No portable fire extinguisher present. For reporting purposes only, prep room. Operator moved to designated area. - From follow-up inspection 2020-01-15: No portable fire extinguisher present. For reporting purposes only, prep room. Operator moved to designated area. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-01-4	No portable fire extinguisher present. For reporting purposes only, prep room. Operator moved to designated area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6905296

MR MARGARITA MEXICAN KITCHEN & TEQUILA BAR

License Type: Permanent Food Service

995 N STATE RD 434 STE 303, ALTAMONTE SPRINGS 32714

Inspection Date: 01/15/2020

Inspection Number: 2932381

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MARTIN, LESLIE

Violation Code ObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
-2 tanks in storage room. Operator moved outside. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6904952

TANDOORI BOWL

License Type: Permanent Food Service

3100 ALAFAYA TRL STE 1006, OVIEDO 32765

Inspection Date: 01/17/2020

Inspection Number: 2944640

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code ObservationViolation Citation

49-01-4

Flammables stored in the kitchen . For reporting purposes only. Operator has a gas generator and can of gas present in the back kitchen

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Volusia County

License Number: 7407473

PF CHANG'S CHINA BISTRO

License Type: Permanent Food Service

1862 VICTORY CIR STE L100, DAYTONA BEACH 32114

Inspection Date: 01/15/2020

Inspection Number: 2922947

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Manager states empty

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7406849

TACO BELL

License Type: Permanent Food Service

1860 STATE RD 44, NEW SMYRNA BEACH 32168

Inspection Date: 01/14/2020

Inspection Number: 2963003

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LARSON, SARAH

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked by boxes. For reporting purposes only.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.