

Brevard County

License Number: 1500942

ECONO LODGE

License Type: Permanent Food Service

260 E MERRITT ISLAND CSWY, MERRITT ISLAND 32952

Inspection Date: 01/21/2020

Inspection Number: 2959037

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HICKS, GEORGE RANDY

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane exchange tank in kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1617608 SAN ANGEL RESTAURANT BAR
 License Type: Permanent Food Service 8300 PINES BLVD, PEMBROKE PINES 33024

Inspection Date: 01/23/2020 Inspection Number: 2929158 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BENJAMIN, ALEXANDER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1618226 LA CARRETA REST
 License Type: Permanent Food Service 301 N UNIVERSITY DR, PEMBROKE PINES 33024

Inspection Date: 01/24/2020 Inspection Number: 2946821 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BENJAMIN, ALEXANDER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1620842 MOE'S SOUTHWEST GRILL #42
 License Type: Permanent Food Service 2400 W COMMERCIAL BLVD, TAMARAC 33309

Inspection Date: 01/22/2020 Inspection Number: 2933218 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GRAY, ANTHONY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Collier County

License Number: 2102446

NEW YORK PIZZA & PASTA

License Type: Permanent Food Service

11140 TAMIAMI TRL N, NAPLES 34110

Inspection Date: 01/24/2020

Inspection Number: 2954842

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PFENNING, BRUNO

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. Operator placed extinguisher in proper storage. For reporting purposes only. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2334512

ARAMARK AT BANKUNITED

License Type: Permanent Food Service

7815 NW 148 ST, MIAMI LAKES 33016

Inspection Date: 01/23/2020

Inspection Number: 2945239

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CRUZ, EDGAR

Violation Code

Observation

Violation Citation

49-03-4

Flammables stored/debris present in water heater room. For reporting purposes only.
 Observed corner room with 5 gas water heaters used as a area to store boxes of single service items, located at main kitchen area.
 Priority: Reporting ****Repeat Violation****

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Duval County

License Number: 2608119

BONO'S PIT BAR B Q

License Type: Permanent Food Service

5903 NORWOOD AVE, JACKSONVILLE 322084345

Inspection Date: 01/21/2020

Inspection Number: 2932888

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: YOUNG, JENNIFER

Violation Code ObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
5 lb propane tank located across from barbecue pit **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615145

WINGSTOP

License Type: Permanent Food Service

5324-10 BLANDING BLVD, JACKSONVILLE 32210

Inspection Date: 01/23/2020

Inspection Number: 2972361

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Extinguisher by front counter.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3912834

TRULY MEDITERRANEAN GRILL

License Type: Permanent Food Service

887 E BLOOMINGDALE AVE, BRANDON 33511

Inspection Date: 01/21/2020

Inspection Number: 2946009

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CANNELLA, MARK

Violation Code ObservationViolation Citation

45-05-4 Portable fire extinguisher missing from its designated location. For reporting purposes only. K class fire extinguisher stored on floor in kitchen area .

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906785

ITALIAN DREAM GROUP INC

License Type: Permanent Food Service

4300 W CYPRESS ST, TAMPA 33607

Inspection Date: 01/23/2020

Inspection Number: 2912653

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Admin. complaint recommended

Inspector Name: FEDERORVITCH, CASEY

Violation Code ObservationViolation Citation

45-04-4 - From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Flat top grill, deep fryers. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2020-01-23: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3912268

THINH AN KITCHEN & TOFU

License Type: Permanent Food Service

8104 W WATERS AVE, TAMPA 33615

Inspection Date: 01/23/2020

Inspection Number: 2933795

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BEACHAM, MICHELLE

Violation Code ObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Lee County

License Number: 4602339

JAN BO CHINESE RESTAURANT

License Type: Permanent Food Service

25 HOMESTEAD RD N #1, LEHIGH ACRES 33936

Inspection Date: 01/21/2020

Inspection Number: 2952409

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: JOHNSON, JONATHAN

Violation Code ObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4603809

LAZY FLAMINGO

License Type: Permanent Food Service

1036 PERIWINKLE WAY, SANIBEL 339576915

Inspection Date: 01/22/2020

Inspection Number: 2935309

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: WICK, JENNIFER

Violation Code ObservationViolation Citation

49-01-4

Flammables stored/debris present in dry storage room. For reporting purposes only. Manager moved gas can out of area. **Corrected On-Site**

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Manatee County

License Number: 5105382

CONNECTION CAFE

License Type: Permanent Food Service

1207 3RD AVE W, BRADENTON 34205

Inspection Date: 01/21/2020

Inspection Number: 2918649

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: GALICIA, ARIEL

Violation CodeObservationViolation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

Mini fryer on prep table - From follow-up inspection 2020-01-21: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5101916

GULF DRIVE CAFE

License Type: Permanent Food Service

900 N GULF DRIVE, BRADENTON BEACH 34217

Inspection Date: 01/22/2020

Inspection Number: 2972118

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: RICHENDOLLAR, SANDRA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone, at hood, cook line. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301453

TWO BROTHERS PIZZA LLC

License Type: Permanent Food Service

8423 SE CHURCH ST, HOBE SOUND 33455

Inspection Date: 01/23/2020

Inspection Number: 2944379

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. small deep fryer/small flat top grill/kitchen **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301823

CUBAN CAFE

License Type: Permanent Food Service

9407 SE FEDERAL HWY, HOBE SOUND 33455

Inspection Date: 01/24/2020

Inspection Number: 2941165

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. flat grill/frontline. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5300518

SUBWAY 115

License Type: Permanent Food Service

839 S FEDERAL HWY, STUART 34994

Inspection Date: 01/23/2020

Inspection Number: 2972398

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code ObservationViolation Citation

45-01-4 No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6019420

MOE'S SOUTHWEST GRILL #41

License Type: Permanent Food Service

2200 W GLADES RD #1200B, BOCA RATON 33431

Inspection Date: 01/21/2020

Inspection Number: 2949205

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BANNIGAN, TIM

Violation Code

Observation

Violation Citation

45-05-4 Portable fire extinguisher missing from its designated location. For reporting purposes only.
 - "Class K" portable extinguisher on floor on cook line.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6102186

ICON GENTLEMAN'S CLUB

License Type: Permanent Food Service

18722-28 US HWY 19, HUDSON 346676693

Inspection Date: 01/21/2020

Inspection Number: 2971415

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: TORRACO, MARIANNE

Violation Code

Observation

Violation Citation

49-04-4

Flammables stored/debris present in laundry room. For reporting purposes only. Establishment operating with changed menu and/or increased seating without septic system approval for such change. Establishment did not report seating change that affects the license fee, Clean Indoor Air Act, sewage system approval or other related requirements. 90 seats present, septic system present. Manager states that they are installing a new septic system. Seating increase form emailed.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Pinellas County

License Number: 6217940

ALOHA TO GO HALE

License Type: Permanent Food Service

5903 SEMINOLE BLVD, SEMINOLE 33772

Inspection Date: 01/24/2020

Inspection Number: 2944715

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Located on floor behind cashier. Removed .

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6308487

TACO BELL # 185

License Type: Permanent Food Service

2045 W MEMORIAL BLVD, LAKELAND 33815

Inspection Date: 01/22/2020

Inspection Number: 2943394

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, GUADALUPE

Violation Code Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed at front counter.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6805684 THE WAVERLY
 License Type: Permanent Food Service 2095 N BEACH RD, ENGLEWOOD 34223

Inspection Date: 01/23/2020 Inspection Number: 2948323 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: FERRY, WILLIAM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Corrected on site	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6804923 MOES SOUTHWEST GRILL
 License Type: Permanent Food Service 4005 CLARK RD, SARASOTA 34233

Inspection Date: 01/21/2020 Inspection Number: 2892141 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: RICHENDOLLAR, SANDRA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher entrance to kitchen	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Extinguisher entrance to kitchen - From follow-up inspection 2020-01-22: Operator contacted abc fire equipment to bring it up to code. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6502180

THE LOOP PIZZA GRILL

License Type: Permanent Food Service

101 MARKETSIDE AVENUE, SUITE 401, PONTE VEDRA 32081

Inspection Date: 01/21/2020

Inspection Number: 2949151

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GOSAI, MATT

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only.
Rear exit blocked by boxes. Cleared by manager. **Corrected On-Site**

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Volusia County

License Number: 7400083

MCDONALDS

License Type: Permanent Food Service

151 RIDGEWOOD AVE., HOLLY HILL 32117

Inspection Date: 01/22/2020

Inspection Number: 2890823

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: RUTLEDGE, REBECCA

Violation Code

Observation

Violation Citation

49-01-4

Gas can stored inside building by back door. **Corrected On-Site**

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.