

**Alachua County**

License Number: 1103361

DUNKIN DONUTS

License Type: Permanent Food Service

16091 NW US 441, ALACHUA 32615

Inspection Date: 01/27/2020

Inspection Number: 2914156

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name:

Violation Code    ObservationViolation Citation

46-01-4      - From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only.  
Rear exit door is blocked with a prep table.    - From follow-up inspection  
2020-01-27: No change \*\*Admin Complaint\*\*

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 1102617

HOOK FISH &amp; CHICKEN

License Type: Permanent Food Service

1340 E UNIVERSITY AVE, GAINESVILLE 32641

Inspection Date: 01/27/2020

Inspection Number: 2952586

Inspection Type: Routine - Food

Inspection Disposition: Administrative  
complaint recommended

Inspector Name:

Violation Code    ObservationViolation Citation

46-04-4      Unapproved lock. Walk-in freezer and walk-in cooler doors both have dead bolt slide locks.  
For reporting purposes only.

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Brevard County**

License Number: 1503921

PIZZA HUT

License Type: Permanent Food Service

2690 S HOPKINS AVE, TITUSVILLE 32780

Inspection Date: 01/30/2020

Inspection Number: 2941304

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name:

Violation Code    ObservationViolation Citation46-01-4    Marked exit/path to marked exit blocked. For reporting purposes only. Blocked  
with trash \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 1506195

DR. JAVA GOURMET CAFE

License Type: Permanent Food Service

2222 S HARBOUR CITY BLVD 6TH FLOOR, MELBOURNE 32901

Inspection Date: 01/27/2020

Inspection Number: 2945835

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name:

Violation Code    ObservationViolation Citation45-04-4    Use of cooking equipment producing grease laden vapors/smoke with no hood  
suppression system installed. Notified Fire AHJ. For reporting purposes only.-  
using small fryer

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1623884	LONE PALM AND SOUTH POOL		
License Type: Permanent Food Service	1111 NORTH OCEAN DR, HOLLYWOOD 33019		
Inspection Date: 01/28/2020	Inspection Number: 2946718	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Coke fountain, with exposed wires, cover missing.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1619467	MCDONALDS #4400		
License Type: Permanent Food Service	6204 MIRAMAR PKWY, MIRAMAR 33023		
Inspection Date: 01/27/2020	Inspection Number: 2882979	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked by garbage container and empty card board boxes. For reporting purposes only. Operator cleared pathway **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

License Number: 1623703	THE MUGHAL		
License Type: Permanent Food Service	2100 N UNIVERSITY DR, PEMBROKE PINES 33024		
Inspection Date: 01/31/2020	Inspection Number: 2949000	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1624900	IT! ITALY		
License Type: Permanent Food Service	500 E LAS OLAS BLVD SUITE 200, FORT LAUDERDALE 33301		
Inspection Date: 01/31/2020	Inspection Number: 2960906	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name:			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 9 - 15 gallon propane tanks stored on inside staircase. Inspector will email Inspection report to Fire Marshall Jeff Lucas. **Corrective Action Taken**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Broward County**

License Number: 1620104

CHEZ MAMA TAKE OUT RESTAURANT

License Type: Permanent Food Service

1026 NW 9 AVE, FORT LAUDERDALE 33311

Inspection Date: 01/31/2020

Inspection Number: 2955303

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code    Observation

Violation Citation

45-02-4    Portable fire extinguisher gauge in red zone. For reporting purposes only. At fire extinguisher in kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Clay County**

License Number: 2001376

WINGSTOP

License Type: Permanent Food Service

410 BLANDING BLVD UNIT 15, ORANGE PARK 32073

Inspection Date: 01/27/2020

Inspection Number: 2972574

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
Back door of kitchen blocked by garbage can and boxes

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Dade County**

License Number: 2324070  
 License Type: Permanent Food Service

BRU'S ROOM/EDGEWATER,GRILLE/MERCADO TACO  
 2269 DAN MARINO BLVD, STAND # C214, MIAMI 33056

Inspection Date: 01/31/2020      Inspection Number: 2889085      Inspection Type: Routine - Food      Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

Violation Code    ObservationViolation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only.  
 Observed extinguisher by shelf on main entrance in overcharged zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2332592  
 License Type: Permanent Food Service

OVATIONS FOOD SERVICES - ARSHT CENTER/BRAVA  
 1300 BISCAYNE BLVD, MIAMI 33132

Inspection Date: 01/29/2020      Inspection Number: 2969424      Inspection Type: Routine - Food      Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

Violation Code    ObservationViolation Citation

47-03-4      Observed electrical wiring exposed at walk in cooler. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334629  
 License Type: Permanent Food Service

JIMMY JOHNS  
 5701 SUNSET DR STE 182, SOUTH MIAMI 33143

Inspection Date: 01/31/2020      Inspection Number: 2955324      Inspection Type: Routine - Food      Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

Violation Code    ObservationViolation Citation

46-01-4      Marked exit/path to marked exit blocked. For reporting purposes only. Observed back exit door blocked by bicycles.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2334358  
 License Type: Permanent Food Service

CECI PIZZA  
 7900 NW 27 AVE BOOTH 425, MIAMI 33147

Inspection Date: 01/30/2020      Inspection Number: 2960414      Inspection Type: Routine - Food      Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

Violation Code    ObservationViolation Citation

46-01-4      Marked exit/path to marked exit blocked. For reporting purposes only. Observed blocked by 2 trolleys in the pathway of the exit door

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Dade County**

License Number: 2319530

LA VILLA DE DON POLLO

License Type: Permanent Food Service

19361 S DIXIE HWY, CUTLER BAY 33157

Inspection Date: 01/31/2020

Inspection Number: 2946207

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code   ObservationViolation Citation

45-06-4      Portable fire extinguisher is inaccessible. For reporting purposes only. Observed extinguisher blocked by ladder and broom.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325243

POLLO TROPICAL 25

License Type: Permanent Food Service

19911 NW 2 AVE, MIAMI 331692903

Inspection Date: 01/31/2020

Inspection Number: 2951794

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code   ObservationViolation Citation

46-01-4      Marked exit/path to marked exit blocked. For reporting purposes only. Observed boxes and food cart at back door. Employee removed all items. \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2331220

KENTUCKY FRIED CHICKEN

License Type: Permanent Food Service

949 SW 107 AVE, MIAMI 33174

Inspection Date: 01/27/2020

Inspection Number: 2952728

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code   ObservationViolation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone in front counter. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336269

WINGS N JERK

License Type: Permanent Food Service

10519 SW 109 CT, MIAMI 33176

Inspection Date: 01/29/2020

Inspection Number: 2946359

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code   ObservationViolation Citation

48-04-4      Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2316721 OASIS GRILL  
 License Type: Permanent Food Service 12400 SW 152 ST, MIAMI 33177

Inspection Date: 01/28/2020 Inspection Number: 2950060 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-05-4	Flammables stored near a source of ignition. For reporting purposes only. Observed gas tank of 20 pound stored on the prep area. <b>**Corrected On-Site**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2335134 EL MIO  
 License Type: Permanent Food Service 12362 QUAIL ROOST DR, MIAMI 33177

Inspection Date: 01/29/2020 Inspection Number: 2628621 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	- From initial inspection : Portable fire extinguisher missing from its designated location. For reporting purposes only. - From follow-up inspection 2020-01-29: Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Duval County**

License Number: 2612932 EL TAPATIO ORIGINAL  
 License Type: Permanent Food Service 7900 103 ST STE 32, JACKSONVILLE 32210

Inspection Date: 01/28/2020 Inspection Number: 2952308 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two tanks stored in prep area near exit door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2608960 HARDEE'S  
 License Type: Permanent Food Service 1500 MAYPORT RD, ATLANTIC BEACH 32233

Inspection Date: 01/29/2020 Inspection Number: 2907968 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by back door is in red zone and needs to be recharged.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2611601 ANDY'S SANDWICH SHOPPE  
 License Type: Permanent Food Service 503 S LANE AVE, JACKSONVILLE 322543531

Inspection Date: 01/27/2020 Inspection Number: 2950189 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two tanks near back door.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hernando County**

License Number: 3700459

MCDONALD'S 10572

License Type: Permanent Food Service

13100 CORTEZ BLVD, BROOKSVILLE 34613

Inspection Date: 01/28/2020

Inspection Number: 2915355

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code    Observation

Violation Citation

46-01-4    Marked exit/path to marked exit blocked. For reporting purposes only.  
 Dry storage door blocked by trash whale and empty boxes. **\*\*Repeat Violation\*\***

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.



**Lake County**

License Number: 4508233

GATORS DOCKSIDE VILLAGES LLC

License Type: Permanent Food Service

1004 MAIN ST, THE VILLAGES 32159

Inspection Date: 01/28/2020

Inspection Number: 2935949

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name:

Violation Code

Observation

Violation Citation

47-01-4

Observed frayed/spliced electrical wires. For reporting purposes only.  
To right of dish machine.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Manatee County**

License Number: 5104031

EVIE'S TAVERN &amp; GRILL TAMPA INC

License Type: Permanent Food Service

5897 WHITFIELD AVE, SARASOTA 34243

Inspection Date: 01/30/2020

Inspection Number: 2936567

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name:

Violation Code   ObservationViolation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5104088

BURGER KING #9856

License Type: Permanent Food Service

3235 UNIVERSITY PKWY, SARASOTA 34243

Inspection Date: 01/30/2020

Inspection Number: 2973256

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name:

Violation Code   ObservationViolation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603283 BEACH CASTLE BURGER  
 License Type: Permanent Food Service 461 RANGER RD STE 5, MARY ESTHER 32569

Inspection Date: 01/31/2020 Inspection Number: 2935093 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Kitchen wall mount	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5604035 AMERICAN HOUSE BLUEWATER BAY  
 License Type: Permanent Food Service 4595 HWY 20 E, NICEVILLE 32578

Inspection Date: 01/27/2020 Inspection Number: 2935143 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Expired - 6/29/16 #130209 / 6/29/16 # 130210 **Repeat Violation**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



**Orange County**

License Number: 5806854 SIDESHOW/CANTINA  
 License Type: Permanent Food Service 15 N ORANGE AVE, ORLANDO 328012418

Inspection Date: 01/28/2020 Inspection Number: 2956781 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Equipment impeding access to exit door. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5811461 POM POM'S TEAHOUSE & SANDWICHERIA  
 License Type: Permanent Food Service 67 N BUMBY AVE, ORLANDO 32803

Inspection Date: 01/31/2020 Inspection Number: 2973272 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. One-pan burner being used occasionally in back area, no hood system in place. Oil and/or butter being used in pans to heat items.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814570 POPEYES #12079  
 License Type: Permanent Food Service 2663 N HIAWASSEE RD, HIAWASSEE 32818

Inspection Date: 01/28/2020 Inspection Number: 2940750 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.





**Palm Beach County**

License Number: 6012406 DELI ON RYE  
 License Type: Permanent Food Service 4311 N FEDERAL HWY, BOCA RATON 33431

Inspection Date: 01/28/2020 Inspection Number: 2941268 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

Violation Code Observation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.  
 - there is an exhaust hood with s fire suppression system in place however the deep fryer is on a counter-top outside of the exhaust hood and has no fire suppression.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6021041 MCCARTHY'S PUB  
 License Type: Permanent Food Service 518 N US HWY 1, TEQUESTA 33469

Inspection Date: 01/29/2020 Inspection Number: 2947453 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

Violation Code Observation

47-03-4 Observed electrical wiring in disrepair. For reporting purposes only.cover plate/loose/electrical outlet by cookline.

Violation Citation

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6007565 BOCA COUNTRY CLUB  
 License Type: Permanent Food Service 17751 BOCA CLUB BLVD, BOCA RATON 33487

Inspection Date: 01/27/2020 Inspection Number: 2949213 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Violation Citation

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6007566 BOCA COUNTRY CLUB  
 License Type: Permanent Food Service 17751 BOCA CLUB BLVD, BOCA RATON 33487

Inspection Date: 01/27/2020 Inspection Number: 2949001 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

Violation Code Observation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

Violation Citation

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Pinellas County**

License Number: 6217254 THE TACO LADY  
 License Type: Permanent Food Service 5507 38 AVE N, ST. PETERSBURG 33709

Inspection Date: 01/30/2020 Inspection Number: 2961399 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Fire extinguishers on floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215393 CHINA 1  
 License Type: Permanent Food Service 1285 S MISSOURI AVE, CLEARWATER 33756

Inspection Date: 01/31/2020 Inspection Number: 2972592 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked by boxes on the floor. For reporting purposes only. **Repeat Violation**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6214962 THIRSTY MARLIN GRILL & BAR  
 License Type: Permanent Food Service 1023 FLORIDA AVE, PALM HARBOR 34683

Inspection Date: 01/27/2020 Inspection Number: 2944135 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Several boxes, moved **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Pinellas County**

License Number: 6217485

CHICK FIL A PALM HARBOR

License Type: Permanent Food Service

32800 US HWY 19 N, PALM HARBOR 34684

Inspection Date: 01/27/2020

Inspection Number: 2941087

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name:

Violation Code   ObservationViolation Citation45-02-4      Portable fire extinguisher gauge in red zone by back room area . For reporting  
purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6213630

TACO BELL #17693

License Type: Permanent Food Service

40976 N US HWY 19, TARPON SPRINGS 346895446

Inspection Date: 01/28/2020

Inspection Number: 2951969

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name:

Violation Code   ObservationViolation Citation46-01-4      Marked exit/path to marked exit blocked. For reporting purposes only. Trash can,  
removed \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Polk County**

License Number: 6308537

MARLENES TAKE OUT

License Type: Permanent Food Service

813 W MEMORIAL BLVD, LAKE LAND 33815

Inspection Date: 01/28/2020

Inspection Number: 2947179

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code    Observation

Violation Citation

45-04-4    Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed counter top fryer in use not under suppression system, operator moved fryer under suppression system. **\*\*Corrected On-Site\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Sarasota County**

License Number: 6804726 HOLIDAY INN EXPRESS & SUITES SARASOTA EAST/I-75  
 License Type: Permanent Food Service 5730 GANTT RD, SARASOTA 34233

Inspection Date: 01/29/2020 Inspection Number: 2911935 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. On floor under HWS.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6805477 JIMMY JOHN'S GOURMET SANDWICHES  
 License Type: Permanent Food Service 5304 CLARK RD, SARASOTA 34233

Inspection Date: 01/30/2020 Inspection Number: 2910907 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name:

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Operator moved cart and buckets **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Seminole County**

License Number: 6903347

STEAK N SHAKE #272

License Type: Permanent Food Service

4325 N LAKE MARY BLVD, LAKE MARY 327462448

Inspection Date: 01/29/2020

Inspection Number: 2946839

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name:

Violation Code    Observation

Violation Citation

46-01-4            Marked exit/path to marked exit blocked. For reporting purposes only. Rear door.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Volusia County**

License Number: 7405531

CARRABBA'S ITALIAN GRILL

License Type: Permanent Food Service

2200 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 01/28/2020

Inspection Number: 2949586

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name:

Violation Code   ObservationViolation Citation46-01-4   Marked exit/path to marked exit blocked. For reporting purposes only.  
Exit hallway by guest bathrooms blocked by tables and chairs.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 7405261

DELICIAS CENTROAMERICANAS LLC

License Type: Permanent Food Service

722 MASON AVE, DAYTONA BEACH 32117

Inspection Date: 01/29/2020

Inspection Number: 2952283

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name:

Violation Code   ObservationViolation Citation45-04-4   Use of cooking equipment producing grease laden vapors/smoke with no hood  
suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.