

**Brevard County**

License Number: 1506313

MOM &amp; POPS BAR AND GRILL

License Type: Permanent Food Service

900 N ATLANTIC AVE STE D, COCOA BEACH 32931

Inspection Date: 02/06/2020

Inspection Number: 2960251

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: HICKS, GEORGE RANDY

Violation Code    ObservationViolation Citation

48-01-5    - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.    - From follow-up inspection 2020-01-07: \*\*Time Extended\*\*    - From follow-up inspection 2020-02-06: \*\*Time Extended\*\*

61C-1.004(9) FAC Reporting: (9) Heating and ventilation  
- The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1506649

OUTBACK STEAKHOUSE

License Type: Permanent Food Service

7211 LAKE ANDREW DR, MELBOURNE 32940

Inspection Date: 02/06/2020

Inspection Number: 2941388

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: WALCOTT, AMY

Violation Code    ObservationViolation Citation

45-02-4    Portable fire extinguisher gauge in red zone. For reporting purposes only by backdoor.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Broward County**

License Number: 1618533

BARGAIN FAMILY RESTAURANT

License Type: Permanent Food Service

728 S DIXIE HWY, HOLLYWOOD 33020

Inspection Date: 02/04/2020

Inspection Number: 2947005

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: CHAPDELAIN, MARIE

Violation Code   ObservationViolation Citation

48-03-4      Gas pressure cleaner inside restaurant . For reporting purposes only.

509.211(2)(a) FS Reporting: (2)(a) It is unlawful for any person to use within any public lodging establishment or public food service establishment any fuel-burning wick-type equipment for space heating unless such equipment is vented so as to prevent the accumulation of toxic or injurious gases or liquids. For reporting purposes only.

License Number: 1623703

THE MUGHAL

License Type: Permanent Food Service

2100 N UNIVERSITY DR, PEMBROKE PINES 33024

Inspection Date: 01/31/2020

Inspection Number: 2949000

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: BENJAMIN, ALEXANDER

Violation Code   ObservationViolation Citation

45-04-4      Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1653171

FOOD-CO-HOLIC LLC

License Type: Mobile Food Dispensing Vehicle

5007 N HIATUS RD, SUNRISE 33351

Inspection Date: 02/03/2020

Inspection Number: 1222244

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRES, LARRY

Violation Code   ObservationViolation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Citrus County**

License Number: 1901408

CONEY ISLAND DRIVE INN

License Type: Permanent Food Service

674 NORTHEAST 5 STREET, CRYSTAL RIVER 34429

Inspection Date: 02/04/2020

Inspection Number: 2973385

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

49-05-4

Establishment increased seating without providing written approval from the local fire authority.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Collier County**

License Number: 2102555

QUAIL CREEK COUNTRY CLUB

License Type: Permanent Food Service

13300 VALEWOOD DR, NAPLES 34119

Inspection Date: 02/03/2020

Inspection Number: 2954291

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PFENNING, BRUNO

Violation Code

Observation

Violation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2333921 PINOLANDIA CORPORATION  
 License Type: Permanent Food Service 119 NW 12TH AVE, MIAMI 33128

Inspection Date: 02/06/2020 Inspection Number: 2956748 Inspection Type: Routine - Food Inspection Disposition: Warning Issued  
 Inspector Name: PAGAN, VICTOR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Located in back kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2336086 LA ESQUINA DEL PAN CON BISTEC #2  
 License Type: Permanent Food Service 1011 SW 8 ST, MIAMI 33130

Inspection Date: 02/05/2020 Inspection Number: 2934357 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GARCIA, B OSCAR

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
49-05-4	Flammables stored near a source of ignition. For reporting purposes only. Propane tank next to fryer.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2303290 COURTYARD CAFE  
 License Type: Permanent Food Service 2051 S LEJEUNE RD, MIAMI 33134

Inspection Date: 02/06/2020 Inspection Number: 2892972 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: PICO, JORGE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2020-02-06: No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Time Extended**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Dade County**

License Number: 2334629 JIMMY JOHNS  
 License Type: Permanent Food Service 5701 SUNSET DR STE 182, SOUTH MIAMI 33143

Inspection Date: 01/31/2020 Inspection Number: 2955324 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PICO, JORGE

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed back exit door blocked by bicycles.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2321924 SARA SHARPE CATERING INC  
 License Type: Permanent Food Service 3328 SW 23 TERR, MIAMI 331453128

Inspection Date: 02/07/2020 Inspection Number: 2949830 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GARCIA, B OSCAR

Violation Code ObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2317188 POPEYES FAMOUS FRIED CHICKEN 6  
 License Type: Permanent Food Service 1695 NW 103 ST, MIAMI 331471433

Inspection Date: 02/06/2020 Inspection Number: 2960472 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: JOSEPH, VANRIE

Violation Code ObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Observed numerous cardboard boxes on the floor

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2331584 TRATTORIA DI PIU  
 License Type: Permanent Food Service 2475 NW 95TH AVE UNIT #9, DORAL BRANCH 33172

Inspection Date: 02/03/2020 Inspection Number: 2956698 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: GONZALEZ, ERIK

Violation Code ObservationViolation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in overcharged zone by hand wash sink inside kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2614119

HOMEWOOD SUITES BY HILTON JACKSONVILLE DOWNTOWN SOUTHBANK

License Type: Permanent Food Service

1201 KINGS AVE, JACKSONVILLE 32207

Inspection Date: 02/04/2020

Inspection Number: 2933206

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: ARMSTRONG, RICO

**Violation Code** **Observation****Violation Citation**

48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2020-02-04: Boiler certificates available.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.
48-02-5	- From initial inspection : Insurance inspector boiler report not posted in boiler room. For reporting purposes only. - From follow-up inspection 2020-02-04: Boiler certificates available.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 2615422

SUPER TIENDA LATINA Y RESTAURANTE

License Type: Permanent Food Service

3935 TOLEDO RD STE 6, JACKSONVILLE 32217

Inspection Date: 02/03/2020

Inspection Number: 2914474

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JEFFERS, MARY-BETH

**Violation Code** **Observation****Violation Citation**

46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Multiple large pots blocking path to exit door in kitchen. Also, trash can blocking exit path at door in kitchen.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.
---------	---	--

**Escambia County**

License Number: 2705401

O'ZONE PIZZA PUB INC

License Type: Permanent Food Service

1010 N 12 AVE SUITE #130, PENSACOLA 32501

Inspection Date: 02/05/2020

Inspection Number: 2905057

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALBRITTON, GREGORY

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.  
 Inside front entrance at bottom of steps water dripping from Ac line onto wires.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Hillsborough County**

License Number: 3906579

SUBWAY

License Type: Permanent Food Service

4311 W WATER AVE STE 101, TAMPA 33614

Inspection Date: 02/04/2020

Inspection Number: 2930461

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation Code

Observation

Violation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lake County**

License Number: 4508827

LOS COMPADRES SUPERMARKET INC

License Type: Permanent Food Service

2741 W OLD US HWY 441, MOUNT DORA 32757

Inspection Date: 02/04/2020

Inspection Number: 2958200

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: MONTGOMERY, DOREEN

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only

4 large propane tanks in room that has walk in cooler, operator states they rent them

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Leon County**

License Number: 4703289

AURA & PRIVE

License Type: Permanent Food Service

215 W COLLEGE AVE STE 101 & 102, TALLAHASSEE 32301

Inspection Date: 01/29/2020

Inspection Number: 2973274

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: TAKEH, NADEGE

Violation Code

Observation

Violation Citation

45-04-4

OBSERVED: USE OF COOKING EQUIPMENT PRODUCING GREASE LADEN VAPORS/SMOKE WITH NO HOOD SUPPRESSION SYSTEM INSTALLED. NOTIFIED FIRE AHJ. FOR REPORTING PURPOSES ONLY

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Levy County**

License Number: 4800385 ISLAND ROOM  
 License Type: Permanent Food Service 10 E 2 ST, CEDAR KEY 32625

Inspection Date: 02/03/2020 Inspection Number: 2887044 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PACE, PATRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In storage area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4800463 TACO BELL # 198  
 License Type: Permanent Food Service 2025 N YOUNG BLVD, CHIEFLAND 32626

Inspection Date: 02/04/2020 Inspection Number: 2949084 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: PACE, PATRICK

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Emergency exit sign at back door hanging by wires.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5809181 PANERA BREAD #3312  
 License Type: Permanent Food Service 11472 UNIVERSITY BLVD, ORLANDO 32817

Inspection Date: 02/06/2020 Inspection Number: 2931625 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: FRANZ, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.- by trash **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5809179 HILTON GARDEN INN - ORLANDO AIRPORT  
 License Type: Permanent Food Service 7300 AUGUSTA NATIONAL DR, ORLANDO 32822

Inspection Date: 02/07/2020 Inspection Number: 2931679 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler for FI 124222 . For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5807459 MCDONALD'S #2576  
 License Type: Permanent Food Service 451 S GOLDENROD RD, ORLANDO 328228121

Inspection Date: 02/06/2020 Inspection Number: 2884621 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: RULLAN, ALFONSO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked With seats, by play pen.. For reporting purposes only. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.



**Pasco County**

License Number: 6102849

MAMMA MIA PIZZERIA

License Type: Permanent Food Service

8639 REGENCY PARK BLVD, PORT RICHEY 34668

Inspection Date: 02/06/2020

Inspection Number: 2891034

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRACO, MARIANNE

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Pizza boxes

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Pinellas County**

License Number: 6200962	PERISCOPE RESTAURANT		
License Type: Permanent Food Service	6800 SUNSHINE SKYWAY LN S, ST PETERSBURG	337114901	
Inspection Date: 02/05/2020	Inspection Number: 2940061	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: RANVILLE, AMANDA			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
49-03-4	Flammables stored/debris present in boiler room. For reporting purposes only. Large amount of wood in hot water room.		61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
License Number: 6218001	POPEYES		
License Type: Permanent Food Service	1285 S MISSOURI AVE STE A, CLEARWATER	33756	
Inspection Date: 08/14/2019	Inspection Number: 2973657	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Warning Issued
Inspector Name: UNDEFINED, INSPECTOR			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
46-01-4	Observed: Marked exit/path to marked exit blocked. For reporting purposes only. Folded boxes in front of back exit door in kitchen Priority: Reporting		61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.
License Number: 6216176	SUBWAY #33258		
License Type: Permanent Food Service	18415 US HWY 19 N, CLEARWATER	33764	
Inspection Date: 02/06/2020	Inspection Number: 2893882	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LANTIGUA, ROBERTO			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked by a pile of empty boxes. For reporting purposes only.		61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.
License Number: 6212615	CARAMBOLA		
License Type: Permanent Food Service	400 MANDALAY AVE, CLEARWATER	33767	
Inspection Date: 02/05/2020	Inspection Number: 2947837	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>		<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. All expired.		61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.



**Pinellas County**

License Number: 6205894

SHERATON ISLAND CAFE

License Type: Permanent Food Service

1160 GULF BLVD, CLEARWATER BCH 33767

Inspection Date: 02/03/2020

Inspection Number: 2932669

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Two boiler certificates expired.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Polk County**

License Number: 6305082

CHILI'S WINTER HAVEN FLA #409

License Type: Permanent Food Service

699 CYPRESS GDNS BLVD, WINTER HAVEN 338804458

Inspection Date: 02/06/2020

Inspection Number: 2948540

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITE, CHERYL

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. Boiler certificate expired 2/25/16 For reporting purposes only. **\*\*Repeat Violation\*\***

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Sarasota County**

License Number: 6804954

L&D CHINA BUFFET

License Type: Permanent Food Service

4411 AIDAN LN, NORTH PORT 34287

Inspection Date: 02/03/2020

Inspection Number: 2958550

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: FERRY, WILLIAM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-01-4	Observed frayed/spliced electrical wires. For reporting purposes only. Extension cord near cook line was spliced together at three different areas.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
47-01-4	- From initial inspection : Observed frayed/spliced electrical wires. For reporting purposes only. Extension cord near cook line was spliced together at three different areas. - From follow-up inspection 2020-02-05: <b>**Time Extended**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6904585

SONNY'S BBQ

License Type: Permanent Food Service

7460 DOVER GARDEN LANE, OVIEDO 32765

Inspection Date: 02/05/2020

Inspection Number: 2957342

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code    Observation

Violation Citation

47-03-4    Missing switch plate at the dishwasher

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**St. Lucie County**

License Number: 6600733

COURTYARD BY MARRIOTT

License Type: Permanent Food Service

10978 S OCEAN DR, JENSEN BEACH 34957

Inspection Date: 02/04/2020

Inspection Number: 2940748

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 lp tanks in downstairs hallway.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Volusia County**

License Number: 7407307 TOMOKA BREWING COMPANY  
 License Type: Permanent Food Service 4647 CLYDE MORRIS BLVD UNIT 504, PORT ORANGE 32129

Inspection Date: 02/04/2020 Inspection Number: 2966959 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: LARSON, SARAH

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 7406351 ENCORE CATERING OF CENTRAL FL  
 License Type: Catering 105 MANDARIN AVE, DELAND 32720

Inspection Date: 02/04/2020 Inspection Number: 1113211 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended  
 Inspector Name: OCASIO-LOPEZ, LISA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 tanks located inside building above refrigerator. - From follow-up inspection 2020-02-04: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.