

Bradford County

License Number: 1400161

THE DOWNTOWN GRILL

License Type: Permanent Food Service

301 E CALL ST, STARKE 32091

Inspection Date: 02/20/2020

Inspection Number: 2942613

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PACE, PATRICK

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Blocked by room divider. Single door exit on side of building from banquet room.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Broward County

License Number: 1624927 SLICED BURGER
 License Type: Permanent Food Service 6290 WEST SAMPLE ROAD UNIT 103B, CORAL SPRINGS 33067

Inspection Date: 02/19/2020 Inspection Number: 2966215 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BANNIGAN, TIM

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 45-05-4 | Portable fire extinguisher missing from its designated location. For reporting purposes only. - Class ABC portable extinguisher on floor next to mop sink. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 1611934 HISTORIC DOWNTOWNER SALOON
 License Type: Permanent Food Service 10 S NEW RIVER DR E, FORT LAUDERDALE 33301

Inspection Date: 02/21/2020 Inspection Number: 2951603 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: BRANN, JUSTIN

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 48-04-4 | Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 propane tanks on top of ice machine, 3 tanks by CO2 tanks inside kitchen. Inspector will email inspection report to Fire Marshall Jeff Lucas. **Corrective Action Taken** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 1616008 CHECKERS DRIVE-IN
 License Type: Permanent Food Service 590 E OAKLAND PARK BLVD, WILTON MANORS 33334

Inspection Date: 02/17/2020 Inspection Number: 2943966 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GRAY, ANTHONY

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 45-05-4 | Portable fire extinguisher missing from its designated location. For reporting purposes only. **Repeat Violation** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Clay County

License Number: 2001024 SONIC DRIVE IN #4505
 License Type: Permanent Food Service 908 BLANDING BLVD, ORANGE PARK 32065

Inspection Date: 02/18/2020 Inspection Number: 2900409 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BIAVA, GRANT

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. In outside storage shed next to door, in recharge state | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 2000788 BOWL THAI & SUSHI RESTAURANT
 License Type: Permanent Food Service 10 BLANDING BLVD STE B, ORANGE PARK 32073

Inspection Date: 02/17/2020 Inspection Number: 2970571 Inspection Type: Food-Licensing Inspection Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: BIAVA, GRANT

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to rear entrance of establishment, fire extinguisher in overcharge. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Dade County

License Number: 2326911 CHEESECAKE FACTORY (THE)
 License Type: Permanent Food Service 7535 DADELAND MALL SP2000, MIAMI 33156

Inspection Date: 02/21/2020 Inspection Number: 2883678 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: LEIDECKER, EDILMA

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 48-01-5 | - From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2020-02-21: No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. **Time Extended** | 61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. | 61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |

License Number: 2330543 MOE'S SOUTHWEST GRILL #44
 License Type: Permanent Food Service 10660 NW 19TH STREET, MIAMI 33172

Inspection Date: 02/20/2020 Inspection Number: 2958974 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ERIK

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone by hand wash sink in front of office. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 2318222 SIAM BISTRO
 License Type: Permanent Food Service 7348 SW 117 AVE, MIAMI 33183

Inspection Date: 02/20/2020 Inspection Number: 2943219 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GONZALEZ, ALEJANDRO

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|--|
| 46-01-4 | Marked exit/path to marked exit blocked. For reporting purposes only. | 61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only. |

Dade County

License Number: 2335211

TACO BELL 031630

License Type: Permanent Food Service

4185 SW 147 AVE, MIAMI 33185

Inspection Date: 02/18/2020

Inspection Number: 2949648

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JA DE DIOS, YANLEE

Violation Code

Observation

Violation Citation

46-04-4 Exit door locked. For reporting purposes only. Garbage cans. **Corrected On-Site**

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Hillsborough County

License Number: 3912840

DANNY'S ALL AMERICAN CAFE

License Type: Permanent Food Service

4406 FALKENBURG RD, TAMPA 33610

Inspection Date: 02/19/2020

Inspection Number: 2944493

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: DAVIS, CAROL S

Violation Code ObservationViolation Citation49-01-4 Increased seating from 10 to approximately 35. ****Repeat Violation****

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

49-01-4 - From initial inspection : Increased seating from 10 to approximately 35.
****Repeat Violation**** - From follow-up inspection 2020-02-19: ****Time Extended****

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 3912341

BISTRO BT

License Type: Permanent Food Service

4267 HENDERSON BLVD, TAMPA 33629

Inspection Date: 02/17/2020

Inspection Number: 2942389

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation Code ObservationViolation Citation45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
Small household fryer under prep shelf.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Lee County

License Number: 4606793

HAMMOND STADIUM LEE COUNTY SPORTS COMPLEX COMMISSARY

License Type: Permanent Food Service

14400 6 MILE CYPRESS PKWY, FORT MYERS 33912

Inspection Date: 02/21/2020

Inspection Number: 2968995

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JOHNSON, JONATHAN

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Orange County

License Number: 5813774 RESIDENCE INN BY MARRIOTT ORLANDO DOWNTOWN
 License Type: Permanent Food Service 680 N ORANGE AVE, ORLANDO 32801

Inspection Date: 02/21/2020 Inspection Number: 2937585 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: QUINONES, ANTONIO

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 48-01-5 | No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Establishment appear to have 3 boilers; however, has certificates for two out of the 3. | 61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only. |

License Number: 5814140 CHICK FIL A ORLANDO SQUARE
 License Type: Permanent Food Service 1800 SAND LAKE RD, ORLANDO 32809

Inspection Date: 02/20/2020 Inspection Number: 2963069 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: GREENE, MARVIN

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. K class extinguisher. | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 5810529 SUSHI TOMI
 License Type: Permanent Food Service 8462 JOHN YOUNG PKWY, ORLANDO 32819

Inspection Date: 02/17/2020 Inspection Number: 2960568 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MANTI, KATHRYN

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 45-06-4 | Portable fire extinguisher is inaccessible. For reporting purposes only. Blocked by garbage can | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 5811989 TASTE OF ASIA
 License Type: Permanent Food Service 8910 TURKEY LAKE ROAD C-300, ORLANDO 32819

Inspection Date: 02/17/2020 Inspection Number: 2960779 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: MANTI, KATHRYN

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|---|---|
| 45-06-4 | Portable fire extinguisher is inaccessible. For reporting purposes only. Blocked by a shelf | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Orange County

License Number: 5813244 PAPA JOHN'S PIZZA #266
 License Type: Permanent Food Service 7354 CURRY FORD RD STE 151-G, ORLANDO 32822

Inspection Date: 02/13/2020 Inspection Number: 2903915 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: RULLAN, ALFONSO

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 46-01-4 | Marked exit/path to marked exit blocked, left side back door blocked with cart, ladder and mop bucket.. For reporting purposes only. **Repeat Violation** | 61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only. |

License Number: 5813566 CHEDDAR'S CASUAL CAFE
 License Type: Permanent Food Service 12201 E COLONIAL DR, ORLANDO 32826

Inspection Date: 02/18/2020 Inspection Number: 2947930 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THORNCROFT, ROBERT

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 45-02-4 | Portable fire extinguisher gauge in red zone. For reporting purposes only. At the both exit door of the kitchen and the dinning room . 3 extinguisher in the red | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |
| 47-01-4 | Observed frayed/spliced electrical wires. For reporting purposes only. Salad spinner the cord is cracked | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

License Number: 5813781 ITAR BISTRO & MARKET
 License Type: Permanent Food Service 7065 WESTPOINT BLVD STE 100, ORLANDO 32835

Inspection Date: 02/18/2020 Inspection Number: 2907859 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied
 Inspector Name: CONNOLLY, MADELINE

| <u>Violation Code</u> | <u>Observation</u> | <u>Violation Citation</u> |
|-----------------------|--|---|
| 45-02-4 | - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. The one by Espresso machine, - From follow-up inspection 2019-12-20: **Time Extended** - From follow-up inspection 2020-02-18: **Time Extended** | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |

Palm Beach County

License Number: 6011957

ST LOUIS GRILL

License Type: Permanent Food Service

4751 MAIN ST, JUPITER 33458

Inspection Date: 02/19/2020

Inspection Number: 2943229

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.outlet cover missing/frontline

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6113702

JEM RESTAURANT GROUP OF FLORIDA INC

License Type: Permanent Food Service

7575 SR 54, NEW PORT RICHEY 34653

Inspection Date: 02/17/2020

Inspection Number: 2968405

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRACO, MARIANNE

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Garbage pails and boxes, removed **Corrected On-Site**

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Polk County

License Number: 6307811

RAINBOW PRIDE AND LOUNGE

License Type: Permanent Food Service

221 AVE T NE, WINTER HAVEN 33881

Inspection Date: 02/20/2020

Inspection Number: 2960817

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: JACKSON, SHARON

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed small electrical fryer being used to fry plantains.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6804432

PAPA JOHN'S PIZZA

License Type: Permanent Food Service

1223 US 41 BYP S, VENICE 34292

Inspection Date: 02/18/2020

Inspection Number: 2906431

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PEREZ, STACY

Violation Code

Observation

Violation Citation

47-01-4

Observed electrical box hanging down inside walk in cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6905025

JASON'S DELI

License Type: Permanent Food Service

3887 LAKE MARY BLVD, SUITE 1021, LAKE MARY 32746

Inspection Date: 02/18/2020

Inspection Number: 2951342

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ALVIS, DAVID

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. By trash to be taken out. ****Corrective Action Taken****

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

St. Johns County

License Number: 6502038

LITTLE CAESARS

License Type: Permanent Food Service

465 SR 13, JACKSONVILLE 32259

Inspection Date: 02/17/2020

Inspection Number: 2918217

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: GOSAI, MATT

Violation Code Observation

Violation Citation

47-01-4 Observed frayed/spliced electrical wires. For reporting purposes only. Exposed , loose wires hanging at inside entrance of walk in cooler.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

47-01-4 - From initial inspection : Observed frayed/spliced electrical wires. For reporting purposes only. Exposed , loose wires hanging at inside entrance of walk in cooler. - From follow-up inspection 2020-02-20: At callback : No Change. Time needed to fix. ****Time Extended****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7403812

HOOTERS OF DAYTONA

License Type: Permanent Food Service

2100 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114

Inspection Date: 02/20/2020

Inspection Number: 2960308

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

49-03-4

Liquor stored in water heater room. For reporting purposes only.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 7407123

CHAL'S TIME OUT SPORTS PUB

License Type: Permanent Food Service

1401 S RIDGEWOOD AVE #3, EDGEWATER 32132

Inspection Date: 02/21/2020

Inspection Number: 2904068

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LARSON, SARAH

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.