

Brevard County

License Number: 1505627

BOB EVANS RESTAURANT #452

License Type: Permanent Food Service

100 SHERIFF DR, MELBOURNE 32940

Inspection Date: 02/24/2020

Inspection Number: 2954946

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WALCOTT, AMY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Tank near walk in cooler

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1622272

CIAO CUCINA & BAR

License Type: Permanent Food Service

4443 LYONS RD D104, COCONUT CREEK 33073

Inspection Date: 02/26/2020

Inspection Number: 2962002

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: GOLDMAN, BARRY

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Operator removed from building. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1611934

HISTORIC DOWNTOWNER SALOON

License Type: Permanent Food Service

10 S NEW RIVER DR E, FORT LAUDERDALE 33301

Inspection Date: 02/24/2020

Inspection Number: 2951603

Inspection Type: Routine - Food

Inspection Disposition: Call Back - Complied

Inspector Name: BRANN, JUSTIN

Violation CodeObservationViolation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 3 propane tanks on top of ice machine, 3 tanks by CO2 tanks inside kitchen. Inspector will email inspection report to Fire Marshall Jeff Lucas. **Corrective Action Taken** - From follow-up inspection 2020-02-24: Per operator, tanks were moved outside. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Citrus County

License Number: 1901262

ROCCOS PIZZA & CAFE

License Type: Permanent Food Service

6612 GULF TO LAKE HWY, CRYSTAL RIVER 34429

Inspection Date: 02/26/2020

Inspection Number: 2960734

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

49-01-4 Establishment increased seating without providing written approval from the local fire authority and wastewater provider.

License shows 36 seats, inspector count is - 42 seats inside dining room, 60 in side dining room, 20 outside

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Clay County

License Number: 2001373

KOREAN HOUSE

License Type: Permanent Food Service

1540 WELLS ROAD #14, ORANGE PARK 32073

Inspection Date: 02/25/2020

Inspection Number: 2917951

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only.
Box of butane cans stored under stove on cook line, manager removed during inspection. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Collier County

License Number: 2103112

ALPINE RESTAURANT

License Type: Permanent Food Service

2355 VANDERBILT BEACH RD STE 158, NAPLES 34109

Inspection Date: 02/25/2020

Inspection Number: 2954387

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PFENNING, BRUNO

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building by back door. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2316700		GRAND CHINA RESTAURANT	
License Type: Permanent Food Service		18643 S DIXIE HWY, CUTLER BAY 33157	
Inspection Date: 02/25/2020	Inspection Number: 2953469	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HERNANDEZ, NILYAM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Observed exposed wired in dry storage.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2335124		EL REY DE LAS FRITAS	
License Type: Permanent Food Service		10142 WEST FLAGLER ST, MIAMI 33174	
Inspection Date: 02/26/2020	Inspection Number: 2958657	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed in back kitchen by dry storage.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2335091		BULLA GASTROBAR	
License Type: Permanent Food Service		5335 NW 87 AVE C102, MIAMI 33178	
Inspection Date: 02/25/2020	Inspection Number: 2937247	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GANDOLFF, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 5 bbq LP gas tanks store on the second floor dry storage room.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 5 bbq LP gas tanks store on the second floor dry storage room. - From follow-up inspection 2020-02-26: Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 12 bbq LP gas tanks store on the second floor dry storage room. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2613562

CHICK-FIL-A AT BUTLER POINTE PLAZA

License Type: Permanent Food Service

7147 PHILIPS HWY, JACKSONVILLE 32256

Inspection Date: 02/24/2020

Inspection Number: 2908289

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Located new back door not in the red zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Escambia County

License Number: 2704081

NEW WORLD LANDING

License Type: Permanent Food Service

600 SOUTH PALAFOX ST, PENSACOLA 32502

Inspection Date: 02/28/2020

Inspection Number: 2893585

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation Code

Observation

Violation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Hamilton County

License Number: 3400184

FAT BELLY'S

License Type: Permanent Food Service

16750 SPRING STREET, WHITE SPRINGS 32096

Inspection Date: 02/26/2020

Inspection Number: 2944169

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.
Wiring for vent fan above smoker.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3917506

DAILY DOSE COFFEE HOUSE AND EATERY

License Type: Permanent Food Service

302 KNIGHTS RUN # 130, TAMPA 33602

Inspection Date: 02/24/2020

Inspection Number: 2934337

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: COLEMAN, TONYA

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood
suppression system installed. Notified Fire AHJ. For reporting purposes only.
Repeat Violation509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

License Number: 3916492

AQUA

License Type: Permanent Food Service

7627 COURTNEY CAMPBELL CAUSEWAY, TAMPA 33607

Inspection Date: 02/26/2020

Inspection Number: 2971385

Inspection Type: Complaint Full

Inspection Disposition: Warning
Issued

Inspector Name: FEDERORVITCH, CASEY

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
122542, 122546, 122555 exp 10-30-2019. For reporting purposes only.61C-1.004(9) FAC Reporting: (9) Heating and ventilation
- The heating and ventilation system shall be kept in
good repair or be installed to maintain a minimum of 68
degrees Fahrenheit throughout the building. The
insurance inspector's boiler report is required annually
for power boilers and high pressure/high temperature
boilers and biannually for low pressure steam or vapor
heating boilers and shall be posted in the boiler room.
For reporting purposes only.

48-01-5

- From initial inspection : No current insurance inspector boiler report or boiler
certificate available for boiler. 122542, 122546, 122555 exp 10-30-2019. For
reporting purposes only. - From follow-up inspection 2020-02-27: **Time
Extended**61C-1.004(9) FAC Reporting: (9) Heating and ventilation
- The heating and ventilation system shall be kept in
good repair or be installed to maintain a minimum of 68
degrees Fahrenheit throughout the building. The
insurance inspector's boiler report is required annually
for power boilers and high pressure/high temperature
boilers and biannually for low pressure steam or vapor
heating boilers and shall be posted in the boiler room.
For reporting purposes only.

Leon County

License Number: 4703352

ALOFT

License Type: Permanent Food Service

150 E CALL ST, TALLAHASSEE 32301

Inspection Date: 02/25/2020

Inspection Number: 2959012

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TAKEH, NADEGE

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Monroe County

License Number: 5428122

CHAD S

License Type: Permanent Food Service

92330 OVERSEAS HWY, TAVERNIER 33070

Inspection Date: 02/28/2020

Inspection Number: 2960864

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5811180

LANGFORD RCI LLC

License Type: Catering

300 EAST NEW ENGLAND AVE, WINTER PARK 32789

Inspection Date: 02/28/2020

Inspection Number: 1115056

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LUI, SUK HAN

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./both expired.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5813252

LANGFORD RCI LLC

License Type: Permanent Food Service

300 E NEW ENGLAND AVE, WINTER PARK 32789

Inspection Date: 02/28/2020

Inspection Number: 2959494

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LUI, SUK HAN

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./both certificates expired.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5813268

LANGFORD RCI LLC

License Type: Permanent Food Service

300 NEW ENGLAND AVE, WINTER PARK 32789

Inspection Date: 02/28/2020

Inspection Number: 2959525

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LUI, SUK HAN

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./boilers certificate expired.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5813178

GDC ORLANDO HOTEL OWNER LLC

License Type: Permanent Food Service

500 S ORANGE AVE, ORLANDO 32801

Inspection Date: 02/27/2020

Inspection Number: 2932455

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: QUINONES, ANTONIO

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Orange County

License Number: 5813330		ALOFT ORLANDO DOWNTOWN 2ND FLOOR KITCHEN	
License Type: Permanent Food Service		500 S ORANGE AVE, ORLANDO 32801	
Inspection Date: 02/27/2020	Inspection Number: 2932409	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: QUINONES, ANTONIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 5811356		BORDER GRILL FRESH-MEX	
License Type: Permanent Food Service		5695 WEST VINELAND RD STE A, ORLANDO 32819	
Inspection Date: 02/28/2020	Inspection Number: 2969007	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CONNOLLY, MADELINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only in dining room	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5813959		GYU-KAKU ORLANDO	
License Type: Permanent Food Service		7858 TURKEY LAKE RD #100, ORLANDO 32819	
Inspection Date: 02/28/2020	Inspection Number: 2960746	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MANTI, KATHRYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. ABC extinguisher on floor by bag in the box	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5805936		PICABU'S	
License Type: Permanent Food Service		1500 EPOCT RESORT BLVD, LAKE BUENA VISTA 32830	
Inspection Date: 02/26/2020	Inspection Number: 2964375	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certificate expired 12/15/2019	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Orange County

License Number: 5808500

EL MERCADO DE CORONADO

License Type: Permanent Food Service

1000 W BUENA VISTA DR, LAKE BUENA VISTA 328301000

Inspection Date: 02/24/2020

Inspection Number: 2952549

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
Observed expired 135080, 135081 7/26/2019 **Repeat Violation**

61C-1.004(9) FAC Reporting: (9) Heating and ventilation
- The heating and ventilation system shall be kept in
good repair or be installed to maintain a minimum of 68
degrees Fahrenheit throughout the building. The
insurance inspector's boiler report is required annually
for power boilers and high pressure/high temperature
boilers and biannually for low pressure steam or vapor
heating boilers and shall be posted in the boiler room.
For reporting purposes only.

License Number: 5807960

SUKI HANNA

License Type: Permanent Food Service

4060 TOWN CENTER BLVD, ORLANDO 32837

Inspection Date: 02/24/2020

Inspection Number: 2910245

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MANTI, KATHRYN

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By
cases of frying oil

509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Palm Beach County

License Number: 6019319

LOPEZ CAFE

License Type: Permanent Food Service

572 E CANAL ST S, BELLE GLADE 33430

Inspection Date: 02/26/2020

Inspection Number: 2957576

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MENOR, MICHAEL

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. 2 electrical fryers in use not under the hood **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Electrical box covers missing throughout kitchen **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6011127

EL FOGONCITO

License Type: Permanent Food Service

711 W INDIANTOWN RD STE C4, JUPITER 33458

Inspection Date: 02/27/2020

Inspection Number: 2958945

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.cover plate missing/electrical outlet/frontline.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6009887

DUFFY'S DRAFT HOUSE

License Type: Permanent Food Service

185 E INDIANTOWN RD, JUPITER 33477

Inspection Date: 02/27/2020

Inspection Number: 2956710

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.speed rack/backdoor/corrective action taken/operator removed speed rack. **Corrective Action Taken**

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Pasco County

License Number: 6113489

CRISTIANOS PIZZA AND PASTA

License Type: Permanent Food Service

5743 MAIN ST, NEW PORT RICHEY 34652

Inspection Date: 02/28/2020

Inspection Number: 2976239

Inspection Type: Routine - Food

Inspection Disposition: Emergency order recommended

Inspector Name: TORRACO, MARIANNE

Violation CodeObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. In kitchen by reach in cooler

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6113169

MY DELI BUTTON LLC

License Type: Permanent Food Service

13416 US 19, HUDSON 34667

Inspection Date: 02/26/2020

Inspection Number: 2952490

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRACO, MARIANNE

Violation CodeObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Bacon, eggs . Flat top grill under shelf, smoke in kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Floor fan and bucket, Corrected on Site: removed **Corrected On-Site**

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Pinellas County

License Number: 6217305

PDQ

License Type: Permanent Food Service

2181 GULF TO BAY BLVD, CLEARWATER 33765

Inspection Date: 02/26/2020

Inspection Number: 2975725

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BENEDICT, TRACY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By the Togo window saying needs recharge

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6805504

THE CHEESECAKE FACTORY

License Type: Permanent Food Service

140 UNIVERSITY TOWN CENTER DR #101, SARASOTA 34243

Inspection Date: 02/28/2020

Inspection Number: 2956971

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed gauge in red in kitchen bakery area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6905224

RED-EYE SPORTS TAVERN (STORE #01)

License Type: Permanent Food Service

855 E STATE ROAD 434 UNIT 1133-35, WINTER SPRINGS 32708

Inspection Date: 02/26/2020

Inspection Number: 2938345

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. At the back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6902309

CHENG'S CHINESE RESTAURANT

License Type: Permanent Food Service

3705 LAKE EMMA ROAD, LAKE MARY 32746

Inspection Date: 02/26/2020

Inspection Number: 2959447

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: ALVIS, DAVID

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. In the dining room, exit door blocked by boxes and decorative screen

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.