

Alachua County

License Number: 1103455

PIZZA IN THE HOOD

License Type: Permanent Food Service

14212 NW 154TH AVE, ALACHUA 32615

Inspection Date: 03/03/2020

Inspection Number: 2960090

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: HENTGES, JUDY

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Propane tank stored inside next to the ice machine.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Broward County

License Number: 1621899		HAVANA 1957	
License Type: Permanent Food Service		14571 SW 5 ST, PEMBROKE PINES 33027	
Inspection Date: 03/04/2020	Inspection Number: 2908471	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SMITH, CORETTA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. Observed 5 x 16 lbs propane tanks in kitchen near back exit door. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1624429		LALLOS	
License Type: Permanent Food Service		1401 NW 39 TERRACE, LAUDERHILL 33313	
Inspection Date: 03/04/2020	Inspection Number: 2976223	Inspection Type: Complaint Full	Inspection Disposition: Administrative complaint recommended
Inspector Name: LEWIS, LYNDEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1621952		BLUE WATER RESTAURANT AND BAR	
License Type: Permanent Food Service		440 S SEABREEZE BLVD, FORT LAUDERDALE 33316	
Inspection Date: 03/05/2020	Inspection Number: 2935146	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: EVANS, EUGENE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 1621955		SEABREEZE POOL BAR	
License Type: Permanent Food Service		440 S SEABREEZE BLVD, FORT LAUDERDALE 33316	
Inspection Date: 03/05/2020	Inspection Number: 2935072	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: EVANS, EUGENE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Broward County

License Number: 1623647

COURTYARD FT LAUDERDALE BEACH

License Type: Permanent Food Service

440 S SEABREEZE BLVD, FORT LAUDERDALE 33316

Inspection Date: 03/05/2020

Inspection Number: 2935103

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: EVANS, EUGENE

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.61C-1.004(9) FAC Reporting: (9) Heating and ventilation
- The heating and ventilation system shall be kept in
good repair or be installed to maintain a minimum of 68
degrees Fahrenheit throughout the building. The
insurance inspector's boiler report is required annually
for power boilers and high pressure/high temperature
boilers and biannually for low pressure steam or vapor
heating boilers and shall be posted in the boiler room.
For reporting purposes only.

License Number: 1622090

MC DONALDS L/C #009-2321

License Type: Permanent Food Service

11200 SR 84, DAVIE 33325

Inspection Date: 03/05/2020

Inspection Number: 2895772

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: SEWELL, SANGAY

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes.

Exit door blocked with garbage bin next to three compartment sink. Operator
removed61C-1.004(9) FAC: (9 Reporting: Means of access,
including entrances, halls, and stairways, must permit
unobstructed travel at all times and shall be clean,
ventilated and well-lighted day and night. Hall and stair
runners shall be kept in good condition. Railways, as
defined in 61C-1.001(23), F.A.C., shall be installed on
all stairways and around all porches and steps. For
reporting purposes only.

Dade County

License Number: 2336085		THE HALAL GUYS	
License Type: Permanent Food Service		1010 BRICKELL AVE CU1, MIAMI 33131	
Inspection Date: 03/02/2020	Inspection Number: 2970479	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HENLEY, LATONYA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed mop bucket blocking the back door. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2334027		PLATE	
License Type: Permanent Food Service		2105 CORAL WAY, MIAMI 33145	
Inspection Date: 03/02/2020	Inspection Number: 2972819	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2330523		MI LINDO ECUADOR	
License Type: Permanent Food Service		8726 NW 26 ST UNIT 18, MIAMI 33172	
Inspection Date: 03/06/2020	Inspection Number: 2938222	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed two propane tanks inside establishment, in dry storage on second floor.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2316174		SPICE MAGIC	
License Type: Permanent Food Service		10720 W FLAGLER ST #15, SWEETWATER 33174	
Inspection Date: 03/06/2020	Inspection Number: 2928529	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher inside kitchen in recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2613627 SUBWAY #32884
 License Type: Permanent Food Service 3000 MONCRIEF RD #1, JACKSONVILLE 32209

Inspection Date: 03/03/2020 Inspection Number: 2905473 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: YOUNG, JENNIFER

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. **Repeat Violation**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2613110 LEVANT GRILL & HOOKAH LOUNGE
 License Type: Permanent Food Service 9041 SOUTHSIDE BLVD #180, JACKSONVILLE 32256

Inspection Date: 03/03/2020 Inspection Number: 2976330 Inspection Type: Complaint Full Inspection Disposition: Warning Issued
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher near bar area in red zone. Manager stated that company is coming out to replace.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher near bar area in red zone. Manager stated that company is coming out to replace. - From follow-up inspection 2020-03-04: Still th	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3911456

JAPANESE KITCHEN DOSUNCO

License Type: Permanent Food Service

3310 W KENNEDY BLVD, TAMPA 33609

Inspection Date: 03/05/2020

Inspection Number: 2936289

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: KLUSENDORF, JEANNE

Violation Code

Observation

Violation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5104490

LAKEWOOD RANCH GOLF & CC MAIN

License Type: Permanent Food Service

7650 LEGACY BLVD, BRADENTON 34202

Inspection Date: 03/06/2020

Inspection Number: 2965277

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed on extinguisher near dish area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301058

ROMA PIZZA OF PALM CITY

License Type: Permanent Food Service

978 MARTIN DOWNS BLVD, PALM CITY 34990

Inspection Date: 03/04/2020

Inspection Number: 2956814

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in back storage room.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5809616		AIN'T MISS BEHAVING & BEACH BAR	
License Type: Permanent Food Service		1550 SR 436, WINTER PARK 32792	
Inspection Date: 03/04/2020	Inspection Number: 2957328	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5802942		GONZALEZ NUMERO UNO	
License Type: Permanent Food Service		2499 S ORANGE AVE, ORLANDO 32806	
Inspection Date: 03/03/2020	Inspection Number: 2966595	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DIOP, DONALD			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Refrigerator in kitchen impeding access to exit door.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5812934		LANDSCAPE OF FLAVORS/THE DROP OFF	
License Type: Permanent Food Service		1850 ANIMATION WAY, LAKE BUENA VISTA 32830	
Inspection Date: 03/03/2020	Inspection Number: 2967544	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SPEIGHTS, BLANCHIE MACHELLE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certification expired 2/22/2020 recommend Chef to notify engineering.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 5814892		JUSTINS CARIBBEAN FUSION RESTAURANT LLC	
License Type: Permanent Food Service		6700 CONROY WINDERMERE RD, #120, ORLANDO 32835	
Inspection Date: 03/06/2020	Inspection Number: 2969066	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: CONNOLLY, MADELINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Walk in cooler light switch	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Osceola County

License Number: 5907980

WORLD PREMIER

License Type: Permanent Food Service

1991 W BUENA VISTA DR, LAKE BUENA VISTA 32830

Inspection Date: 03/05/2020

Inspection Number: 2960336

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SPEIGHTS, BLANCHIE MACHELLE

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Boiler certification are expired also have incorrect Resort (posted Music)

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Palm Beach County

License Number: 6020330

BAGEL BISTRO

License Type: Permanent Food Service

173 N. US HIGHWAY 1, TEQUESTA 33469

Inspection Date: 03/02/2020

Inspection Number: 2947433

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.kitchen **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6101954		CHECKERS DRIVE IN RESTAURANT	
License Type: Permanent Food Service		12600 S US HWY 301, DADE CITY 33525	
Inspection Date: 03/05/2020	Inspection Number: 2964431	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: BEAULIEU, STEPHANIE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6113489		CRISTIANOS PIZZA AND PASTA	
License Type: Permanent Food Service		5743 MAIN ST, NEW PORT RICHEY 34652	
Inspection Date: 02/29/2020	Inspection Number: 2976239	Inspection Type: Routine - Food	Inspection Disposition: Emergency Order Callback Not Complied
Inspector Name: TORRACO, MARIANNE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. In kitchen by reach in cooler - From follow-up inspection 2020-02-29: **Time Extended**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
Inspection Date: 03/02/2020	Inspection Number: 2976239	Inspection Type: Routine - Food	Inspection Disposition: Emergency Order Callback Time Extension
Inspector Name: TORRACO, MARIANNE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. In kitchen by reach in cooler - From follow-up inspection 2020-02-29: **Time Extended** - From follow-up inspection 2020-03-02: **Time Extended**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 6102388		JOHNNY'S PIZZA	
License Type: Permanent Food Service		13229 US HWY 19, HUDSON 34667	
Inspection Date: 03/06/2020	Inspection Number: 2972804	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: TORRACO, MARIANNE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-04-4	Establishment did not report seating change that affects the license fee, Clean Indoor Air Act, sewage system approval or other related requirements. 35 seats present, licensed for 10. Reviewed with Dune in Plan Review on 1-27-2020. Seating increase for	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.	

Pinellas County

License Number: 6213118		BOULEVARD BURGERS & TAP HOUSE	
License Type: Permanent Food Service		5905 GULF BLVD, ST.PETE BEACH 33706	
Inspection Date: 03/03/2020	Inspection Number: 2976474	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: DAY-WALKER, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in prep/ dish area in red recharge zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 6207290		SHERATON POOLSIDE CAFE	
License Type: Permanent Food Service		1160 GULF BLVD, CLEARWATER BCH 33767	
Inspection Date: 03/04/2020	Inspection Number: 2954026	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Two expired. **Repeat Violation**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 6210240		MAINSTAY TAVERN	
License Type: Permanent Food Service		1160 GULF BLVD, CLEARWATER BCH 33767	
Inspection Date: 03/04/2020	Inspection Number: 2954072	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: KOUSTIS, TIMOTHY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Two expired. **Repeat Violation**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 6214875		LITTLE THAI CAFE	
License Type: Permanent Food Service		1810 S PINELLAS AVE 1, TARPON SPRINGS 34689	
Inspection Date: 03/05/2020	Inspection Number: 2974652	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PIATT, PAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only. Unlocked **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

Putnam County

License Number: 6400805

SHRIMP 'R' US & MORE

License Type: Permanent Food Service

765 3 AVE, WELAKA 32193

Inspection Date: 03/04/2020

Inspection Number: 2967888

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANCO, RICHARD

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher gauge at fry station is in the red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6805250

MEXICO LINDO ST ARMANDS

License Type: Permanent Food Service

40 S BLVD OF THE PRESIDENTS, SARASOTA 34236

Inspection Date: 03/02/2020

Inspection Number: 2930717

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: VITKUN, RONALD

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Observed chairs blocking access to emergency exit left of wait station.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6803462

GOLF SERENOA LLC

License Type: Permanent Food Service

6773 SERENOA DR, SARASOTA 34241

Inspection Date: 03/04/2020

Inspection Number: 2927195

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: MOREHEAD, PHILIP

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only in back storage area by fire control panel

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Johns County

License Number: 6502217

THE COMMANDER'S SHELLFISH CAMP

License Type: Permanent Food Service

7579 A1A S, SAINT AUGUSTINE 32080

Inspection Date: 03/06/2020

Inspection Number: 2913719

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: FRANCO, RICHARD

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Fire extinguisher next to hand washing sink in kitchen is in the gauges red zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.