

**Brevard County**

License Number: 1502644 COURTYARD BY MARRIOTT  
 License Type: Permanent Food Service 2101 W NEW HAVEN AVE, WEST MELBOURNE 32904

Inspection Date: 03/11/2020 Inspection Number: 2951427 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: MITTEN, JAMES

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Expired 11/29/19.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1506313 MOM & POPS BAR AND GRILL  
 License Type: Permanent Food Service 900 N ATLANTIC AVE STE D, COCOA BEACH 32931

Inspection Date: 03/09/2020 Inspection Number: 2960251 Inspection Type: Routine - Food Inspection Disposition: Call Back - Complied  
 Inspector Name: HICKS, GEORGE RANDY

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	- From initial inspection : No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. - From follow-up inspection 2020-01-07: **Time Extended** - From follow-up inspection 2020-02-06: **Time Extended** - From follow-up inspection 2020-03-09: **Time Extended**	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1506536 HOKKAIDO SUSHI INC OF MERRITT ISLAND  
 License Type: Permanent Food Service 125 E MERRITT ISLAND CSWY #115, MERRITT ISLAND 32952

Inspection Date: 03/11/2020 Inspection Number: 2943290 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action  
 Inspector Name: FRANZ, LINDA

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back stock room, exit blocked by case of bleach, cO2 tanks and scooter, corrected by operator **Corrected On-Site**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Broward County**

License Number: 1621436		ORCHID CONCESSIONS GULFSTRM PK RACING ASSC INC	
License Type: Permanent Food Service		901 S FEDERAL HWY, HALLANDALE 33009	
Inspection Date: 03/09/2020	Inspection Number: 2967177	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GANPAT, INDAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke .Notified Fire AHJ. For reporting purposes only. Fire Marshall came during inspection. <b>**Corrective Action Taken**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1624530		DANDEE DONUT	
License Type: Permanent Food Service		3101 N STATE RD 7, MARGATE 33063	
Inspection Date: 03/13/2020	Inspection Number: 2958617	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GOLDMAN, BARRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Mini fryer at to go station - operator removed. Egg maker - fried eggs made uncovered with butter - reviewed with operator the egg maker must be covered during cooking. <b>**Corrective Action Taken**</b>	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1618466		PI BON GOU	
License Type: Permanent Food Service		2551 N DIXIE HWY, POMPANO BEACH 33064	
Inspection Date: 03/10/2020	Inspection Number: 2957166	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: GONZALEZ, DENNIS			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 1619698		MOON THAI & JAPANESE REST	
License Type: Permanent Food Service		9637 WESTVIEW DR, CORAL SPRINGS 33076	
Inspection Date: 03/10/2020	Inspection Number: 2885731	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: BANNIGAN, TIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only.  - Nearly half of the width of the rear emergency egress hallway is obstructed by shelving and dry food storage.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

**Citrus County**

License Number: 1901262

ROCCOS PIZZA & CAFE

License Type: Permanent Food Service

6612 GULF TO LAKE HWY, CRYSTAL RIVER 34429

Inspection Date: 03/10/2020

Inspection Number: 2976117

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

49-01-4

Establishment increased seating without providing written approval from the local fire authority and wastewater provider. License shows 36 seats, inspector count is - 42 seats inside dining room, 60 in side dining room, 20 outside \*\*Repeat Violation\*\*

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

**Columbia County**

License Number: 2200564

KRYSTALS

License Type: Permanent Food Service

2383 W US HWY 90, LAKE CITY 32055

Inspection Date: 03/10/2020

Inspection Number: 2976784

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Fire extinguisher next to hand washing sink in back of kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2326649	EL CARIBE CAFETERIA		
License Type: Permanent Food Service	299 WEST 27TH STREET, HIALEAH 33010		
Inspection Date: 03/11/2020	Inspection Number: 2955351	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed under stairs in kitchen area.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2328175	WENDY'S #2434		
License Type: Permanent Food Service	1100 NW 54 ST, MIAMI 33127		
Inspection Date: 03/12/2020	Inspection Number: 2977113	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MARTIN, RAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Observed rear exit door blocked by small step ladder and card board boxes located in rear of kitchen.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2330505	SAMAN AREPAS BISTRO		
License Type: Permanent Food Service	4709 NW 79 AVE, DORAL 33166		
Inspection Date: 03/12/2020	Inspection Number: 2958226	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HERNANDEZ, NILYAM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Observed in back area by mop sink wall.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2333600	LA MOON CREPES		
License Type: Permanent Food Service	12891 SW 42 ST, MIAMI 33175		
Inspection Date: 03/09/2020	Inspection Number: 2976339	Inspection Type: Food-Licensing Inspection	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, ERIK			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed extinguisher in recharge zone in front of restroom.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Dade County**

License Number: 2334280

PANNA CAFE EXPRESS

License Type: Permanent Food Service

11402 NW 41 ST STE 112, MIAMI 33178

Inspection Date: 03/13/2020

Inspection Number: 2967132

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: WILLIAMS, ALFREDA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2325070

TACO BELL #15451

License Type: Permanent Food Service

7350 SW 117 AVE, MIAMI 33183

Inspection Date: 03/10/2020

Inspection Number: 2940388

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MARTIN, RAUL

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Class K extinguisher

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2614021

THE CAPITAL GRILLE #8029

License Type: Permanent Food Service

5197 BIG ISLAND DR, JACKSONVILLE 32246

Inspection Date: 03/13/2020

Inspection Number: 2960234

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GONZALEZ, MAYRA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.  
For reporting purposes only.61C-1.004(9) FAC Reporting: (9) Heating and ventilation  
- The heating and ventilation system shall be kept in  
good repair or be installed to maintain a minimum of 68  
degrees Fahrenheit throughout the building. The  
insurance inspector's boiler report is required annually  
for power boilers and high pressure/high temperature  
boilers and biannually for low pressure steam or vapor  
heating boilers and shall be posted in the boiler room.  
For reporting purposes only.

License Number: 2613886

OTAKI JAPANESE STEAKHOUSE &amp; SUSHI BAR

License Type: Permanent Food Service

7860 GATE PKWY #119, JACKSONVILLE 32256

Inspection Date: 03/11/2020

Inspection Number: 2897741

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
In dining room at middle hibachi station509.032(2)(d) FS Reporting: (d) The division, or its  
agent, shall notify the local firesafety authority or the  
State Fire Marshal of any readily observable violation of  
a rule adopted under chapter 633 which relates to public  
lodging establishments or public food establishments,  
and the identification of such violation does not require  
any firesafety inspection certification. For reporting  
purposes only.

**Hernando County**

License Number: 3700323

WILLY'S TROPICAL BREEZE

License Type: Permanent Food Service

PINE ISLAND PARK, BROOKSVILLE 34607

Inspection Date: 03/13/2020

Inspection Number: 2883790

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TORRACO, MARIANNE

Violation Code

Observation

Violation Citation

49-04-4

\*Establishment increased seating without municipal sewer approval.  
 \*Establishment did not report seating change that affects the license fee, Clean Indoor Air Act, sewage system approval or other related requirements.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

42 seats present in deck . Seating increase for emailed.



**Hillsborough County**

License Number: 3918244

ANDREW PANDREW'S JERK HUT A JAMAICAN DRIVE UP EATERY

License Type: Permanent Food Service

1045 E HILLSBOROUGH AVE, TAMPA 33603

Inspection Date: 03/09/2020

Inspection Number: 2925673

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: MARQUETTI, JESSICA

Violation CodeObservationViolation Citation

49-05-4 - From initial inspection : Establishment currently licensed as a non seating has 20 seats outside . For reporting purposes only. **\*\*Repeat Violation\*\*** - From follow-up inspection 2020-03-09: **\*\*Admin Complaint\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3911112

MAX'S CAFE

License Type: Permanent Food Service

3802 W MARTIN LUTHER KING BLVD, TAMPA 33614

Inspection Date: 03/10/2020

Inspection Number: 2896801

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: EHLERS, MICHAEL

Violation CodeObservationViolation Citation

45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-04-4 - From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2020-03-12: Not done yet. **\*\*Time Extended\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3918192

CHINA 1

License Type: Permanent Food Service

4350 W WATER AVE STE 103, TAMPA 33614

Inspection Date: 03/13/2020

Inspection Number: 2967670

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation CodeObservationViolation Citation

49-05-4 For reporting purposes only. Licensed as NOST, currently has 8 seats. Operator states he has called city and fire and is waiting for them to come do their inspection. **\*\*Corrective Action Taken\*\*** **\*\*Repeat Violation\*\***

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4604450

MARIA'S PIZZERIA & RESTAURANT

License Type: Permanent Food Service

1224 SE 46 LN, CAPE CORAL 33904

Inspection Date: 03/11/2020

Inspection Number: 2960912

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SOMMERS, KARA

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Cookline/dishwash area. \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Okaloosa County**

License Number: 5603442

THE PANCAKERY

License Type: Permanent Food Service

960 HWY 98 E STE 104, DESTIN 32541

Inspection Date: 03/12/2020

Inspection Number: 2966633

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: STEINMAN, MARC

Violation Code

Observation

Violation Citation

45-02-4      Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Kitchen next to hand wash sink

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5810663		SUBWAY #483	
License Type: Permanent Food Service		4440 CURRYFORD RD, ORLANDO 32812	
Inspection Date: 03/12/2020	Inspection Number: 2884717	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PLEICONES, KIM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-04-4	Exit door locked. For reporting purposes only. Back kitchen exit door has metal bar lock on door during hours of operation	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 5812591		JOE'S CRAB SHACK	
License Type: Permanent Food Service		8400 INTERNATIONAL DR, ORLANDO 32819	
Inspection Date: 03/09/2020	Inspection Number: 2947954	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: MANTI, KATHRYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	K class Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5814659		BOTEKO DO MANOLO	
License Type: Permanent Food Service		7653 INTERNATIONAL DR SUITE 105, ORLANDO 32819	
Inspection Date: 03/10/2020	Inspection Number: 2936422	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MANTI, KATHRYN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only. Found under hand sink near office **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 5811485		TACO BELL/LONG JOHN SILVERS	
License Type: Permanent Food Service		16880 E COLONIAL DR, ORLANDO 32820	
Inspection Date: 03/11/2020	Inspection Number: 2964302	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THORNCROFT, ROBERT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. At the back door	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Orange County**

License Number: 5813536

FONDA EL CRIOLLITO RESTAURANT

License Type: Permanent Food Service

4701B SOUTH SEMORAN BLVD, UNIT 10, ORLANDO 32822

Inspection Date: 03/10/2020

Inspection Number: 2962482

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

46-01-4 - From initial inspection : Marked exit/path to marked exit blocked,child chairs stored in front of emergency exit.. For reporting purposes only. - From follow-up inspection 2020-03-10: \*\*Time Extended\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

46-01-4 Marked exit/path to marked exit blocked,child chairs stored in front of emergency exit.. For reporting purposes only.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5813759

BUFFALO WILD WINGS

License Type: Permanent Food Service

6819 S SEMORAN BLVD, ORLANDO 32822

Inspection Date: 03/11/2020

Inspection Number: 2959154

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked empty boxes by back door. For reporting purposes only.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5810596

ALI BABA'S DELI

License Type: Permanent Food Service

7624 SUN VISTA WAY, ORLANDO 32822-7501

Inspection Date: 03/13/2020

Inspection Number: 2964382

Inspection Type: Routine - Food

Inspection Disposition: Warning  
Issued

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked, mop bucket and ladder. For reporting purposes only. \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Orange County**

License Number: 5814892

JUSTINS CARIBBEAN FUSION RESTAURANT LLC

License Type: Permanent Food Service

6700 CONROY WINDERMERE RD, #120, ORLANDO 32835

Inspection Date: 03/10/2020

Inspection Number: 2969066

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Extension given, pending

Inspector Name: CONNOLLY, MADELINE

Violation CodeObservationViolation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only.

Walk in cooler light switch - From follow-up inspection 2020-03-10: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5811110

TAKUMI

License Type: Permanent Food Service

8933 W COLONIAL DR, OCOEE 34761

Inspection Date: 03/09/2020

Inspection Number: 2943091

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: GREENE, MARVIN

Violation CodeObservationViolation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. K extinguisher by back kitchen exit door. - From follow-up inspection 2020-03-09: \*\*Time Extended\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6021589

LITTLE CAESARS

License Type: Permanent Food Service

23011 STATE RD 7, BOCA RATON 33428

Inspection Date: 03/09/2020

Inspection Number: 2976900

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BANNIGAN, TIM

Violation CodeObservationViolation Citation

46-04-4 Exit door locked. For reporting purposes only.  
- rear exit door.

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 6013858

GOLDEN CORRAL

License Type: Permanent Food Service

389 WINCHESTER PARK BLVD, BOYNTON BEACH 33436

Inspection Date: 03/12/2020

Inspection Number: 2977090

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation CodeObservationViolation Citation

48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only. Found for the second time no boiler certification available at time of inspection

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Pasco County**

License Number: 6113648

CULVERS OF WIREGRASS

License Type: Permanent Food Service

28831 ST RD 56, WESLEY CHAPEL 33543

Inspection Date: 03/13/2020

Inspection Number: 2963072

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: AIELLO, ROCCI

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6113573

EL CERRITO MEXICAN RESTAURANT AND GRILL

License Type: Permanent Food Service

6911 CONGRESS ST, NEW PORT RICHEY 34653

Inspection Date: 03/09/2020

Inspection Number: 2976594

Inspection Type: Complaint Full

Inspection Disposition: Warning  
Issued

Inspector Name: TORRACO, MARIANNE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
2 mop buckets , ladder, cases of to go supplies, Corrected on Site: removed  
\*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.



**Pinellas County**

License Number: 6217758

SHAKER &amp; PEEL

License Type: Permanent Food Service

3150 TAMPA RD STE 12, OLDSMAR 34677

Inspection Date: 03/10/2020

Inspection Number: 2942712

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PEARCE, LAURA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6214668

FAIRWAY PIZZA &amp; SPORTS PAGE PUB

License Type: Permanent Food Service

2901 ALT 19 NORTH, PALM HARBOR 34683

Inspection Date: 03/12/2020

Inspection Number: 2976943

Inspection Type: Complaint Full

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PIATT, PAUL

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Near the door and ice machine area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Seminole County**

License Number: 6903751

OVIEDO SPORTS COMPLEX

License Type: Permanent Food Service

1251 E BROADWAY, OVIEDO 32765

Inspection Date: 03/10/2020

Inspection Number: 2888164

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: THORNCROFT, ROBERT

Violation Code

Observation

Violation Citation

47-01-4

Observed missing electrical plate For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.