

Alachua County

License Number: 1102843

CARIBBEAN QUEEN

License Type: Permanent Food Service

507 NW 5 AVE, GAINESVILLE 32601

Inspection Date: 03/17/2020

Inspection Number: 2952893

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Admin. complaint recommended

Inspector Name: WEATHERS, TIM

Violation Code

Observation

Violation Citation

48-04-4

- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 1 tank in back room. - From follow-up inspection 2020-01-14: Propane tank outside. - From follow-up inspection 2020-03-17: Tank outside.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Brevard County

License Number: 1506379		JERSEY MIKE'S SUBS #13052	
License Type: Permanent Food Service		90 W HIBISCUS BLVD., MELBOURNE 32901	
Inspection Date: 03/16/2020	Inspection Number: 2952472	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MITTEN, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back door blocked by trash cans **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

License Number: 1502268		THAI KITCHEN	
License Type: Permanent Food Service		1729 N WICKHAM RD, MELBOURNE 32935	
Inspection Date: 03/18/2020	Inspection Number: 2977115	Inspection Type: Complaint Full	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HICKS, GEORGE RANDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. removed from indoors. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 1505974		CHARLIE AND JAKE'S BARBECUE	
License Type: Permanent Food Service		490 E EAU GALLIE BLVD, INDIAN HARBOUR BEACH 32937	
Inspection Date: 03/19/2020	Inspection Number: 2934049	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: HICKS, GEORGE RANDY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Broward County

License Number: 1621146

LA CARRETA RESTAURANT

License Type: Permanent Food Service

14791 MIRAMAR PKWY, MIRAMAR 33027

Inspection Date: 03/18/2020

Inspection Number: 2891033

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: SMITH, CORETTA

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. Observed last boiler certification dated 09/13/2017, jurisdiction # 021619. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 1618285

JERSEY JOHNS PIZZERIA

License Type: Permanent Food Service

8648 GRIFFIN RD, COOPER CITY 33328

Inspection Date: 03/18/2020

Inspection Number: 2949342

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked with boxes.

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Clay County

License Number: 2001181

AKAYA GRILL & SUSHI

License Type: Permanent Food Service

1075 OAKLEAF PLANTATION PKWY S #106, ORANGE PARK 32065

Inspection Date: 03/16/2020

Inspection Number: 2975480

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: BIAVA, GRANT

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Under hand wash station next to triple sink, gauge in recharge state.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001330

PAPA MURPHY'S PIZZA FL067

License Type: Permanent Food Service

2640 BLANDING BLVD STE 212, MIDDLEBURG 32068-9107

Inspection Date: 03/17/2020

Inspection Number: 2977465

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BIAVA, GRANT

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Under phone and monitor in prep area, extinguisher in recharge state.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2001118

LITTLE CAESARS PIZZA

License Type: Permanent Food Service

661 BLANDING BLVD #514, ORANGE PARK 32073

Inspection Date: 03/17/2020

Inspection Number: 2891727

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BIAVA, GRANT

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only.
Uncovered junction box inside walk in cooler, wires exposed to water from condensation unit.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2317295		HOLIDAY INN	
License Type: Permanent Food Service		7707 NW 103 ST, HIALEAH GARDENS 33016	
Inspection Date: 03/17/2020	Inspection Number: 2958905	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: CRUZ, EDGAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2324358		MIS CHULAS RESTAURANT SABOR KATRACHO MEX	
License Type: Permanent Food Service		29363 SW 152 AVE, HOMESTEAD 33033	
Inspection Date: 03/20/2020	Inspection Number: 2954736	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GONZALEZ, RICARDO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2331495		TENTACIONES GOURMET	
License Type: Permanent Food Service		2500 NW 79 AVE STE-100, DORAL 33122	
Inspection Date: 03/19/2020	Inspection Number: 2967684	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SANCHEZ, JAVIER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2358967		LA ROCA FOODS	
License Type: Mobile Food Dispensing Vehicle		1860 NW 17 AVE, MIAMI 33125	
Inspection Date: 03/19/2020	Inspection Number: 1218814	Inspection Type: Routine - Food	Inspection Disposition: Administrative complaint recommended
Inspector Name: STUBBS, CHRISTINE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2336147	TAJ MAHAL INDIAN CUISINE		
License Type: Permanent Food Service	185 NW 36 ST, MIAMI 33127		
Inspection Date: 03/19/2020	Inspection Number: 2954152	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: MARTIN, RAUL			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Located next to hand wash sink	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2333285	G R COIN LAUNDRY & CAFETERIA		
License Type: Permanent Food Service	438 SW 8 AVE, MIAMI 33130		
Inspection Date: 03/16/2020	Inspection Number: 2938284	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GARCIA, B OSCAR			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2333517	SUVICHE SOBE		
License Type: Permanent Food Service	1119 16TH ST, MIAMI BEACH 33139		
Inspection Date: 03/18/2020	Inspection Number: 2944205	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ALVAREZ, MARGARET			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

License Number: 2335992	LA QUINTA INN & SUITES #4040		
License Type: Permanent Food Service	3501 NW 42 AVE LEJEUNE RD, MIAMI 33142		
Inspection Date: 03/19/2020	Inspection Number: 2961410	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: AZPURUA, JULIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-02-5	Insurance inspector boiler report not posted in boiler room. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

Dade County

License Number: 2358832

ATEGO FOOD & SERVICES CORP

License Type: Mobile Food Dispensing Vehicle

13920 SW 47 ST #103, MIAMI 33175

Inspection Date: 03/19/2020

Inspection Number: 1217843

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: AZPURUA, JULIO

Violation CodeObservationViolation Citation

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed next to driver seat of mobile unit. - From follow-up inspection 2020-03-19: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed next to driver seat of mobile unit.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2334280

PANNA CAFE EXPRESS

License Type: Permanent Food Service

11402 NW 41 ST STE 112, MIAMI 33178

Inspection Date: 03/16/2020

Inspection Number: 2967132

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: MARTIN, RAUL

Violation CodeObservationViolation Citation

45-02-4 - From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. - From follow-up inspection 2020-03-16: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2333474

AVENTURA CAFE

License Type: Permanent Food Service

21000 W DIXIE HWY, MIAMI 33180

Inspection Date: 03/16/2020

Inspection Number: 2967163

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: TAYLOR, JOHN

Violation CodeObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Located near back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2336460

CHIPOTLE #3383

License Type: Permanent Food Service

1700 NW 117 PLACE, SUITE 101, MIAMI 33182

Inspection Date: 03/20/2020

Inspection Number: 2969276

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, ERIK

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed extinguisher by exterior door in recharge zone.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615293

9 BALL HEAVEN

License Type: Permanent Food Service

2777 UNIVERSITY BLVD W UNIT 12, JACKSONVILLE 32217

Inspection Date: 03/16/2020

Inspection Number: 2912540

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JEFFERS, MARY-BETH

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Emergency exit at left of bar blocked by banquet equipment.
Also, emergency exit next to hallway of alcohol stock room blocked by cases of beverages and a cabinet.

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

46-04-4

Exit door locked. For reporting purposes only.
Emergency exit door in hallway near office has slider lock. ****Repeat Violation****

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2613943

SHERATON JACKSONVILLE HOTEL

License Type: Permanent Food Service

10605 DEERWOOD PARK BLVD, JACKSONVILLE 32256

Inspection Date: 03/20/2020

Inspection Number: 2920933

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ANDERSON, EDWARD

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only. Jurisdiction 093815 exp. date 1/18/2020. Engineer stated boiler has been inspected, no current boiler certificate.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Hillsborough County

License Number: 3952841	TACO HIDALGO LLC
License Type: Mobile Food Dispensing Vehicle	2919 WASHINGTON RD, VALRICO 33594
Inspection Date: 03/17/2020	Inspection Number: 1222851
Inspector Name: CANNELLA, MARK	Inspection Type: Food-Licensing Inspection
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3903008	GIRL AND A GRILL LLC
License Type: Permanent Food Service	4330 N NEBRASKA AVE, TAMPA 33603
Inspection Date: 03/18/2020	Inspection Number: 2971649
Inspector Name: COLEMAN, TONYA	Inspection Type: Food-Licensing Inspection
	Inspection Disposition: Call Back - Admin. complaint recommended
<u>Violation Code</u>	<u>Observation</u>
45-06-4	- From initial inspection : Applied as a non seating and currently has two picnic tables outside and 4 bar stools inside. Operator plans on adding more seats. For reporting purposes only. - From follow-up inspection 2020-03-18: **Admin Complaint**
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3906785	ITALIAN DREAM GROUP INC
License Type: Permanent Food Service	4300 W CYPRESS ST, TAMPA 33607
Inspection Date: 03/19/2020	Inspection Number: 2912653
Inspector Name: FEDERORVITCH, CASEY	Inspection Type: Routine - Food
	Inspection Disposition: Call Back - Complied
<u>Violation Code</u>	<u>Observation</u>
45-04-4	- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Flat top grill, deep fryers. Notified Fire AHJ. For reporting purposes only. - From follow-up inspection 2020-01-23: **Time Extended** - From follow-up inspection 2020-03-19: **Time Extended**
	<u>Violation Citation</u>
	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 3917970	TACOS 4G INC
License Type: Permanent Food Service	4349 W WATER AVE, TAMPA 33614
Inspection Date: 03/19/2020	Inspection Number: 2960800
Inspector Name: EHLERS, MICHAEL	Inspection Type: Routine - Food
	Inspection Disposition: Inspection Completed - No Further Action
<u>Violation Code</u>	<u>Observation</u>
46-04-4	Exit door locked. For reporting purposes only. Chair and boxes blocking back exit. Items moved. **Corrected On-Site**
	<u>Violation Citation</u>
	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Lake County

License Number: 4508727

MOUNT DORA HOSPITALITY LLC

License Type: Permanent Food Service

142 EAST 4TH AVENUE, MOUNT DORA 32757

Inspection Date: 03/20/2020

Inspection Number: 2944633

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MONTGOMERY, DOREEN

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 4508734

1921 MOUNT DORA

License Type: Permanent Food Service

142 E 4TH AVE, MOUNT DORA 32757

Inspection Date: 03/20/2020

Inspection Number: 2944617

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: MONTGOMERY, DOREEN

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Leon County

License Number: 4703344

LEOLA'S CRAB SHACK

License Type: Permanent Food Service

710-C WEST ORANGE AVENUE, TALLAHASSEE 32310

Inspection Date: 03/17/2020

Inspection Number: 2956975

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: TAKEH, NADEGE

Violation Code

Observation

Violation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Manatee County

License Number: 5104539

RUBY TUESDAY 7157

License Type: Permanent Food Service

8306 TOURIST CENTER DR, BRADENTON 34201

Inspection Date: 03/19/2020

Inspection Number: 2951402

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed on fire extinguisher near rest room hallway.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301821 LURES RIVERFRONT RESTAURANT
 License Type: Permanent Food Service 3330 NE INDIAN RIVER DR, JENSEN BEACH 34957

Inspection Date: 03/16/2020 Inspection Number: 2953764 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PETROW, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. One Fire extinguisher at bar.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5301309 DUNKIN DONUTS/BASKIN ROBBINS
 License Type: Permanent Food Service 6001 SE FEDERAL HWY, STUART 34997

Inspection Date: 03/20/2020 Inspection Number: 2977631 Inspection Type: Complaint Full Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PETROW, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher in back kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Okaloosa County

License Number: 5603406

FAIRFIELD INN AND SUITES

License Type: Permanent Food Service

19001 EMERALD COAST PKWY, DESTIN 32541

Inspection Date: 09/13/2019

Inspection Number: 2977613

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: STEINMAN, MARC

Violation Code

Observation

Violation Citation

48-01-5

OBSERVED: NO CURRENT INSURANCE INSPECTOR BOILER REPORT OR
BOILER CERTIFICATE AVAILABLE FOR BOILER.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation
- The heating and ventilation system shall be kept in
good repair or be installed to maintain a minimum of 68
degrees Fahrenheit throughout the building. The
insurance inspector's boiler report is required annually
for power boilers and high pressure/high temperature
boilers and biannually for low pressure steam or vapor
heating boilers and shall be posted in the boiler room.
For reporting purposes only.

Orange County

License Number: 5809869

EMBASSY SUITES ORLANDO DOWNTOWN

License Type: Permanent Food Service

191 E PINE ST, ORLANDO 32801

Inspection Date: 03/16/2020

Inspection Number: 2944271

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: QUINONES, ANTONIO

Violation CodeObservationViolation Citation48-01-5 No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only. **Corrected On-Site**61C-1.004(9) FAC Reporting: (9) Heating and ventilation
- The heating and ventilation system shall be kept in
good repair or be installed to maintain a minimum of 68
degrees Fahrenheit throughout the building. The
insurance inspector's boiler report is required annually
for power boilers and high pressure/high temperature
boilers and biannually for low pressure steam or vapor
heating boilers and shall be posted in the boiler room.
For reporting purposes only.48-02-5 Insurance inspector boiler report not posted in boiler room. For reporting purposes
only.61C-1.004(9) FAC Reporting: (9) Heating and ventilation
- The heating and ventilation system shall be kept in
good repair or be installed to maintain a minimum of 68
degrees Fahrenheit throughout the building. The
insurance inspector boiler report is required annually for
power boilers and high pressure or high temperature
boilers and biannually for low pressure steam or vapor
heating boilers and shall be posted in the boiler room.
For reporting purposes only.

License Number: 5804252

CAFE MADRID DELI & BAKERY

License Type: Permanent Food Service

4502 CURRY FORD RD, ORLANDO 32812

Inspection Date: 03/17/2020

Inspection Number: 2954697

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: DIOP, DONALD

Violation CodeObservationViolation Citation45-04-4 Use of cooking equipment producing grease laden vapors/smoke with no hood
suppression system installed. Notified Fire AHJ. For reporting purposes only. In
prep area room between kitchen and front service area. **Repeat Violation**509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Food cart
impeding access to kitchen rear exit door. **Corrected On-Site**61C-1.004(9) FAC: (9) Reporting: Means of access,
including entrances, halls, and stairways, must permit
unobstructed travel at all times and shall be clean,
ventilated and well-lighted day and night. Hall and stair
runners shall be kept in good condition. Railways, as
defined in 61C-1.001(23), F.A.C., shall be installed on
all stairways and around all porches and steps. For
reporting purposes only.

Orange County

License Number: 5807118

BOI BRAZIL CHURRASCARIA

License Type: Permanent Food Service

5668 INTERNATIONAL DR, ORLANDO 32819

Inspection Date: 03/17/2020

Inspection Number: 2968988

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: CONNOLLY, MADELINE

Violation CodeObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only in storage room

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

48-04-4 - From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only in storage room - From follow-up inspection 2020-03-18: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5807318

HUNGRY HOWIES 184

License Type: Permanent Food Service

7628 SUN VISTA WAY, ORLANDO 32822

Inspection Date: 03/13/2020

Inspection Number: 2925236

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: RULLAN, ALFONSO

Violation CodeObservationViolation Citation

46-01-4 Marked exit/path to marked exit blocked, mixer and Trashcan in front of an emergency exit, back door. For reporting purposes only.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Osceola County

License Number: 5910985

DUKE'S BREWHOUSE

License Type: Permanent Food Service

4037 13 ST, ST. CLOUD 34769

Inspection Date: 03/17/2020

Inspection Number: 2976931

Inspection Type: Complaint Full

Inspection Disposition: Warning Issued

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

45-02-4 Portable fire extinguisher gauge in red zone. For reporting purposes only. Near back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6008053

ANGELO'S CHICKEN & PIZZA

License Type: Permanent Food Service

155 TONEY PENNA DR, JUPITER 33458

Inspection Date: 03/19/2020

Inspection Number: 2958692

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.fire nozzles/not installed/oven side/operator will have serviced this week.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6212684

BAYOU CLUB

License Type: Permanent Food Service

7979 BAYOU CLUB BLVD, LARGO 33777

Inspection Date: 03/17/2020

Inspection Number: 2893929

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LANTIGUA, ROBERTO

Violation CodeObservationViolation Citation

48-02-5

Insurance inspector boiler report not posted in boiler room. For reporting purposes only. Operator posted updated boiler report.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector boiler report is required annually for power boilers and high pressure or high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 6217253

JOHNNYS TAPHOUSE & GRILL LLC

License Type: Permanent Food Service

224 E TARPON AVE, TARPON SPRINGS 34689

Inspection Date: 03/20/2020

Inspection Number: 2977547

Inspection Type: Complaint Full

Inspection Disposition: Call Back - Extension given, pending

Inspector Name: PIATT, PAUL

Violation CodeObservationViolation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. Class K in kitchen - From follow-up inspection 2020-03-20: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Class K in kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.