

**Broward County**

License Number: 1622590

CHIPOTLE MEXICAN GRILL #1502

License Type: Permanent Food Service

1736 N FEDERAL HWY, FORT LAUDERDALE 33305

Inspection Date: 04/08/2020

Inspection Number: 2978437

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MATTIELLO-ATASSI, MARIA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. FE by back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1621478

PANDA EXPRESS #1188

License Type: Permanent Food Service

5820 UNIVERSITY DR, DAVIE 33328

Inspection Date: 04/02/2020

Inspection Number: 2978212

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRAY, ANTHONY

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Observed exit door blocked with boxes \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Hernando County**

License Number: 3700703

CHECKERS RESTAURANT

License Type: Permanent Food Service

852 S BROAD ST, BROOKSVILLE 34601

Inspection Date: 04/08/2020

Inspection Number: 2978387

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MEAKINS, ALLISON

Violation Code

Observation

Violation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
 Box of pot and pan detergent  
 Box of high temp grill cleaner  
 sitting in front of the rear exit door

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.