

Broward County

License Number: 1619223

D & J FEEDING TREE RESTAURANT

License Type: Permanent Food Service

904 N 30 RD, HOLLYWOOD 33021

Inspection Date: 04/16/2020

Inspection Number: 2958333

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANN, JUSTIN

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Observed 4 - 4.5 gallon propane tanks inside establishment - dining room behind walk in cooler/freezer. Inspector will send inspection report to Hollywood Fire Marshall.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Clay County

License Number: 2001314

JAVA'S BREWIN

License Type: Permanent Food Service

3555 HIGHWAY 17 #12, ORANGE PARK 32003

Inspection Date: 04/15/2020

Inspection Number: 2910958

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
Near rear exit to establishment, gauge in recharge state

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2335319

PIOLA RESTAURANT

License Type: Permanent Food Service

1950 NW 87 AVE, DORAL 33172

Inspection Date: 04/14/2020

Inspection Number: 2946252

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 propane tanks in storage area larger than 2.7 lbs.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2615079

RIVER CITY BONOS

License Type: Permanent Food Service

731 DUVAL STATION RD, JACKSONVILLE 32218

Inspection Date: 04/14/2020

Inspection Number: 2952670

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: YOUNG, JENNIFER

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
15 lb propane tank used to fuel smoker

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613213

D & LP SUBS

License Type: Permanent Food Service

1409 3 ST S, JACKSONVILLE BEACH 32250

Inspection Date: 04/17/2020

Inspection Number: 2965992

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: HARTMANN, MICHELLE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.
Blocked by boxes on floor. Person in charge cleared path. **Corrected On-Site**

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Hillsborough County

License Number: 3910561

RIVIERA RESTAURANT

License Type: Permanent Food Service

14819 N DALE MABRY, TAMPA 336182027

Inspection Date: 04/16/2020

Inspection Number: 2968429

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: EHLERS, MICHAEL

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Trash can and box in front of back kitchen exit door.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 3915657

SPICE KITCHEN

License Type: Permanent Food Service

11653 COUNTRYWAY BLVD, TAMPA 33626

Inspection Date: 04/14/2020

Inspection Number: 2965266

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: BEACHAM, MICHELLE

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Operator removed the tank from premises. **Corrective Action Taken**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5812695 SUBWAY #47519
 License Type: Permanent Food Service 2823 S ORANGE AVE STE 140, ORLANDO 32806

Inspection Date: 04/15/2020 Inspection Number: 2899447 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PLEICONES, KIM

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Back kitchen exit door has metal bar on door during hours of operation **Corrected On-Site** **Repeat Violation**	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5800825 TABLA BAR AND GRILL
 License Type: Permanent Food Service 5827 CARAVAN CT, ORLANDO 328197901

Inspection Date: 04/14/2020 Inspection Number: 2965502 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: CONNOLLY, MADELINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. Cover missing on outlet in prep ar a	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5813636 ISLAND VIBEZ JAMAICAN RESTAURANT & GRILL
 License Type: Permanent Food Service 5931 OLD WINTER GARDEN RD, ORLANDO 32835

Inspection Date: 04/14/2020 Inspection Number: 2969089 Inspection Type: Routine - Food Inspection Disposition: Call Back - Admin. complaint recommended
 Inspector Name: CONNOLLY, MADELINE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	- From initial inspection : Portable fire extinguisher missing from its designated location. For reporting purposes only Fire extinguisher on floor in kitchen - From follow-up inspection 2020-04-14: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Propane tank stored between handwashing sink in kitchen - From follow-up inspection 2020-04-14: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5807013

JOSIES PIZZA & WINGS

License Type: Permanent Food Service

1233 S HIAWASSEE RD, ORLANDO 328355702

Inspection Date: 04/13/2020

Inspection Number: 2969023

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: CONNOLLY, MADELINE

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only by exterior door behind customer restrooms - From follow-up inspection 2020-04-13: **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6216877

LA V

License Type: Permanent Food Service

441 CENTRAL AVENUE, ST. PETERSBURG 33701

Inspection Date: 04/16/2020

Inspection Number: 2965644

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: PORTER, LINDSAY

Violation CodeObservationViolation Citation

45-06-4

Portable fire extinguisher is inaccessible. For reporting purposes only. K class
blocked by table in kitchen509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

License Number: 6217242

CEDARS GRILL

License Type: Permanent Food Service

6549 54 AVE N, ST.PETERSBURG 33709

Inspection Date: 04/15/2020

Inspection Number: 2932118

Inspection Type: Routine - Food

Inspection Disposition: Emergency
order recommended

Inspector Name: HOBBS, ANDREW

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside
of the building. For reporting purposes only.
In dry storage room **Repeat Violation**509.032(2)(d) FS Reporting: (d) The division, or its
agent, shall notify the local firesafety authority or the
State Fire Marshal of any readily observable violation of
a rule adopted under chapter 633 which relates to public
lodging establishments or public food establishments,
and the identification of such violation does not require
any firesafety inspection certification. For reporting
purposes only.

Putnam County

License Number: 6400879

THIS & THAT CAFE

License Type: Permanent Food Service

700 ST JOHNS AVE, PALATKA 32177

Inspection Date: 04/13/2020

Inspection Number: 2970968

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small flattop grill on counter next to oven. Used to cook eggs, and heat bacon and sausage. ****Repeat Violation****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.