

**Broward County**

License Number: 1618533

BARGAIN FAMILY RESTAURANT

License Type: Permanent Food Service

728 S DIXIE HWY, HOLLYWOOD 33020

Inspection Date: 04/21/2020

Inspection Number: 2947005

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Complied

Inspector Name: BRANN, JUSTIN

Violation CodeObservationViolation Citation

48-03-4

- From initial inspection : Gas pressure cleaner inside restaurant . For reporting  
purposes only. - From follow-up inspection 2020-04-21: \*\*Time Extended\*\*509.211(2)(a) FS Reporting: (2)(a) It is unlawful for any  
person to use within any public lodging establishment or  
public food service establishment any fuel-burning  
wick-type equipment for space heating unless such  
equipment is vented so as to prevent the accumulation  
of toxic or injurious gases or liquids. For reporting  
purposes only.

License Number: 1613499

TACO BELL #132

License Type: Permanent Food Service

7625 W COMMERCIAL BLVD, TAMARAC 33351

Inspection Date: 04/20/2020

Inspection Number: 2958237

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: MATTIELLO-ATASSI, MARIA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only (x2)

509.032(2)(d) FS Reporting: (d) The division, or its  
agent, shall notify the local firesafety authority or the  
State Fire Marshal of any readily observable violation of  
a rule adopted under chapter 633 which relates to public  
lodging establishments or public food establishments,  
and the identification of such violation does not require  
any firesafety inspection certification. For reporting  
purposes only.

**Clay County**

License Number: 2001144

SONIC DRIVE IN #5411

License Type: Permanent Food Service

1801 TOWN CENTER BLVD, FLEMING ISLAND 32003

Inspection Date: 04/21/2020

Inspection Number: 2971593

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BIAVA, GRANT

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to rear exit to establishment, gauge in recharge state.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Columbia County**

License Number: 2200564

KRYSTALS

License Type: Permanent Food Service

2383 W US HWY 90, LAKE CITY 32055

Inspection Date: 04/20/2020

Inspection Number: 2949085

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Fire extinguisher next to hand washing sink in back of kitchen. \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2359245

YOYOS BURGERS

License Type: Mobile Food Dispensing Vehicle

600 W 27 ST, HIALEAH 33010

Inspection Date: 04/22/2020

Inspection Number: 1222006

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GONZALEZ, RICARDO

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Duval County**

License Number: 2613747

SONIC DRIVE IN #5373

License Type: Permanent Food Service

5080 BUTLER POINT RD, JACKSONVILLE 32256

Inspection Date: 04/20/2020

Inspection Number: 2971876

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: VILBRUN, JOSUE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.  
Fire extinguisher located by back door entrance has gauge in red zone

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Indian River County**

License Number: 4105345

MOE'S SOUTHWEST GRILL

License Type: Permanent Food Service

1601 US HWY 1, VERO BEACH 32960

Inspection Date: 04/20/2020

Inspection Number: 2955220

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Back door educated again \*\*Corrected On-Site\*\* \*\*Repeat Violation\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Lee County**

License Number: 4606198

MELODY'S CAFETERIA

License Type: Permanent Food Service

1000 LEE BLVD# 303, LEHIGH ACRES 33936

Inspection Date: 04/23/2020

Inspection Number: 2979039

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: JOHNSON, JONATHAN

Violation Code

Observation

Violation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Marion County**

License Number: 5202864

THE COURTYARD ON BROADWAY

License Type: Permanent Food Service

120 SW BROADWAY ST, OCALA 34471

Inspection Date: 04/23/2020

Inspection Number: 2911023

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: DRIGGERS, MANDY

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
One in main kitchen and one in catering kitchen.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.



**Monroe County**

License Number: 5428004

SUBWAY #30974

License Type: Permanent Food Service

91200 OVERSEAS HWY #5, TAVERNIER 33070

Inspection Date: 04/22/2020

Inspection Number: 2978937

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WHITEHURST, SCOTT

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Garbage cans in pathway to exit

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Orange County**

|                                      |  |   |  |
|--------------------------------------|--|---|--|
| License Number: 5812682              |  | DUE AMICI   |  |
| License Type: Permanent Food Service |  | 2124 EDGEWATER DR, ORLANDO 32804  |  |
| Inspection Date: 04/20/2020          | Inspection Number: 2938112   | Inspection Type: Routine - Food   | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: PLEICONES, KIM       |  |   |  |
| <u>Violation Code</u>                | <u>Observation</u>   | <u>Violation Citation</u>   |  |
| 46-01-4                              | Marked exit/path to marked exit blocked. For reporting purposes only.<br>Exit sign over door in back prep area, exit blocked by rolling rack and stock pot | 61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.       |  |
| License Number: 5811331              |  | PIZZA HUT   |  |
| License Type: Permanent Food Service |  | 2435 S ORANGE AVE, ORLANDO 32806  |  |
| Inspection Date: 04/23/2020          | Inspection Number: 2898452   | Inspection Type: Routine - Food   | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: PLEICONES, KIM       |  |   |  |
| <u>Violation Code</u>                | <u>Observation</u>   | <u>Violation Citation</u>   |  |
| 46-01-4                              | Marked exit/path to marked exit blocked. For reporting purposes only.<br>Exit door blocked by push cart, boxes and trash can                               | 61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.       |  |
| License Number: 5810322              |  | MELLOW MUSHROOM   |  |
| License Type: Permanent Food Service |  | 11680 E COLONIAL DR, ORLANDO 32817  |  |
| Inspection Date: 04/20/2020          | Inspection Number: 2956993   | Inspection Type: Routine - Food   | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: CONNOLLY, MADELINE   |  |   |  |
| <u>Violation Code</u>                | <u>Observation</u>   | <u>Violation Citation</u>   |  |
| 49-03-4                              | Flammables stored/debris present in boiler room. For reporting purposes only.<br><br>Multiple fabrics and cardboard items stored with hot water tank       | 61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.  |  |
| License Number: 5813368              |  | DOMINO'S PIZZA #8629  |  |
| License Type: Permanent Food Service |  | 9326 NARCOSSEE RD, ORLANDO 32827  |  |
| Inspection Date: 04/24/2020          | Inspection Number: 2904902   | Inspection Type: Routine - Food   | Inspection Disposition: Inspection Completed - No Further Action |
| Inspector Name: THORNCROFT, ROBERT   |  |   |  |
| <u>Violation Code</u>                | <u>Observation</u>   | <u>Violation Citation</u>   |  |
| 45-05-4                              | Portable fire extinguisher missing from its designated location. For reporting purposes only. At the back door sign indicating a fire extinguisher         | 509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only. |  |

**Orange County**

License Number: 5811413

PESAROS PIZZERIA

License Type: Permanent Food Service

3464 AVALON PARK E BLVD STE 108, ORLANDO 32828

Inspection Date: 04/23/2020

Inspection Number: 2945959

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Exit by bathrooms blocked by chairs, and equipment

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Osceola County**

License Number: 5911717

WENDY'S #12947

License Type: Permanent Food Service

2300 OLD CANOE CREEK ROAD, ST. CLOUD 34772

Inspection Date: 04/21/2020

Inspection Number: 2978630

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

49-03-4

Flammables stored/debris present in waterheater room. For reporting purposes only. **\*\*Corrected On-Site\*\***

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

**Palm Beach County**

License Number: 6021052

FLAVORS 27

License Type: Permanent Food Service

510 US HWY 27 N, SOUTH BAY 33493

Inspection Date: 04/22/2020

Inspection Number: 2954093

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: AHLE, ROBERT

Violation Code

Observation

Violation Citation

49-05-4

Flammables stored near a source of ignition. For reporting purposes only.  
observed 20gal Propane cylinder in kitchen near stove operator removed cylinder  
\*\*Corrected On-Site\*\* \*\*Repeat Violation\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.