

**Broward County**

License Number: 1623560

SOSTA CAFFE

License Type: Permanent Food Service

10800 PINES BLVD #5, PEMBROKE PINES 33026

Inspection Date: 04/27/2020

Inspection Number: 2941348

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BENJAMIN, ALEXANDER

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked by tables and chairs. Managers cleared path. For reporting purposes only. \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 1619742

EINSTEIN BROS BAGELS #847

License Type: Permanent Food Service

989 NOB HILL RD, PLANTATION 33324

Inspection Date: 04/28/2020

Inspection Number: 2953706

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: ROSE, MONIQUE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. \*\*Corrected On-Site\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 1620813

DON MATIAS RESTAURANT NO.2

License Type: Permanent Food Service

7788 NW 44 ST, SUNRISE 33351

Inspection Date: 04/28/2020

Inspection Number: 2971471

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MATTIELLO-ATASSI, MARIA

Violation CodeObservationViolation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only. At FE at front counter.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Dade County**

License Number: 2359011	CJS HOT SPOT		
License Type: Mobile Food Dispensing Vehicle	101 SW 15 ROAD, HOMESTEAD 33030		
Inspection Date: 04/29/2020	Inspection Number: 1217876	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: LEIDECKER, EDILMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-01-4	No portable fire extinguisher present. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2316948	TOTAL CAFETERIA		
License Type: Permanent Food Service	1401 NW 23 ST, MIAMI 33142		
Inspection Date: 05/01/2020	Inspection Number: 2947036	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: AZPURUA, JULIO			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 2 15lb propane tanks inside restaurant.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2328651	POLLO TROPICAL #55		
License Type: Permanent Food Service	11875 SW 26 ST, MIAMI 33175		
Inspection Date: 04/27/2020	Inspection Number: 2931610	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PICO, JORGE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
47-03-4	Observed electrical wiring in disrepair. For reporting purposes only. observed exposed electrical wires in walk in cooler.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

**Duval County**

License Number: 2609756

SUBWAY SANDWICHES &amp; SALADS IV

License Type: Permanent Food Service

11565 N MAIN ST #0206, JACKSONVILLE 322184088

Inspection Date: 05/01/2020

Inspection Number: 2979372

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: YOUNG, JENNIFER

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only.  
Exit door blocked by wooden panel \*\*Repeat Violation\*\*

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2615282

CATULLO'S ITALIAN

License Type: Permanent Food Service

1650 SAN PABLO RD S, #2, JACKSONVILLE 32224

Inspection Date: 04/29/2020

Inspection Number: 2973193

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PERRY, DENNIS

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.  
Multiple gas tanks stored in establishment. Tanks removed. \*\*Corrected On-Site\*\*

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Hillsborough County**

License Number: 3916718

SPRINGHILL SUITES BY MARRIOTT TAMPA NORTH

License Type: Permanent Food Service

5396 PRIMROSE LAKE CIR, TAMPA 33647

Inspection Date: 04/27/2020

Inspection Number: 2964448

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: MOULDER, BRITTANY

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.  
For reporting purposes only. \*\*Repeat Violation\*\*

61C-1.004(9) FAC Reporting: (9) Heating and ventilation  
- The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

**Indian River County**

License Number: 4105313

WOOD N SPOON

License Type: Permanent Food Service

2015 9TH ST SW SUITE 8, VERO BEACH 32962

Inspection Date: 05/01/2020

Inspection Number: 2943305

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: SCHOENLY, BARBARA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Lee County**

License Number: 4604108

MCDONALDS #13880

License Type: Permanent Food Service

1604 W CAPE CORAL PKWY, CAPE CORAL 33914

Inspection Date: 04/28/2020

Inspection Number: 2979225

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: EHMER, ANNETTE

Violation Code

Observation

Violation Citation

46-01-4 Marked exit/path to marked exit blocked. For reporting purposes only. Back door blocked by stacked chairs.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Manatee County**

License Number: 5102978

WINGS N THINGS

License Type: Permanent Food Service

7640 N LOCKWOOD RIDGE RD, SARASOTA 34243

Inspection Date: 04/29/2020

Inspection Number: 2937454

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: CARMASSI, BRADLEY

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Observed on extinguisher near rear kitchen door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Orange County**

License Number: 5808103	LANDRY'S SEAFOOD HOUSE		
License Type: Permanent Food Service	8800 VINELAND AVE, ORLANDO 32821		
Inspection Date: 04/28/2020	Inspection Number: 2964725	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OCASIO-LOPEZ, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

License Number: 5813025	BONEFISH GRILL		
License Type: Permanent Food Service	6730 CENTRAL FLORIDA PKWY, ORLANDO 32821		
Inspection Date: 04/28/2020	Inspection Number: 2973182	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: ANGEL, TERRY			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-03-4	Flammables stored/debris present in hot water heater room. For reporting purposes only.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.	

License Number: 5814653	CHEESECAKE FACTORY		
License Type: Permanent Food Service	11602 REGENCY VILLAGE DR, ORLANDO 32821		
Inspection Date: 04/28/2020	Inspection Number: 2964468	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: OCASIO-LOPEZ, LISA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	

License Number: 5809607	PANERA BREAD #3317		
License Type: Permanent Food Service	471 N ALAFAYA TRL, ORLANDO 32828		
Inspection Date: 04/28/2020	Inspection Number: 2963403	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: PICHARDO, RENEE			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	Oven exhaust not connected. Oven not in use.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	



**Orange County**

License Number: 5814744

PAPA LOZZI ITALIA

License Type: Permanent Food Service

504 N ALAFAYA TRL STE 105, ORLANDO 32828

Inspection Date: 04/30/2020

Inspection Number: 2951665

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Next to back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5814515

MAKI HIBACHI

License Type: Permanent Food Service

11954 NARCOOSSEE RD #1, ORLANDO 32832

Inspection Date: 04/28/2020

Inspection Number: 2969847

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Exit partial blocked by high chairs and bags of linen by bathrooms.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Osceola County**

License Number: 5911332

PISTANG PILIPINO

License Type: Permanent Food Service

4149 W VINE ST, KISSIMMEE 34741

Inspection Date: 04/29/2020

Inspection Number: 2979111

Inspection Type: Complaint Full

Inspection Disposition: Emergency order recommended

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system turned on.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911370

AVOCADO MEXICAN GRILL

License Type: Permanent Food Service

715 BLOOM ST, CELEBRATION 34747

Inspection Date: 05/01/2020

Inspection Number: 2963187

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LORENZO, ANA

Violation Code

Observation

Violation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only./ outlet missing in kitchen area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Palm Beach County**

License Number: 6020262

TRINDY GOURMET

License Type: Permanent Food Service

407 N ROSEMARY AVE, WEST PALM BEACH 33401

Inspection Date: 04/30/2020

Inspection Number: 2937489

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: HORTON, TIMOTHY

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Table Top fryer observed. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6006463

DOMINOS 5169

License Type: Permanent Food Service

836 W LANTANA RD, LANTANA 33462

Inspection Date: 04/27/2020

Inspection Number: 2978348

Inspection Type: Routine - Food

Inspection Disposition: Inspection  
Completed - No Further Action

Inspector Name: GONZALEZ, DENNIS

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Found empty boxes and bags of garbage blocking rear exit door.

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

**Pinellas County**

License Number: 6218036

WINGSTOP

License Type: Permanent Food Service

10125 ULMERTON RD, LARGO 33771

Inspection Date: 04/27/2020

Inspection Number: 2975313

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: LANTIGUA, ROBERTO

Violation Code

Observation

Violation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only. Operator awaiting final fire inspection test for hood suppression.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

**Polk County**

License Number: 6307811

RAINBOW PRIDE AND LOUNGE

License Type: Permanent Food Service

221 AVE T NE, WINTER HAVEN 33881

Inspection Date: 04/27/2020

Inspection Number: 2960817

Inspection Type: Routine - Food

Inspection Disposition: Call Back -  
Admin. complaint recommended

Inspector Name: WHITE, CHERYL

Violation Code

Observation

Violation Citation

45-04-4

- From initial inspection : Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed small electrical fryer being used to fry plantains. - From fo

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.