

Broward County

License Number: 1619121

CASA BORINQUEN

License Type: Permanent Food Service

6519 TAFT ST, HOLLYWOOD 33024

Inspection Date: 05/11/2020

Inspection Number: 2955077

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: BENJAMIN, ALEXANDER

Violation CodeObservationViolation Citation

47-03-4

Observed electrical wiring in disrepair. For reporting purposes only. Light fixture above fryer hanging by a wire. Water leaking down electrical wire through ceiling

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 1614235

MIAMI GRILL #16

License Type: Permanent Food Service

661 W SUNRISE BLVD, FORT LAUDERDALE 33311

Inspection Date: 05/12/2020

Inspection Number: 2966899

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: LEWIS, LYNDEN

Violation CodeObservationViolation Citation

45-05-4

Portable fire extinguisher missing from its designated location. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Columbia County

License Number: 2200738

CHILI'S

License Type: Permanent Food Service

2893 WEST US HWY 90, LAKE CITY 32055

Inspection Date: 05/15/2020

Inspection Number: 2980243

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GRODEWALD, PAUL

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler.
For reporting purposes only.
Water heater is 130 gallons. ****Repeat Violation****

61C-1.004(9) FAC Reporting: (9) Heating and ventilation
- The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Dade County

License Number: 2334993		TEXAS ROADHOUSE	
License Type: Permanent Food Service		33250 S DIXIE HWY, FLORIDA CITY 33034	
Inspection Date: 05/11/2020	Inspection Number: 2966921	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LEIDECKER, EDILMA			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
49-01-4	Flammables stored/debris present in meter room. For reporting purposes only. Observed cardboard boxes present in water heating room.	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.	
License Number: 2335768		RED ROOF PLUS+ MIAMI AIRPORT	
License Type: Permanent Food Service		3401 NW LEJEUNE RD, MIAMI 33142	
Inspection Date: 05/13/2020	Inspection Number: 2965436	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: HODGE, KRISTEN			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. Boiler certificate or insurance inspector's boiler report expired. For reporting purposes.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2331941		C R DISTRIBUTION CENTER	
License Type: Permanent Food Service		5534 NW 72 AVE, MIAMI 33166	
Inspection Date: 05/13/2020	Inspection Number: 2964224	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: LODENQUAI, BARRINGTON			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.	
License Number: 2332709		EL KONUCO CAFETERIA	
License Type: Permanent Food Service		8457 NW 61 ST, MIAMI 33166	
Inspection Date: 05/14/2020	Inspection Number: 2968145	Inspection Type: Routine - Food	Inspection Disposition: Call Back - Complied
Inspector Name: HERNANDEZ, NILYAM			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	- From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. - From follow-up inspection 2020-05-14: Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2327162

FRITANGA AIRPORT

License Type: Permanent Food Service

4441 NW 36TH ST, MIAMI SPRINGS 33166

Inspection Date: 05/12/2020

Inspection Number: 2979961

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HERNANDEZ, NILYAM

Violation CodeObservationViolation Citation

46-04-4

Exit door locked. For reporting purposes only. **Corrected On-Site**

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 2334928

PISCO Y NAZCA CEVICHE GASTROBAR

License Type: Permanent Food Service

8405 MILLS DR, SUITE 206, MIAMI 33183

Inspection Date: 05/11/2020

Inspection Number: 2949194

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: URIBE, GUISELLA

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed propane tanks on first and second floor. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Duval County

License Number: 2614386 PHILIP SUSHI XIE LLC
 License Type: Permanent Food Service 9475 PHILIPS HWY STE 20, JACKSONVILLE 32256

Inspection Date: 05/12/2020 Inspection Number: 2973718 Inspection Type: Routine - Food Inspection Disposition: Administrative complaint recommended
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. Chrome fire extinguisher on wall next to back door gauge in red zone.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2615372 SMKNQ
 License Type: Permanent Food Service 7111 BONNEVAL RD UNIT 8, JACKSONVILLE 32256

Inspection Date: 05/14/2020 Inspection Number: 2971751 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: VILBRUN, JOSUE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Flat top grill on cook line used to cook food with no hood suppression system. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hillsborough County

License Number: 3912619

SOUTH SORE PIZZA & SUBS INC

License Type: Permanent Food Service

3026 E COLLEGE AVE, RUSKIN 33570

Inspection Date: 05/11/2020

Inspection Number: 2966059

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MOULDER, BRITTANY

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only.

Observed mini fryer used with no hood system

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5801621

LEE & RICKS OYSTER BAR INC

License Type: Permanent Food Service

5621 OLD WINTER GDN RD, ORLANDO 32811

Inspection Date: 05/11/2020

Inspection Number: 2969085

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BACHOO, SAVITRI

Violation CodeObservationViolation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

License Number: 5813262

BONEFISH GRILL

License Type: Permanent Food Service

12301 LAKE UNDERHILL RD STE #101, ORLANDO 32828

Inspection Date: 05/14/2020

Inspection Number: 2956143

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PICHARDO, RENEE

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. At the back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5812241

Q KARAOKE

License Type: Permanent Food Service

4519 S ORANGE BLOSSOM TR, ORLANDO 32839

Inspection Date: 05/14/2020

Inspection Number: 2956422

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DIOP, DONALD

Violation CodeObservationViolation Citation

46-01-4

Marked exit/path to marked exit blocked. For reporting purposes only. Reach-in cooler impeding access to kitchen exit door.

61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Palm Beach County

License Number: 6020356

HOG SNAPPERS SHACK & SUSHI

License Type: Permanent Food Service

279 US HWY 1, TEQUESTA 33469

Inspection Date: 05/11/2020

Inspection Number: 2928380

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. small fryer/for sushi station./kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6200448

SUNSET GRILLE

License Type: Permanent Food Service

2996 DR MARTIN LUTHER KING JR ST N, ST. PETERSBURG 33704

Inspection Date: 05/13/2020

Inspection Number: 2979986

Inspection Type: Complaint Full

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: WAGNER, MARGARET

Violation Code

Observation

Violation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
 - observed 2 tanks indoors
 Both removed from building **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Polk County

License Number: 6350938

LA MICHOACANA MEX STORE

License Type: Mobile Food Dispensing Vehicle

1725 N MEMORIAL BLVD, LAKE LAND 33815

Inspection Date: 05/11/2020

Inspection Number: 1221805

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: GARCIA, GUADALUPE

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Operator replaced extinguisher. **Corrected On-Site**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Sarasota County

License Number: 6803462

GOLF SERENOA LLC

License Type: Permanent Food Service

6773 SERENOA DR, SARASOTA 34241

Inspection Date: 05/12/2020

Inspection Number: 2927195

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: SARCOMO, TONY

Violation Code

Observation

Violation Citation

47-03-4

- From initial inspection : Observed electrical wiring in disrepair. For reporting purposes only in back storage area by fire control panel - From follow-up inspection 2020-05-12: Company is hired to fix. **Time Extended** **Corrective Action Taken**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Seminole County

License Number: 6903233

ALI BABA HOUSE OF KEBAB

License Type: Permanent Food Service

1155 W SR 434 #105, LONGWOOD 32750

Inspection Date: 05/12/2020

Inspection Number: 2969033

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MONTGOMERY, DOREEN

Violation Code

Observation

Violation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building, on shelf under prep table, operator moved outside For reporting purposes only. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Volusia County

License Number: 7407507

BUILT CUSTOM BURGERS

License Type: Permanent Food Service

260 DAYTONA BLVD STE 440, DAYTONA BEACH 32114

Inspection Date: 05/11/2020

Inspection Number: 2969602

Inspection Type: Routine - Food

Inspection Disposition: Call Back -
Complied

Inspector Name: BRANNER, LISELOTTE

Violation CodeObservationViolation Citation

46-01-4

- From initial inspection : Marked exit/path to marked exit blocked. For reporting purposes only. Ladder and other items store in front door in common hallway by exit. - From follow-up inspection 2020-05-11: Manager states strip mall maintenance is coming to pick up ladder

61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 7450728

SANDPIPER SOUTH BEACH CONCESSIONS

License Type: Mobile Food Dispensing Vehicle

1722 STATE AVE, HOLLY HILL 32117

Inspection Date: 05/15/2020

Inspection Number: 1216153

Inspection Type: Routine - Food

Inspection Disposition: Emergency
order recommended

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

45-01-4

No portable fire extinguisher present. For reporting purposes only. Mobile concessions unit with no extinguisher

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 7404501

BOOTHILL SALOON

License Type: Permanent Food Service

310 MAIN ST, DAYTONA BCH 321184436

Inspection Date: 05/13/2020

Inspection Number: 2980109

Inspection Type: Complaint Partial

Inspection Disposition: Warning
Issued

Inspector Name: WOOD, JUSTIN

Violation CodeObservationViolation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Small table top fryers, Foreman grills in use with no hood suppression system. Notified Fire AHJ. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.