

Clay County

License Number: 2001379

NYC HOLEY MOLEY BAGEL SHOP

License Type: Permanent Food Service

179 COLLEGE DR, SUITE 19, ORANGE PARK 32065

Inspection Date: 05/29/2020

Inspection Number: 2979938

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MERCER, THOMAS

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Establishment has table top fryer on prep table with no hood system.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2332491

ASADOS EL PAISA

License Type: Permanent Food Service

11735 SW 147 AVE UNIT 25, MÍAMI 33196

Inspection Date: 05/26/2020

Inspection Number: 2980803

Inspection Type: Food-Licensing Inspection

Inspection Disposition: Call Back -
Complied

Inspector Name: AZPURUA, JULIO

Violation Code

Observation

Violation Citation

45-02-4

- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed class K extinguisher not charge. - From follow-up inspection
2020-05-26: Portable fire extinguisher gauge in red zone. For reporting purposes only.
Observed class K extinguisher not charge. **Time Extended**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Hernando County

License Number: 3701241

DAMICOS

License Type: Permanent Food Service

3206 AERIAL WAY, BROOKSVILLE 34604

Inspection Date: 05/26/2020

Inspection Number: 2974977

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAHL, MICHELE

Violation Code

Observation

Violation Citation

49-01-4

49-01-4 Observed: Establishment increased seating without providing written approval from the local fire authority and wastewater provider. License shows 30 seats, inspector count is 52.
Priority: Reporting

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Marion County

License Number: 5201325

MARYS PLACE

License Type: Permanent Food Service

5035 SE ABSHIER BLVD, BELLEVIEW 344203920

Inspection Date: 05/29/2020

Inspection Number: 2945429

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: DRIGGERS, MANDY

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Near back door

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5202677

PI ON BROADWAY

License Type: Permanent Food Service

110 S. W. BROADWAY, OCALA 34471

Inspection Date: 05/27/2020

Inspection Number: 2964708

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: DRIGGERS, MANDY

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.
Several tanks near exit door at bottom of stairs.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Martin County

License Number: 5301593

PANERA BREAD CAFE #3357

License Type: Permanent Food Service

2894 SW TOWN CENTER WAY, PALM CITY 34990

Inspection Date: 05/29/2020

Inspection Number: 2893596

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: PETROW, MICHAEL

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. Fire extinguisher by back door.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Osceola County

License Number: 5911687

MD CENTRAL FLORIDA LLC

License Type: Permanent Food Service

2714 OSCEOLA PKWY, KISSIMMEE 34741

Inspection Date: 05/27/2020

Inspection Number: 2946286

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: DAVIS, DIANNA

Violation Code

Observation

Violation Citation

45-06-4

Portable fire extinguisher is in the corner on the floor behind garbage container..

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6020661

GRIOT CARRIBEAN TAKE OUT LLC

License Type: Permanent Food Service

1558 PALM BEACH LAKES BLVD #5, WEST PALM BEACH 33401

Inspection Date: 05/27/2020

Inspection Number: 2980735

Inspection Type: Complaint Full

Inspection Disposition: Emergency order recommended

Inspector Name: MARTINEZ, RHEANNE

Violation Code

Observation

Violation Citation

45-04-4

Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Observed at prep table fryer-with no exhaust.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pinellas County

License Number: 6206242

MIXED GRILLE

License Type: Permanent Food Service

3001 COUNTRYSIDE BLVD, CLEARWATER 33761

Inspection Date: 05/28/2020

Inspection Number: 2970015

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: PEARCE, LAURA

Violation CodeObservationViolation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only. In wait station at beverage station opposite ice bin / soda dispenser near dining area

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6212548

THE BROWN BOXER PUB & GRILLE

License Type: Permanent Food Service

731 BAYWAY BLVD, CLEARWATER 33767

Inspection Date: 05/28/2020

Inspection Number: 2941006

Inspection Type: Routine - Food

Inspection Disposition: Administrative
complaint recommended

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation

49-01-4

Flammables stored/debris present in store room. Two gas cans. For reporting purposes only.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Volusia County

License Number: 7403951

HAMPTON INN DAYTONA SPEEDWAY AIRPORT

License Type: Permanent Food Service

1715 W INTERNATIONAL SPEEDWAY BLVD, DAYTONA BEACH 32114-1303

Inspection Date: 05/26/2020

Inspection Number: 2906850

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: BRANNER, LISELOTTE

Violation Code

Observation

Violation Citation

48-01-5

No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only.

61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.