

Collier County

License Number: 2102541 MYKONOS KUZINA
 License Type: Permanent Food Service 13510 TAMIAMI TRAIL N #1, NAPLES 34110

Inspection Date: 06/05/2020 Inspection Number: 2960413 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PFENNING, BRUNO

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-05-4	Portable fire extinguisher missing from its designated location. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2103492 MANA RESTAURANT GUATEMEX
 License Type: Permanent Food Service 275 NEW MARKET ST E, IMMOKALEE 34142

Inspection Date: 06/11/2020 Inspection Number: 2979314 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: JOHNSON, JONATHAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Dade County

License Number: 2329469		FINE FOOD EVENTS	
License Type: Catering		860 NE 79 ST STE B, MIAMI 33138	
Inspection Date: 06/08/2020	Inspection Number: 1114998	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 15 gallon tank inside kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329483		EXQUISITE BITES CATERING LLC	
License Type: Catering		860 NE 79 ST STE B, MIAMI 33138	
Inspection Date: 06/08/2020	Inspection Number: 1114987	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 15 gallon propane tank inside kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329601		PALATE CUISINE	
License Type: Catering		860 NE 79 ST UNIT B, MIAMI 33138	
Inspection Date: 06/11/2020	Inspection Number: 1115003	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 15 pound propane tank inside kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2329649		CHEF ANA	
License Type: Catering		860 NE 79 ST UNIT B, MIAMI 33138	
Inspection Date: 06/08/2020	Inspection Number: 1114989	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 15 gallon propane tank inside kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Dade County

License Number: 2329726		NILZA MARTINS FOOD SERVICES LLC	
License Type: Catering		860 NE 79 ST STE B, MIAMI 33138	
Inspection Date: 06/11/2020	Inspection Number: 1115090	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 15 Gallon propane tank inside kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2335672		MA GOURMET CATERING LLC	
License Type: Permanent Food Service		860 NE 79 ST, MIAMI 33138	
Inspection Date: 06/08/2020	Inspection Number: 2959646	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 15 gallon propane tank inside kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2336336		TASTE IT LLC	
License Type: Permanent Food Service		860 NE 79 ST STE B, MIAMI 33138	
Inspection Date: 06/11/2020	Inspection Number: 2955325	Inspection Type: Routine - Food	Inspection Disposition: Warning Issued
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 15 pound propane tank inside kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2336420		ROLLIN N SMOKIN BBQ	
License Type: Permanent Food Service		860 NE 79 ST STE B, MIAMI 33138	
Inspection Date: 06/11/2020	Inspection Number: 2964068	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: SEYBA, JAMES			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Observed 15 pound propane tank inside kitchen.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	

Duval County

License Number: 2614532		GERRY'S CAFE	
License Type: Permanent Food Service		4978 SOUDEL DR #101, JACKSONVILLE 32208	
Inspection Date: 06/11/2020	Inspection Number: 2967170	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: YOUNG, JENNIFER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Back exit door blocked by wooden board	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	
License Number: 2651662		ISLAND DREAM ITALIAN ICE	
License Type: Mobile Food Dispensing Vehicle		7841 LEM TURNER RD, JACKSONVILLE 32208	
Inspection Date: 06/11/2020	Inspection Number: 1215030	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: YOUNG, JENNIFER			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
45-04-4	Use of cooking equipment producing grease laden vapors/smoke with no hood suppression system installed. Notified Fire AHJ. For reporting purposes only. Small fryer no hood system	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2615675		SEVEN WONDER BAKERY AND CATERING	
License Type: Permanent Food Service		2145 UNIVERSITY BLVD N, JACKSONVILLE 32211	
Inspection Date: 06/10/2020	Inspection Number: 2959025	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: THOMAS, PHILIP			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Two 20 pound propane tanks stored in non working walk in cooler.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.	
License Number: 2614480		SHIRAZ PIZZA	
License Type: Permanent Food Service		3980 SOUTHSIDE BLVD #204, JACKSONVILLE 32216	
Inspection Date: 06/12/2020	Inspection Number: 2958163	Inspection Type: Routine - Food	Inspection Disposition: Inspection Completed - No Further Action
Inspector Name: GOSAI, MATT			
<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>	
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Rear exit blocked by boxes. Moved by manager. **Corrected On-Site**	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.	

Duval County

License Number: 2610891 SOUTHERN COAST SEAFOOD
 License Type: Permanent Food Service 1301 MONUMENT RD #1, JACKSONVILLE 322256462

Inspection Date: 06/10/2020 Inspection Number: 2978712 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: THOMAS, PHILIP

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. 20lbs Propane tank stored in dry storage. Operator removed tank from building. **Corrected On-Site**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 2613067 BAR-B-Q STICKS
 License Type: Permanent Food Service 120 1/2 LEMON ST, NEPTUNE BEACH 32266

Inspection Date: 06/11/2020 Inspection Number: 2976959 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: PERRY, DENNIS

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-01-4	Marked exit/path to marked exit blocked. For reporting purposes only. Exterior door was blocked by small tray stand.	61C-1.004(9) FAC: (9 Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

Lee County

License Number: 4606006

EL TARASCO MEXICAN RESTAURANT

License Type: Permanent Food Service

728 PINE ISLAND RD SW STE 8-9, CAPE CORAL 33991

Inspection Date: 06/10/2020

Inspection Number: 2982107

Inspection Type: Routine - Food

Inspection Disposition: Warning Issued

Inspector Name: EHMER, ANNETTE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
45-02-4	Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door. **Repeat Violation**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.
45-02-4	- From initial inspection : Portable fire extinguisher gauge in red zone. For reporting purposes only. By back door. **Repeat Violation** - From follow-up inspection 2020-06-12: **Time Extended**	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Marion County

License Number: 5201551

DALLAS INN

License Type: Permanent Food Service

16860 S HWY 301, SUMMERFIELD 34491

Inspection Date: 06/09/2020

Inspection Number: 2884318

Inspection Type: Routine - Food

Inspection Disposition: Administrative complaint recommended

Inspector Name: FIGUEROA-ROBLES, TATIANA

Violation Code

Observation

Violation Citation

45-02-4

Portable fire extinguisher gauge in red zone. For reporting purposes only.
At the bar area (under the counter) **Repeat Violation**

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Orange County

License Number: 5813727 CARIBBEAN FINGERS TASTE
 License Type: Permanent Food Service 4981 W COLONIAL DR, ORLANDO 32808

Inspection Date: 06/09/2020 Inspection Number: 2980390 Inspection Type: Food-Licensing Inspection Inspection Disposition: Warning Issued
 Inspector Name: GREENE, MARVIN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
46-04-4	Exit door locked. For reporting purposes only. Back door is blocked from outside with a brick wall.	61C-1.004(9) FAC: (9) Reporting: Means of access, including entrances, halls, and stairways, must permit unobstructed travel at all times and shall be clean, ventilated and well-lighted day and night. Hall and stair runners shall be kept in good condition. Railways, as defined in 61C-1.001(23), F.A.C., shall be installed on all stairways and around all porches and steps. For reporting purposes only.

License Number: 5803832 TRADEWINDS CAFE & BANQUET
 License Type: Permanent Food Service 6677 SEA HARBOUR DR, ORLANDO 32821

Inspection Date: 06/08/2020 Inspection Number: 2971172 Inspection Type: Routine - Food Inspection Disposition: Inspection Completed - No Further Action
 Inspector Name: LUI, SUK HAN

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-01-5	No current insurance inspector boiler report or boiler certificate available for boiler. For reporting purposes only./certificates expired. Inspections were done last month but certificates not available.	61C-1.004(9) FAC Reporting: (9) Heating and ventilation - The heating and ventilation system shall be kept in good repair or be installed to maintain a minimum of 68 degrees Fahrenheit throughout the building. The insurance inspector's boiler report is required annually for power boilers and high pressure/high temperature boilers and biannually for low pressure steam or vapor heating boilers and shall be posted in the boiler room. For reporting purposes only.

Osceola County

License Number: 5911139

PUNJAB KITCHEN

License Type: Permanent Food Service

5479 W IRLO BRONSON MEMORIAL HWY, KISSIMMEE 34746

Inspection Date: 06/09/2020

Inspection Number: 2971441

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: BELTRAN, SANDRA

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 5911483

THE CHATEAU LOUNGE

License Type: Permanent Food Service

4636 W IRLO BRONSON STE 1, KISSIMMEE 34746

Inspection Date: 06/10/2020

Inspection Number: 2971463

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: BELTRAN, SANDRA

Violation CodeObservationViolation Citation

48-04-4

Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Palm Beach County

License Number: 6019819

ARAMARK @ BIOMET 3I

License Type: Permanent Food Service

4600 E PARK DR, PALM BEACH GARDENS 33410

Inspection Date: 06/10/2020

Inspection Number: 2966195

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: ROTONDI, VICTOR

Violation Code

Observation

Violation Citation

47-03-4 Observed electrical wiring in disrepair. For reporting purposes only.electrical cover plate/broken/by mop area.

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

Pasco County

License Number: 6113669 THE SOCIAL
 License Type: Permanent Food Service 5650 MAIN ST, NEW PORT RICHEY 34652

Inspection Date: 06/11/2020 Inspection Number: 2966982 Inspection Type: Routine - Food Inspection Disposition: Warning Issued
 Inspector Name: TORRACO, MARIANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-04-4	Seating increase not reported. Upstairs roof top bar and dining area with 90 seats,	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.
49-04-4	- From initial inspection : Seating increase not reported. Upstairs roof top bar and dining area with 90 seats, - From follow-up inspection 2020-06-12: **Time Extended**	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

License Number: 6102186 ICON GENTLEMAN'S CLUB
 License Type: Permanent Food Service 18722-28 US HWY 19, HUDSON 346676693

Inspection Date: 06/09/2020 Inspection Number: 2971415 Inspection Type: Complaint Full Inspection Disposition: Call Back - Complied
 Inspector Name: TORRACO, MARIANNE

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
49-04-4	- From initial inspection : Flammables stored/debris present in laundry room. For reporting purposes only. Establishment operating with changed menu and/or increased seating without septic system approval for such change. Establishment did not report s	61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Pinellas County

License Number: 6217015

HOPS & PROPS

License Type: Permanent Food Service

335 2 AVE NE, ST. PETERSBURG 33701

Inspection Date: 06/10/2020

Inspection Number: 2966666

Inspection Type: Routine - Food

Inspection Disposition: Warning
Issued

Inspector Name: VALENCIA, ASHLEY

Violation CodeObservationViolation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

48-04-4 - From initial inspection : Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. In kitchen -
From follow-up inspection 2020-06-11: 2 in kitchen

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

License Number: 6215671

GREEK ISLAND RESTAURANT

License Type: Permanent Food Service

1501 CLEARWATER LARGO RD, LARGO 33770

Inspection Date: 06/08/2020

Inspection Number: 2956676

Inspection Type: Routine - Food

Inspection Disposition: Inspection
Completed - No Further Action

Inspector Name: KOUSTIS, TIMOTHY

Violation CodeObservationViolation Citation49-01-4 Flammables stored/debris present in storage room. For reporting purposes only.
Propane tank stored in storage room.

61C-1.004(6) FAC Reporting: (6) Attics, basements, boiler rooms, meter rooms, laundry rooms, and storage rooms shall be kept clean and free of debris and flammables. For reporting purposes only.

Sarasota County

License Number: 6805724

DARUMA

License Type: Permanent Food Service

4910 S TAMIAMI TRL #5147-122, SARASOTA 34231

Inspection Date: 06/12/2020

Inspection Number: 2976387

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: MCKEON, MICHAEL

<u>Violation Code</u>	<u>Observation</u>	<u>Violation Citation</u>
48-04-4	Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. Manager removed tanks.	509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.

St. Lucie County

License Number: 6602903

MAMMA MIA OSTERIA

License Type: Permanent Food Service

848 SE BECKER RD, PORT ST LUCIE 34984

Inspection Date: 06/11/2020

Inspection Number: 2971868

Inspection Type: Routine - Food

Inspection Disposition: Inspection Completed - No Further Action

Inspector Name: HYNES, MONICA

Violation Code

Observation

Violation Citation

48-04-4 Propane tank (larger than 2.7 lb. water capacity/1 lb. gas capacity) located inside of the building. For reporting purposes only. ****Corrected On-Site****

509.032(2)(d) FS Reporting: (d) The division, or its agent, shall notify the local firesafety authority or the State Fire Marshal of any readily observable violation of a rule adopted under chapter 633 which relates to public lodging establishments or public food establishments, and the identification of such violation does not require any firesafety inspection certification. For reporting purposes only.